

ATTACHMENT J-0200000-13
NATIONAL NAVAL MEDICAL CENTER FIRE DEPARTMENT
INTERIM LIFE SAFETY MEASURES

DATE _____ PROJECT # _____ BUILDING # _____

PROJECT NAME _____

1. Ensure free and unobstructed exits. YES ___ NO ___ N/A ___
2. Ensure free and unobstructed access to emergency forces. YES ___ NO ___ N/A ___
3. Ensure fire alarm, detection, and suppression systems are in good working order. YES ___ NO ___
4. Ensure temporary construction partitions are smoke tight and built of noncombustible or limited combustible materials that will not contribute to the development or spread of fire. YES ___ NO ___
5. Provide additional fire-fighting equipment and training personnel in its use. YES ___ NO ___
6. Prohibit smoking. YES ___ NO ___ N/A ___
7. Developing and enforcing storage, housekeeping, and debris removal practices that reduce the building's flammable and combustible fire load to the lowest feasible level. YES ___ NO ___ N/A ___
8. Conduct two fire drills per shift per quarter. YES ___ NO ___ N/A ___
9. Increase hazard surveillance of buildings, grounds and equipment, with special attention to excavations, construction areas, construction storage, and field offices. YES ___ NO ___ N/A ___
10. Training personnel to compensate for impaired structural or compartmentalization features of fire safety. YES ___ NO ___ N/A ___
11. Conducting organization wide safety education programs to promote awareness of LSC deficiencies, construction hazards, and ILSM. YES ___ NO ___ N/A ___

ADDITIONAL COMMENTS:

Temporary construction barriers will meet standards as outlined in NFPA 241.
Contractors shall maintain knowledge of the fire emergency response procedures as outlined in the NNMCINST 11320.1E instruction.

FIRE DEPARTMENT OFFICIAL _____

HOSPITAL ENGINEER _____

PROJECT INSPECTOR _____