

## 5.0 ROOM REQUIREMENTS

### MSAU HQ-BEQ

**Room Name: Office 134**

#### Space Characteristics

**Function:** Provides duty staff with a room to support a 24-hour operation.

**Adjacencies:** Open within the command suite. Contains separate copy room and mess area.

**Special Dimensions:**

Plan Dimensions or area: 528 SF

Minimum Ceiling Height: 10'-0" minimum ceiling height.

**Acoustics:** Walls: STC 50 (walls to adjacent rooms and spaces), **Doors: STC 45.** Floor/Ceiling assemblies shall have an Impact Isolation Class (IIC) of 50 (IIC 45 if field tested).

**Access:** Accessed directly from SGT Open Office and circulation.

**Number of Occupants:** Varies

**Other/Special Requirements:** Provide cable TV, camera network, "panic button" throughout the command suite.

Uniformat Section	Description	Qty	Size	Specific Requirements
C101001	Fixed Partitions			Concrete Masonry Units (CMU)
C101005	Interior Windows			Hollow metal frames. Shop primed and field painted.
C101007	Interior glazing			Tempered glazing where required.
C102001	Interior Doors	As Indicated	3X7	Provide solid core wood flush wood door in a factory stained finish and hollow metal frames (field painted).
C102003	Fire Doors			Where required.
C102007	Interior Door Hardware			Provide door gasketing, protection plates, stops, cores and cylinders as required, simplex lock and lock trim.
C103004	Identifying Devices			Wall mounted, architectural signage, include room number and name of function. Provide signage with changeable inserts.
C103007	Fire Extinguisher Cabinets	As needed		Prefinished, semi-recessed fire extinguisher cabinets. Provide rated cabinets in rated assemblies.
C103008	Counters	8'-0" LF		Solid surface counter tops with a 4" high back-splash.
C103009	Cabinets	8'-0" LF		Wall and base cabinets shall be custom grade per AWI with heavy duty hardware. Cabinets shall meet UFC 4-721-10N standards unless otherwise noted. All cabinets shall have a plastic laminated finish. Space for a full size refrigerator and microwave.
C103012	Firestopping Penetrations	As required		Penetration ratings shall match wall ratings.

**MSAU HQ-BEQ**  
**Room Name: Office 134**

Uniformat Section	Description	Qty	Size	Specific Requirements
C301002	Acrylic Plaster Coating			High Performance (impact resistant) seamless 10 mil minimum interior acrylic coating system shall be used as an interior wall finish over CMU.
C302004	Resilient Floor Finishes			VCT at Coffee Mess Area
C302005	Carpet Tile			Carpet Tile
C302007	Wall Base Finish		4" H	Rubber
C303001	Acoustical Tile and Grid		24" x 24"	Suspended Acoustical Ceiling Panels with a reveal edge and standard prefinished grid system.
C304001	Interior Coatings and Finishes			High Performance Latex Paint
D304001	Air Distribution, Heating and Cooling			Provide ventilation complying with latest ASHRAE 62.1 requirements. Provide continuous ventilation equal to exhaust, ventilation air is to be fully conditioned and at neutral conditions of 70 degrees F and maximum 50% RH.
D304007	Exhaust Systems			Provide continuous exhaust
D305003	Fan Coil Units			Provide horizontal 4-pipe fan coil unit with secondary drain pan
D306001	HVAC Controls			Provide DDC capable digital wall mounted thermostat. Thermostat will provide fan coil units with BACNET connectivity.
D4010	Fire Alarm and Detection Systems			Provide visible and audible notification appliance coverage in accordance with UFC 3-600-01 and UFC 4-021-01.
D4040	Sprinkler Systems			Provide wet-pipe sprinkler coverage in accordance with UFC 3-600-01.
D502001	Branch Circuit Wiring			Provide general purpose duplex receptacles for every 10' of wall space. Provide one quad receptacle for each desk; coordinate locations with D5030 outlets below.
D502002	Lighting Equipment			Target Illuminance = 50fc Fixture Type: Recessed volumetric LED Control: Vacancy Sensor + Switch + Dimming
D503001	Telecommunications Systems			3 – Combination voice and NMCI data outlets. 3 - OpenNet outlets adjacent to each voice/NMCI outlet.  1 – Combination voice and NMCI data outlet for copier Provide systems furniture connections without the use of systems furniture poles

**MSAU HQ-BEQ**  
**Room Name: Office 134**

<b>Uniformat Section</b>	<b>Description</b>	<b>Qty</b>	<b>Size</b>	<b>Specific Requirements</b>
D503004	Television Systems			Provide a CATV outlet, wall-mounted behind the equipment .
D503005	Security Systems			Provide pathway, cabling/wiring to DOS/MSAU Comm 107 Closet for MCESG official A/V Training.
E1090	Other Equipment			1 – Coffee maker 1 – Microwave 1 – Top Freezer Refrigerator