

PANELBOARD "P4RR"

NEMA 3R ENCLOSURE

DEVICE: 480V, 3PH, 3W, 60HZ

GROUND BUS

SHORT CIRCUIT BRACING: 10,000 AMPS

MAIN CIRCUIT BREAKER: 100A FRAME, 100A TRIP

CABINET: SURFACE

LOAD SERVED	HP	KVA A	KVA B	KVA C	CKT. NO.		CKT. NO.	KVA A	KVA B	KVA C	HP	LOAD SERVED	
HIGH BAY RETRACTABLE ROOF CONTROL PANEL	4@ 3/4	2.0			1		2	-				SPACE	
			2.0		3		4		-				SPACE
					2.0		5	6			-		SPACE
SPACE	-	-			7		8	-				-	SPACE
SPACE	-		-		9		10		-			-	SPACE
SPACE	-			-	11		12			-		-	SPACE
SPACE	-	-			13		14	-				-	SPACE
SPACE	-		-		15		16		-			-	SPACE
SPACE	-			-	17		18			-		-	SPACE

KVA PH A: 4.0 KVA PH B: 4.0 KVA PH C: 4.0

TOTAL CONNECTED LOAD: 2.0 KVA

PANEL LOCATION: FIXED ROOF 4 (FR-4)

ELECTRICAL NOTES:

1. REFER TO DRAWING E1 FOR ELECTRICAL LEGEND, GENERAL NOTES AND ABBREVIATIONS.
2. REFER TO DRAWING E5 FOR MOTORIZED ROOF LOCATIONS.

				<small>DEPARTMENT OF THE NAVY</small> <small>~ NAVAL FACILITIES ENGINEERING COMMAND ~</small> <small>NAVAL FACILITIES ENGINEERING COMMAND</small> <small>NAVAL STATION - NORFOLK, VIRGINIA</small>			
				PORTSMOUTH NAVAL SHIPYARD		KITTERY, ME	
	COMPLETION OF DD #3 PROPULSOR ENCLOSURE						
	HIGH BAY RETRACTABLE ROOF SUPPLEMENTAL DETAILS						
	REV	DESCRIPTION	DATE	APPRVD	SIZE	CONSTR. CONTR. NO.	DWG NO. <i>SK2</i>
REVISIONS							
DESIGN	DRAWN	CHECKED	DATE	SCALE	<i>N.T.S.</i>		SHEET <i>2 OF 2</i>