



STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS
HISTORICAL PRESERVATION & HERITAGE COMMISSION

Old State House • 150 Benefit Street • Providence, R.I. 02903-1209

TEL (401) 222-2678

FAX (401) 222-2968

TTY (401) 222-3700

Website www.preservation.ri.gov

10 March 2008

Mr. D.D. Dorocz
Department of the Navy
Environmental Department Head
Naval Station Newport
690 Peary Street
Newport, Rhode Island 02841-1522

Re: Renovations, Building 302, US Naval War College
Coasters Harbor Island, Naval Station Newport

Dear Mr. Dorocz:

The Rhode Island Historical Preservation and Heritage Commission staff has reviewed the information that you have provided for the replacement of windows in Building 302.

The initial review of replacement of windows for this building was granted for a thermopane window that would "otherwise match the existing windows" (Sanderson 5/21/07). On January 30, 2008, this office received a letter from you outlining a change in the Navy's proposal, by which the desired replacement windows are now "Wood Ultimate Double Hung" windows. It is our conclusion that provided that the sash and pane configurations of the "Wood Ultimate Double Hung" windows match the existing windows, the replacement will cause no adverse effect to the building.

These comments are provided in accordance with Section 106 of the National Historic Preservation Act. Please contact Jeffrey Emidy, Project Review Coordinator of this office, with any questions.

Very truly yours,

FOR Edward F. Sanderson, Executive Director
Deputy State Historic Preservation Officer

cc: Shannon Kam, Naval Station Newport

080310.03jde

MAR 18 2008



STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS
HISTORICAL PRESERVATION & HERITAGE COMMISSION

Old State House • 150 Benefit Street • Providence, R.I. 02903-1209

TEL (401) 222-2678

FAX (401) 222-2968

TTY (401) 222-3700

Website www.preservation.ri.gov

18 January 2008

Mr. D.D. Dorocz
Department of the Navy
Environmental Department Head
Naval Station Newport
690 Peary Street
Newport, Rhode Island 02841-1522

Re: Renovations, Building 302, US Naval War College
Coasters Harbor Island, Naval Station Newport

Dear Mr. Dorocz:

The Rhode Island Historical Preservation and Heritage Commission staff has reviewed the information that you have provided for the roof covering of Building 302.

The initial review of a replacement roof for this building centered on the Navy's proposal to use an EPDM membrane roof. On January 7, 2008, this office received a letter from you outlining a change in the Navy's proposal, by which a PVC roof, rather than EPDM, is now the desired material. The existing roof of Building 302 is black, while the PVC roof is available only in white and light gray. It is our conclusion that the light gray PVC roof is an acceptable material for the replacement of the roof on Building 302, and will cause no effect to the building.

These comments are provided in accordance with Section 106 of the National Historic Preservation Act. Please contact Jeffrey Emidy, Project Review Coordinator of this office, with any questions.

Very truly yours,

Ed Edward F. Sanderson, Executive Director
Deputy State Historic Preservation Officer

cc: Shannon Kam, Naval Station Newport