

**PRE-QUOTATION INQUIRY (PQI) 02**  
**N40192-15-Q-7004**  
**26 JAN 2016**

No.	Date	Questions (Should include Specification Section or Drawing Reference)	Answers
1	1/22/2016	<p>Has a contractor performed similar work to this for the government in the past?            If available, please provide the incumbent contract number.</p> <p>If you are unable to provide a contract number, is it safe to assume this is a new requirement for the government?</p>	<p>The most recent similar requirement is purchase order #N40192-16-P-7003 – Lease of Portable Office Space at North Ramp and Bldg. 2510, AAFB, Guam.</p>
2	1/25/2016	<p>a) What is the required wind load?</p> <p>b) Can the trailers be secured with screw anchors?</p>	<p>a) Minimum is 170 mph</p> <p>b) No, because they will be placed on the flight line and cannot drill into the parking spots.</p>
3			
4			
5			
6			
7			
8			
9			
10			

**Note: Submit this worksheet as an e-mail attachment.**