

PRE-QUOTATION INQUIRY (PQI) 03
N40192-15-Q-7004
27 JAN 2016

No.	Date	Questions (Should include Specification Section or Drawing Reference)	Answers
1	1/22/2016	<p>Has a contractor performed similar work to this for the government in the past? If available, please provide the incumbent contract number.</p> <p>If you are unable to provide a contract number, is it safe to assume this is a new requirement for the government?</p>	<p>The most recent similar requirement is purchase order #N40192-16-P-7003 – Lease of Portable Office Space at North Ramp and Bldg. 2510, AAFB, Guam.</p>
2	1/25/2016	<p>a) What is the required wind load?</p> <p>b) Can the trailers be secured with screw anchors?</p>	<p>a) Minimum is 170 mph</p> <p>b) No, because they will be placed on the flight line and cannot drill into the parking spots.</p>
3	1/26/2016	<p>a) Is this solicitation an ALL or NONE request?</p> <p>b) Per Attachment -1 dated 21 Jan 2016, it requests for 2 ea. 80KW diesel generators, however there is no CLIN line item for this unit?</p> <p>c) Per Attachment -1 dated 21 Jan 2016, it requests for 1 ea. HazMat storage container however there is no specification for the size of the HazMat unit and there is no CLIN line item for this unit?</p> <p>d) Please clarify if the vendor will only have 5 days for delivery and set-up from NTP date?</p>	<p>a) All</p> <p>b) The CLINs will be established on the purchase order.</p> <p>c) Drum capacity is minimum (6 each) 55 gal. The CLINs will be established on the purchase order.</p> <p>d) Yes - only 5 days are given for delivery and set-up from award date.</p>
8			
9			
10			

Note: Submit this worksheet as an e-mail attachment.