

STATEMENT OF WORK

Fire Equipment Inspection, Testing and Maintenance Service

Scope of Work: The contractor shall provide required Inspection, Testing and Maintenance Service of the Fire Equipment identified in this SOW at the below listed installations and stations:

1. Naval Base Ventura County (NBVC), CA 93042 encompassing the four (4) fire stations listed below:
 - a. NBVC Point Mugu Station 71, 391 Ronald Reagan, Point Mugu, CA 93042
 - b. NBVC Point Mugu Station 72, 642 Ronald Reagan, Point Mugu, CA 93042
 - c. NBVC Port Hueneme Station 73, 430 Patterson Rd., Port Hueneme, CA 93043
 - d. NBVC St. Nicholas Island Station 74, 144 Monroe Dr., San Nicholas Island, CA 93042

2. Naval Air Station Lemoore (NASL), 770 Franklin Ave. NAS Lemoore CA 93246 encompassing one (1) fire station below:
 - a. NASL Station 61, 770 Franklin Ave. NAS Lemoore CA 93246

3. Naval Base Coronado and San Diego Metro (Metro), CA 92136 encompassing the eleven (11) fire stations listed below:
 - a. NB Coronado Regional Training Compound, 473 Rogers Road, Coronado, CA 92135
 - b. NB Coronado Station 11, 792 Hanger Rd, Coronado, CA 92135
 - c. NB Coronado Station 12, 33 Saufley Rd. Coronado, CA 92135
 - d. NB Coronado Station 13, 19 Kwajalein Rd, Coronado, CA 92135
 - e. NB Coronado Station 14, 1498 13th St, Bldg 5, Imperial Beach, CA 91932
 - f. NB San Diego Station 16, 52 Kalbfus Rd, San Diego, Ca 92136
 - g. NB San Diego Station 17, 3359 Norman Scott Rd, San Diego, CA 92136
 - h. NB San Diego Station 18, 34800 Bob Wilson Dr, San Diego Ca 92140
 - i. NB San Diego Station 19, 614 Belleua Ave, San Diego, CA 92140
 - j. NB San Diego Station 110, 140 Sylvester Rd, San Diego, CA 92106
 - k. NB San Diego Station 111, 271.5 Catalina Blvd, San Diego, CA 92106
 - l. NBC San Clemente Island Station 112, 60143 San Clemente Island, CA 92672

4. Naval Weapons Station Seal Beach (NWSSB), Bldg 203; 800 Seal Beach Blvd, Seal Beach, CA 90740 encompassing one (1) fire station below:
 - a. NWS Seal Beach, Station 31, Bldg 203; 800 Seal Beach Blvd, Seal Beach, CA 90740

Applicable Documents:

1. NFPA 1989: Standard on Breathing Air Quality for Emergency Services Respiratory Protection, 2013 Edition

2. Manufacturers manuals

Requirements:

In consideration of compensation in the amount set forth below, the contractor agrees to perform and/or provide the following:

1. For NBVC, provide qualified personnel to complete inspection, testing and/or maintenance as required on the following identified fire equipment:
 - a. Inspection, testing and maintenance of five (5) respiratory protection air supply air compressors of which one (1) mobile compressor is at Station 71/Bldg 391, two (2) stationary/mobile compressors is at Station 72/Bldg 642, one (1) stationary compressor is at Station 73/Bldg 430 and one (1) stationary compressor is at Station 74/Bldg 144 on SNI, beginning on mutually agreed upon dates between 20 July 2015 and 30 September 2015 in accordance with NFPA 1989: Standard on Breathing Air Quality for Emergency Services Respiratory Protection, 2013 Edition and manufacturers requirements.
2. For NASL, provide qualified personnel to complete inspection, testing and/or maintenance as required on the following identified fire equipment:
 - a. Inspection, testing and maintenance of two (2) respiratory protection air supply air compressors of which one (1) stationary compressor is at Station 61/Bldg 770 and one (1) mobile compressor is at Station 62/Bldg 190, beginning on mutually agreed upon dates between 20 July 2015 and 30 September 2015 in accordance with NFPA 1989: Standard on Breathing Air Quality for Emergency Services Respiratory Protection, 2013 Edition and manufacturers requirements.
3. For Metro, provide qualified personnel to complete inspection, testing and/or maintenance as required on the following identified fire equipment:
 - a. Inspection, testing and maintenance of six (6) respiratory protection air supply air compressors of which one (1) stationary compressor is at Regional Training Center on NB Coronado /Bldg 473, two (2) stationary/mobile compressors is at Station 11/Bldg 792, two (2) stationary/mobile compressors is at Station 17/Bldg 3359 and one (1) stationary compressor is at Station 112/Bldg 60143 on SCI, beginning on mutually agreed upon dates between 20 July 2015 and 30 September 2015 in accordance with NFPA 1989: Standard on Breathing Air Quality for Emergency Services Respiratory Protection, 2013 Edition and manufacturers requirements.
4. For NWSSB, provide qualified personnel to complete inspection, testing and/or maintenance as required on the following identified fire equipment:
 - a. Inspection, testing and maintenance of one (1) respiratory protection air supply air compressor beginning on mutually agreed upon dates between 20 July 2015 and 30 September 2015 in accordance with NFPA 1989: Standard on Breathing

Air Quality for Emergency Services Respiratory Protection, 2013 Edition and manufacturers requirements.

5. Provide all required consumables and tools required to complete maintenance at all locations. Equipment will be made accessible as required.

Qualifications:

Contractor shall provide personnel who are qualified to perform all fire equipment inspection, testing and maintenance in accordance with manufacturers and NFPA requirements.

Period of Performance: 20 July 2015 through 30 September 2015

Work Environment and Government Furnished Equipment: Each Fire Department &ES shall provide fire equipment as needed. Local Points of Contact (POCs) will be provided to vendor to assist with maintenance. Access to the space may be granted on weekends and Federal Holidays via POCs. The contractor may use these facilities as necessary to complete the required tasking.

Physical Security: The contractor shall be responsible for safeguarding all Government property provided for contractor use.