

AMENDMENT #2

Question	Answer
We need to qualify the Kelvin color temp to make sure you receive the correct LED light and that we meet the requirement of Pearl Harbor.	Any kelvin color temp will be accepted as long as the 70 watt LED and 120 volt supply requirement in the solicitation is met.
Is there a bid form that we should complete for this?	There is no specific bid form to complete. Offerors need to submit quotes that include information as requested in the solicitation.