

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE J	PAGE OF PAGES 1 3
2. AMENDMENT/MODIFICATION NO. 0002	3. EFFECTIVE DATE 25-Mar-2016	4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO.(If applicable)
6. ISSUED BY NAVFAC EUROPE AFRICA SOUTHWEST ASIA VIALE PORTO CAPODICHINO NAPOLI 80144	CODE N33191	7. ADMINISTERED BY (If other than item 6) See Item 6		
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)		X	9A. AMENDMENT OF SOLICITATION NO. N33191-16-R-1026	
		X	9B. DATED (SEE ITEM 11) 10-Mar-2016	
			10A. MOD. OF CONTRACT/ORDER NO.	
			10B. DATED (SEE ITEM 13)	
CODE	FACILITY CODE			
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS				
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.				
12. ACCOUNTING AND APPROPRIATION DATA (If required)				
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.				
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.				
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).				
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:				
D. OTHER (Specify type of modification and authority)				
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.				
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) Amendment 0002 issued to provide additional PPI response and alternate Point of Contact.				
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.				
15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
		TEL:	EMAIL:	
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA		16C. DATE SIGNED
_____ (Signature of person authorized to sign)		BY _____ (Signature of Contracting Officer)		25-Mar-2016

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

SECTION SF 30 - BLOCK 14 CONTINUATION PAGE

The following have been added by full text:

AMENDMENT 0002

Amendment 0002 is being issued to provide the following:

1. an updated list of the Official Government responses to the Pre-Proposal Inquiries; and
2. an alternate point of contact for pre-proposal inquiries.

Please ensure that both of the following individuals are copied on all communications regarding this procurement:

Primary Point of Contact: Ms. Cherie Mitchell, email cherie.mitchell@eu.navy.mil

Secondary Point of Contact: Mr. Jose Rodriguez, email Osvaldo.Rodriguez@eu.navy.mil

Updated list of Pre-Proposal Inquiries and Official Government Responses:

RFI	Offeror/Contractor Inquiry	Official Government Response
1	We have not found form the past performance and experience forms in the attachments. Please provide forms.	The following attachments are being provided as part of Amendment 0001: Attachment A - Construction Design Experience Data Sheet; Attachment 1 PPI Government Response Listing; Attachment 2 PPQ; Attachment 3 PPI Form; and Country Clearance Requirements.
2	The following attachments have not been included: Construction Experience Project Data Sheet (Attachment A) and Past Performance Questionnaire (PPQ). If possible a word version would be appreciated.	see above
3	Is this solicitation open to foreign vendors	Yes, this solicitation is open to foreign vendors.
4	Does the Navy intend to hold a pre-bid job site visit?	Originally the Navy did not intend on providing a site visit, however, as a result of the RFI, the determination has been made to hold one. The site visit is optional. Site visit details will be provided in Amendment 0001.

5	<p>SAM is not yet approved. What are our options to still be able to subscribe to this work?</p> <p>The documents also refer to a certificate of clasification, is this for Spanish authority?</p> <p>Group Sub-Group Category F 1 F</p>	<p>Proof of SAM registration should be submitted with your proposal . This can just be a screenshot of your pending registration.</p> <p>Certificate of classification is required by the Spanish Government for work performed in Spain. Please contact the Ministerio de Economia y Hacienda (Spanish Government) for information on how to qualify your firm for this category of work.</p>
6	<p>Drawing Sheet C-101 is missing the perimeter outlines for Dredge Areas No. 1, 2, and 4. Is it possible to get a revised drawing that better depicts the perimeters of these areas?</p>	<p>Revised drawing is being provided as part of Amendment 0001. Drawing title: HCMDROTA-1366775-C-101.</p>
7	<p>Drawing Sheet C-101 - it appears there is shallow water (-3m) and limited space located on the north end of Pier 3 between Dredge Area 5 and Dredge Area 1. Will the contractor be allowed to dredge an access path around the north end of Pier 3 to gain access to the area behind it (Area 3)?</p>	<p>Yes, however, the dredge depth of this "access path" may not exceed the proposed dredge depth of the adjacent Area 5 (-9.00m).</p>
8	<p>Can the Navy provide contact information for local marine fuel suppliers and tow boat companies?</p>	<p>The Navy cannot provide the information. The Contractor is responsible to secure all material suppliers and subcontractors that are required to complete the project.</p>

(End of Summary of Changes)