

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE J	PAGE OF PAGES 1 5
2. AMENDMENT/MODIFICATION NO. 0003	3. EFFECTIVE DATE 02-May-2016	4. REQUISITION/PURCHASE REQ. NO. ACQR4201110		5. PROJECT NO.(If applicable)
6. ISSUED BY NAVFAC EXWC CODE ACQ / NAVAL BASE VENTURA COUNTY 1100 23RD AVE BLDG 1100 PORT HUENEME CA 93043-4301	CODE N39430	7. ADMINISTERED BY (If other than item 6) See Item 6		
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)		X	9A. AMENDMENT OF SOLICITATION NO. N39430-16-R-1830	
		X	9B. DATED (SEE ITEM 11) 28-Mar-2016	
			10A. MOD. OF CONTRACT/ORDER NO.	
			10B. DATED (SEE ITEM 13)	
CODE	FACILITY CODE			
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS				
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u>4</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.				
12. ACCOUNTING AND APPROPRIATION DATA (If required)				
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.				
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.				
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).				
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:				
D. OTHER (Specify type of modification and authority)				
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.				
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) Respond to Requests for Information resulting from seed tasks site visits				
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.				
15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
		TEL:	EMAIL:	
15B. CONTRACTOR/OFFEROR _____ (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED 02-May-2016

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

SECTION SF 30 - BLOCK 14 CONTINUATION PAGE

The following have been added by full text:

AMENDMENT 03

The purpose of this amendment is to respond to the following Requests for Information:

Q28. Section L states to submit “*Standard Form 33, Solicitation, Offer, and Award and all its Amendments in Standard Form 30.*”

Is it acceptable to submit a signed complete SF33 with Block 14 completed acknowledging receipt of the amendments instead of completing Blocks 15 a-c of each SF30 and submitting a copy?

A28. Yes

Q.29 The organization of Volume II Price is outlined under item L.2(1)j. as:

1. Cover Letter
2. A completed Schedule of Firm Fixed Price Rates (Attachment A), including the Base period and four option years.
3. The total price for performing Seed Task X001 (Offeror’s own format).
4. The total price for performing Seed Task X002 (Offeror’s own format).
5. A completed financial questionnaire from the offeror’s primary financial institution (Attachment B).

Section L.4(6) provides the requirements in a different order. Please confirm offerors are to use the organization in L.2(1)j rather than the requirements order in L.4(6).

A29. The proposal will follow the organization of Volume II Price is outlined under item L.2(1)j.

Q30. Instruction for Factor 6, item (i)a asks for “...the company financial statement for the most recent completed financial accounting year.” Please confirm it is acceptable to place the Financial Statement behind the Financial Institution Information (Attachment B).

A30. Yes.

Q31. Factor 6, Price (i) (k) Subcontractor Costs appears to have a fixed amount per year. Is it the Government's intent that each bidder should bid the specified amounts listed with applicable burdens in the Attachment A? If Subcontractor Pricing is required, what level of detail will be required?

A31 Yes. Please utilize the costs provided (\$750,000). No subcontractor pricing detail is required.

Q32. We plan to use a commercial carrier (i.e., FedEx, UPS, USPS) for the delivery of our proposal but have experienced problems with this method at other bases in the past. Please identify if NAVFAC-EXWC or Port Hueneme has a preferred carrier we should use for proposal delivery. Also, will we need to make any special arrangements or provide any special instructions to the carrier?

A32. While there is no “preferred” carrier; FedEx makes multiple deliveries to Bldg. 1100’s shipping and receiving on a daily basis. Items sent via USPS are sent to another building first. Deliveries by UPS have been problematic in the past because some of the drivers are unaware of the shipping and receiving location at Bldg. 1100. As long as the address that is provided in section L.3 (3) (Page 54 of the solicitation) is utilized, no additional instructions are required.

The following questions are related to **Related to Seed 1 - SDVT1, PEARL CITY, HAWAII INSTALL**

Q33. Though the Facility provided a disk of pictures at the site visit, attendees were not allowed to take any pictures. In order to identify any interferences and necessary installations, please provide additional pictures of the high bay area where all of the panels and sinks are to be located.

A33. No additional picture will be provided.

Q34. Please confirm that the Government/Facilities will be responsible for the final electrical connection for the high pressure compressors and dryers.

A34. Yes.

Q35. Under Item 1.1.3, item f. Compressor Room indicates the inclusion of the Gas Distribution Panel. There is no call out in the PWS for a "Gas Distribution Panel" in the compressor room, although there is a sketch of it on page C47, Figure 1. Is the offeror responsible for providing the Gas Distribution panel ?

A35 Yes, the winning contractor is responsible for procuring the new Gas Distribution Panel.

Q36. There is a Pool Remote Alarm Panel 2 that may need to be moved to accommodate the SCUBA sink. Will the Government/Facility be responsible for moving this panel, if required?

A36. The winning contractor will not responsible for moving Pool Remote Alarm Panel 2 if required.

Q37. The eight ½" electrical conduits running from the floor to approx. 8' in height pose a potential electrical hazard with the required SCUBA sink mounting in vicinity of the conduit. Will the government or contractor be responsible for mitigation of risk/danger with these electrical lines and sink?

A37. The winning contractor will not be responsible for moving these conduits if required.

Q38. There are other miscellaneous electrical knife switches (approximately 4) that appear to be in the way of Air and O2 panels. Will the Government/Facility be responsible for moving the switches, if required?

A38. The winning contractor will not be responsible for moving this electrical equipment if required.

Q39. There is no requirement in the PWS for flex hose saddles for the GFE umbilical hoses (3) or the Vehicle Charging Station hoses (4). Will the Government/Facility be responsible for providing these items?

A39. The winning contractor shall provide two (2) umbilical saddles.

Q40. There is no request in the PWS Attachment G for a stainless steel enclosure for the booster pump. Please confirm this enclosure/cabinet will be provided by the Government/Facility.

A40. The stainless steel enclosure in this location should house both the charging panel and the booster pump. A floor mounted enclosure such as the type with a roll up door would be recommended in this location.

Q41. To facilitate demolition of the air system flasks, please confirm the Government/Facility will remove all fencing from the entire area of the Gas Farm.

A41. The Government will not be removing the fence around the Gas Farm to facilitate removal of the flasks. The winning contractor will be responsible for removal and restoration of the fencing if they feel it is necessary

The following questions are related to **Related to Seed 2 - EGLIN AFB NAVSCOLEOD OVERHAUL**

Q42. During the site visit, the Facility/Government representative indicated that there will be a revision to the PWS Attachment H including Sections 3.2.12 and 3.2.13 and Figure 7. Please confirm when offerors can expect this revised PWS.

A42. Revised Figure 7 attached. For clarification: The existing Diluent Panel is to be removed from the system. The Mk 16 Charging Panel will be overhauled as described in 3.2.13 and moved to the current location of the Diluent Panel and become the "MK-16 Air Charging Panel" as shown in the revised Figure 7. Two new panels shall be fabricated. These are the MK-Oxygen Charging Panel and the MK16 Oxygen Charging Manifold as shown in the updated Figure 7.

Q43. Revisions are to be made to Sections 3.2.12 and 3.2.13 along with Figure 7. Will there be an opportunity to ask additional questions in regards to these changes, if needed?

A43. No.

Q44. For the Panels that are required to be Powder Coated, has there been any testing to confirm that the powder will adhere since they are Anodized?

A44. No.

Q45. The concrete pad is sloped, so when the flask banks are rotated 90 degrees, will we be required to engineer/manufacture a slope for the flask drains to work properly?

A45. No.

Q46. Please confirm that the SCV-AHP-1, SCV-AHP-2, SCV-AHP-3 and SCV-AHP-4 are ½" CPV stop check valves that offerors are to replace and not globe valves.

A46. The winning contractor shall replace these 4 valves with Mil-STD-24108 Stop Check Valves.

Q47. The Quick Disconnects (QD) in this section are the only ones specified as "Tomco" with a designated part number. For all other QDs, are we replacing with current Snavite QDs?

A47. Yes.

Q48. Will the GTS Panel remain in its current location and not be demolished with the Diluent Panel? Can this panel be modified to hold the 6 QDs as in Figure 7?

A48. See description of MK-16 Charging above.

Q49. We understand from the site visit that the MV-OX-1 metering valve and the Swagelok Piping that is downstream of it are to be replaced. The piping upstream appears to be the same. Clarification is needed for the downstream piping.

A49. Only the section of piping downstream of MV-OX-1 is to be replaced.

Q50. HC-1 and HC-2 – ½" Ball Valves were not located in the Inner Lock. Please confirm the Facility/Government is responsible for adding these to the Inner Lock

A50. HC-1 and HC-2 are the interior ball valves for the ACS system. These valves are incorrectly labelled CVHC-1 and CVHC-2 on Figure 6.

Q51. Drawings were not found at site visit, confirming that we are still waiting on these and that this is to be provided to us by NAVFAC.

A51. There are currently no drawings of the viewport housing assemble. The winning contractor would have to measure the housing to determine the correct sizing for the required viewports.

Q52. The Comms Box that is currently in the Inner Lock does not have a temperature probe and one cannot be added. Please confirm if a new Comms box with temperature probe is required or just a separate temperature gauge.

A52. This refers to a separate temperature gauge.

Q53. Please define piping supports. Does piping supports mean only the pipe clamps or does this include the uni-struts as well?

A53. This only refers to pipe clamps.

The close date for submission of proposals remains at 11 May 2016.

(End of Summary of Changes)