

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE J	PAGE OF PAGES 1 4
2. AMENDMENT/MODIFICATION NO. 0008	3. EFFECTIVE DATE 19-Feb-2015	4. REQUISITION/PURCHASE REQ. NO. ACQR3882622		5. PROJECT NO.(If applicable)
6. ISSUED BY NAVAL FACILITIES ENG COMMAND WASHINGTON 1314 HARWOOD ST. WASHINGTON DC 20374	CODE N40080	7. ADMINISTERED BY (If other than item 6) See Item 6		
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)		X	9A. AMENDMENT OF SOLICITATION NO. N40080-14-R-0312	
		X	9B. DATED (SEE ITEM 11) 29-Dec-2014	
			10A. MOD. OF CONTRACT/ORDER NO.	
			10B. DATED (SEE ITEM 13)	
CODE	FACILITY CODE			
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS				
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input checked="" type="checkbox"/> is extended, <input type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.				
12. ACCOUNTING AND APPROPRIATION DATA (If required)				
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.				
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.				
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).				
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:				
D. OTHER (Specify type of modification and authority)				
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.				
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) SOLICITATION N40080-14-R-0312-P621 CYBER SECURITY PARKING GARAGE, USNA, ANNAPOLIS, MD As an amendment to the solicitation, the proposal due date is extended to 3 March 2015, time remains unchanged. The following are incorporated into the solicitation: Section 00 01 15 List of Drawings, Half size drawings, Submittal Register, Section 33 61 13 and Section 01 14 00. END OF AMENDMENT 0008				
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.				
15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
		TEL:	EMAIL:	
15B. CONTRACTOR/OFFEROR _____ (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED 19-Feb-2015

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

SECTION SF 30 - BLOCK 14 CONTINUATION PAGE

The following have been added by full text:

AMEND 0008 LIST OF DRAWING**SECTION 00 01 15 LIST OF DRAWINGS**

1.2 CONTRACT DRAWINGS

The following drawings are revised as of 02/17/2015:

NAVFAC DWG NO.	Title
13068314	CONSTRUCTION ACCESS & STAGING PLAN
13068315	CONSTRUCTION ACCESS & STAGING PLAN
13068328	EROSION AND SEDIMENT CONTROL NOTES
13068332	EROSION AND SEDIMENT CONTROL – PHASE I
13068337	UTILITY PLAN
13068338	UTILITY PLAN – HIGH TEMP HOT WATER
13068342	UTILITY PROFILES – HIGH TEMP HOT WATER

On NAVFAC Dwg. No. 13068314 (G-105): Revised construction fence at quadrant B1 for fencing required at temporary piping bypass. Added construction fence at quadrant C3 for fencing required at temporary piping bypass. Revised Key Note #3 and added Key Notes #10, #11, and #12.

On NAVFAC Dwg. No. 13068315 (G-106): Revised construction fence at quadrant B1 for fencing required at temporary piping bypass. Added construction fence at quadrant C3 for fencing required at temporary piping bypass. Added Sheet Note #11. Revised Key Note #6 and #9, and added new Key Note #12. Revised graphic showing number of parking spaces to be blocked for access along Parker Lane.

On NAVFAC Dwg. No. 13068328 (CG-001): Added General Note #18.

On NAVFAC Dwg. No. 13068332 (CG-103): Added STAGE STORAGE FOR REMOVABLE PUMPING STATION (RPS) table. Added “(REFER TO STAGE-STORAGE TABLE FOR REQ. VOL. ON THIS SHEET) to detail reference A3/CG-501 in quadrant C3. Revised “DA (AC): 0.66” to “DA (AC): 0.96” at quadrant B3.

On NAVFAC Dwg. No. 13068337 (CU-101): Added “CONTRACTOR TO FIELD VERIFY” to callout “APPROXIMATE LOCATION OF EXISTING HTWS/R ANCHORS” in quadrants A2 and D1. Revised HTHW piping configuration serving the Navy Gateway (Officer’s Club).

On NAVFAC Dwg. No. 13068338 (CU-102): Added “CONTRACTOR TO FIELD VERIFY” to callout “APPROXIMATE LOCATION OF EXISTING HTWS/R ANCHORS” in quadrants A2 and D1. Revised HTHW piping configuration serving the Navy Gateway (Officer’s Club). Revised Utility Key Notes #2 and #4, and added new Utility Key Note #5.

On NAVFAC Dwg. No. 13068342 (CU-204): Revised details A1 and A4.

These revised Drawings accompany this Amendment.

SECTION 01 14 00 WORK RESTRICTIONS

1.2. SPECIAL SCHEDULING REQUIREMENTS

1.2.f. (3): Delete paragraph in its entirety and replace with the following: “Commence installation of HTHW piping. Install temporary piping bypass in two locations as shown on the Drawings.”

1.2.f. (5): Delete paragraph in its entirety and replace with the following: “Test piping system in accordance with Section 33 61 13, pressure test the HTHW piping, and obtain approval. Execute the cutover to the temporary piping bypass.”

1.2.f. (6): Delete paragraph in its entirety and replace with the following: “The Contractor shall make connections, including performing all testing and acceptance for an operational system cutover shall occur be complete on or before 10 September 2015. This is the required completion date for temporary piping bypass installation the HTHW phase and to which liquidated damages independent from those associated with the Contract Completion Date apply. The Contractor shall advise the Contracting Officer immediately if he discovers he may not be able to maintain the required schedule.”

Add new 1.2.f. (7) as follows: “The government will reenergize the HTHW utility.”

Add new 1.2.f. (8) as follows: “The Contractor shall install the new permanent HTHW utility and connect to the temporary piping bypass. The Government will transition from the existing piping to the newly installed piping via the Contractor installed temporary piping bypass. After the transition, the Contractor shall remove the existing HTHW utility.”

Add new 1.2.f. (9) as follows: “The Contractor shall remove the temporary piping bypass and construction fence around the temporary piping bypass in the summer of 2016, make final connections, ensure the system is restored to fully operational capability including performing all testing and acceptance for an operational system on or before 10 September 2016.”

Add new 1.2.f. (10) as follows: “The Contractor shall turn over to USNA four of the 14” valves that were installed as part of the temporary piping bypass. Deliver to a location as directed within 5 miles of the site.”

SECTION 01 33 00 SUBMITTAL REGISTER

Add additional submittals required under Section 33 61 13.

SECTION 33 61 13 PRE-ENGINEERED UNDERGROUND HEAT DISTRIBUTION SYSTEM

Add “American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE), ASHRAE 90.1-IP to the list of publications.

1.3.4 Rated Characteristics

Revise the first sentence to read “Furnish thermal expansion calculations for all temporary and final supply and return piping using the following design characteristics and installation temperature.”

Add the following: “Provide thermal heat loss calculations to prove the system conforms to ASHRAE 90.1-IP.”

1.4 SUBMITTALS

SD-06 Test Reports: Add “Thermal Heat Loss Calculations; G”.

2.6 TEMPORARY PIPING BYPASS

Revise the first sentence to read “The Contractor shall provide temporary piping bypass and construction fence as shown on the Drawings.”

3.8 THERMAL PERFORMANCE TESTING

Delete this paragraph and all subparagraphs in their entirety.

These revised Sections accompany this Amendment.

(End of Summary of Changes)