

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE OF PAGES	
2. AMENDMENT/MODIFICATION NO. 0006		3. EFFECTIVE DATE 21-Aug-2015	4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO.(If applicable) 1 2
6. ISSUED BY PUBLIC WORKS DEPARTMENT NAS, PATUXENT RIVER 22445 PEARY ROAD, BLDG 504 PATUXENT RIVER MD 20670-5504		CODE N40080	7. ADMINISTERED BY (If other than item 6) See Item 6		
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)			X	9A. AMENDMENT OF SOLICITATION NO. N40080-15-Q-3014	
			X	9B. DATED (SEE ITEM 11) 27-Jul-2015	
				10A. MOD. OF CONTRACT/ORDER NO.	
				10B. DATED (SEE ITEM 13)	
CODE			FACILITY CODE		
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS					
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.					
12. ACCOUNTING AND APPROPRIATION DATA (If required)					
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.					
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.					
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).					
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:					
D. OTHER (Specify type of modification and authority)					
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.					
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) SUBJ: Building 2187 Provide Electrical Upgrades - Lab 1B41 SOW Addendum 2 is attached. This is a revision to the Addendum to the SOW in Amendment 0004.					
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.					
15A. NAME AND TITLE OF SIGNER (Type or print)			16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print) BARBARA A. THOMPSON / PAX TEAM B LEADER TEL: 301- 757-4918 EMAIL: barbara.a.thompson@navy.mil		
15B. CONTRACTOR/OFFEROR _____ (Signature of person authorized to sign)		15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED 21-Aug-2015

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SECTION SF30 - BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

SECTION SF30 - BLOCK 14 CONTINUATION PAGE

The following have been added by full text:

ADDENDUM TO SOW 2

SOW Addendum 2: Building 2187 Provide Electrical Upgrades at Lab 1B41

The following requirements are deleted:

- (1) Provide a dedicated control valve assembly for sprinkler piping supporting Lab 1B41B for shunt-tripping of equipment power.
- (2) Control valve assembly shall be located in Room 1B41A.
- (3) Control valve assembly shall be electrically supervised by the building's existing fire alarm system.
- (4) Connect the MCB to the existing fire alarm system so that in case of fire sprinkler activation in the lab 1B41B, it will shut down the PDU.

Provide following items:

- (1) Provide and Install the Main Circuit breaker (MCB) on the primary side of the transformer in the PDU with the shunt trip.
- (2) Provide and Install the Manual Emergency Shutdown button with the glass cover next to the exit door in the Lab 1B41B and connect it to the MCB in the PDU.

(End of Summary of Changes)