

		1. CONTRACT ID CODE		PAGE		OF PAGES	
		J		1		2	
2. AMENDMENT/MODIFICATION NO. 0003		3. EFFECTIVE DATE 2-September-2015		4. REQUISITION/PURCHASE REQ. NO.		PROJECT NO. (If applicable)	
6. ISSUED BY Naval Facilities Engineering Command 1314 Hardwood Street, SE Washington Navy Yard, DC 20374-5018		Code N40080		7. ADMINISTERED BY (If other than item 6.)		Code	
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)				<input checked="" type="checkbox"/>		9A. AMENDMENT OF SOLICITATION NO. N40080-15-R-1768	
				<input checked="" type="checkbox"/>		9B. DATED (SEE ITEM 11) 12-August-2015	
				<input type="checkbox"/>		10A. MODIFICATION OF CONTRACT/ORDER NO.	
				<input type="checkbox"/>		10B. DATED (SEE ITEM 13)	
CODE		FACILITY CODE					
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS							
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in item 14. The hour and date specified for receipt of Offers <input type="checkbox"/> is extended <input checked="" type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.							
12. ACCOUNTING AND APPROPRIATION DATA (if required)							
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.							
<input type="checkbox"/> A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14. ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.							
<input type="checkbox"/> B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATION CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103 (b).							
<input type="checkbox"/> C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:							
<input type="checkbox"/> D. OTHER: (specify type of modification and authority)							
E. IMPORTANT: Contractor <input type="checkbox"/> is not <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.							
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)							
N40080-15-R-1768, FAN COIL UNIT REPLACEMENT, NAVAL RESEARCH LABORATORY, WASHINGTON, DC							
SEE SF 30 BLOCK 14 CONTINUATION PAGE							
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.							
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)			
15B. CONTRACTOR/OFFEROR (Same as Item 8)		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA		16C. DATE SIGNED	
_____ (Signature of person authorized to sign)				BY _____ (Signature of Contracting Officer)			

SF 30 BLOCK 14 CONTINUATION PAGE

THE PURPOSE OF THIS AMENDMENT IS TO PROVIDE THE FOLLOWING BELOW:

---

**1 ) PART 3; CHAPTER 1; NEW WORK, ELECTRICAL**

DELETE paragraph in its entirety and REPLACE with the following:

“The existing 1P-20A circuit breakers in existing panels, presently serving the FCUs being replaced, will be utilized to connect the new fan coil units. Since the FCUs are being replaced by units with equal horsepower as existing units, no adjustments are required to the panels or wiring. The FCUs will be furnished with a motor thermal disconnect switch. Replace existing # 12 AWG conductors in the existing conduit with #12 MC cables concealed in walls and above ceiling (remove existing conductors and abandon existing conduits) as required, to accommodate the new connections to the new fan coil units.”

**2 ) PART 3; CHAPTER 6 ESR; D5010 ELECTRICAL SERVICE AND DISTRIBUTION:**

DELETE paragraph in its entirety and REPLACE with the following:

“Disconnect existing fan coil units being replaced. Connect new fan coil units to existing 1P–20A breakers in existing “WESTINGHOUSE” panels (presently serving existing fan coil units) using new MC cables. Replace existing conductors to accommodate the connection to new fan coil units. New wiring shall be #12 MC cables installed concealed in walls and above ceiling as required by NEC.”

**3 ) PART 2 – ATTACHMENT A; PARAGRAPH 34 SAFETY AND OCCUPATIONAL HEALTH:**

Sub-Paragraph f.: Delete entire sentence and replace with the following:

“The site Safety and Health Officer may serve also as the superintendent.”

**4 ) PART 6 ATTACHMENTS:**

ADD UPDATED WAGE DETERMINATION

ADD the following attachments:

01 of 02) 5333=1FL=bldg 222=ELEC PANELS

02 of 02) 5333=1FL=bldg 222=ELEC PANELS

***Please note that if your specific question is not addressed, the Solicitation RFP, Specifications or Drawings have adequately addressed your inquiry. Please propose in accordance with the RFP.***

**End of Amendment.**

---