

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE OF PAGES	
2. AMENDMENT/MODIFICATION NO. 0007		3. EFFECTIVE DATE 04-Dec-2015	4. REQUISITION/PURCHASE REQ. NO. ACQR3903264		5. PROJECT NO.(If applicable)
6. ISSUED BY NAVAL FACILITIES ENG COMMAND WASHINGTON 1314 HARWOOD ST SE, BLDG 212 WASHINGTON NAVY YARD DC 20374		CODE N40080	7. ADMINISTERED BY (If other than item 6) See Item 6		
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)			X	9A. AMENDMENT OF SOLICITATION NO. N40080-16-R-0151	
			X	9B. DATED (SEE ITEM 11) 31-Jul-2015	
				10A. MOD. OF CONTRACT/ORDER NO.	
				10B. DATED (SEE ITEM 13)	
CODE			FACILITY CODE		
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS					
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.					
12. ACCOUNTING AND APPROPRIATION DATA (If required)					
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.					
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.					
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).					
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:					
D. OTHER (Specify type of modification and authority)					
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.					
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) The purpose of this Amendment is to provide the following: 1. RFP Revisions 2. Provide Current Wage Rate All other terms and conditions remains unchanged.					
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.					
15A. NAME AND TITLE OF SIGNER (Type or print)			16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
			TEL: _____ EMAIL: _____		
15B. CONTRACTOR/OFFEROR _____ (Signature of person authorized to sign)		15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED 04-Dec-2015

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

SECTION SF 30 - BLOCK 14 CONTINUATION PAGE

The following have been added by full text:

AMENDMENT 0007

ATTACHMENT- ET105

ATTACHMENT- CURRENT WAGE DETERMINTION

6. **Part 2, Section 01 33 10.05 20 – Design Submittal Procedure, 1.9.4.3 states:** “The NCPC review and approval process will not increase the project duration.”

7. **Specification Section 01 33 29 1.5.1”Commissioning services will be provided by a third party working on behalf of the Government.”**

9. **Factor 6- Energy and Sustainable Design (a) solicitation submittal requirements:** The second paragraph has been revise to the following.

“The energy and sustainability narrative **each** shall not exceed four pages single sided or two pages double sided. A Combined total of eight pages single sided or four pages double sided.”

Part 5 Section 14 24 00 2.1

DELETE “Two passenger / service elevators will be required for the project, one for the parking garage and one for the building.”

REPLACE with “One passenger / service elevator will be required for the project.”

CLARIFICATION: Fixed partitions are to have an STC rating of 42 as a minimum, unless otherwise stated in part three room requirements. STC rating doors should be applied in adjacencies of STC rated walls to have a minimum STC as required by the program. Where acoustic characteristics are required by the program in that room, the doors should follow minimum STC ratings to meet that room requirement.

CLARIFICATION: Follow the Room data sheet requirement for 9 lavatories, room requirements take precedence over attached drawings.

CLARIFICATION: Room requirement sheets (space characteristics) take precedence over drawings and floor plans in RFP Part 6. Comply with the Part 3 Ch. 3 3.2.3 paragraph statement, not the dimensioned drawing.

(End of Summary of Changes)