

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE J	PAGE OF PAGES 1 3
2. AMENDMENT/MODIFICATION NO. 0004	3. EFFECTIVE DATE 10-Jun-2015	4. REQUISITION/PURCHASE REQ. NO. ACQR3911253	5. PROJECT NO.(If applicable) 1332591	
6. ISSUED BY NAVFAC MID ATLANTIC PWD MAINE - FEAD PORTSMOUTH PORTSMOUTH NAVAL SHIPYARD BLDG 59 PORTSMOUTH NH 03801-2032	CODE N40085	7. ADMINISTERED BY (If other than item 6) See Item 6		
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)		X	9A. AMENDMENT OF SOLICITATION NO. N40085-15-B-6109	
		X	9B. DATED (SEE ITEM 11) 19-May-2015	
			10A. MOD. OF CONTRACT/ORDER NO.	
			10B. DATED (SEE ITEM 13)	
CODE	FACILITY CODE			
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS				
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.				
12. ACCOUNTING AND APPROPRIATION DATA (If required)				
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.				
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.				
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).				
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:				
D. OTHER (Specify type of modification and authority)				
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.				
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) Amend #04: Responses to RFI's 4 & 5, updated drawing as separate attachment.				
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.				
15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
		TEL:	EMAIL:	
15B. CONTRACTOR/OFFEROR _____ (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED 10-Jun-2015

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

SECTION 00800 - SPECIAL CONTRACT REQUIREMENTS

The following have been added by full text:

REQUEST FOR INFORMATION #4&5

RFI Questions:

4. Amendment #2 item 14, b, We assume this to be applicable to sheet M-601 "Temporary Drainage Pump Schedule (Option 1), not Sheet M-301 as indicated? Can you confirm please?
5. Drawing M-301, Keynote 5, indicated contractor to replace existing valve with a stainless steel motor operated valve. Is there a preferred valve operator or specification for these motor operators?

Answer #4 & #5: Detailed answer on SF30 amend #04 form regarding drawing changes on M301, M302, and M-601.

1. M-301

a. **Replace** General Sheet Note 2 with the following: "FURNISH TWO TEMPORARY DRAINAGE PUMPS (TDP-1 AND TDP-2) FOR WORK UNDER OPTION 1. PUMPS SHALL BE BASIS OF DESIGN AS SCHEDULED ON SHEET M-601 OR APPROVED EQUIVALENT. FURNISH TWO, 20 FOOT LONG AND TWO, 10 FOOT LONG 6" DIAMETER RUBBER DISCHARGE HOSES WITH BASIS OF DESIGN BAUER QUICK DISCONNECT (QD) FITTINGS OR APPROVED EQUIVALENT. HOSES SHALL BE BASIS OF DESIGN HOSECRAFT MODEL RN1 RATED FOR 100 PSIG OR APPROVED EQUIVALENT. FURNISH TWELVE, 20 FOOT LONG SECTIONS OF 6" DIAMETER SCHEDULE 40 GALVANIZED STEEL PIPING WITH QD FITTINGS ON EACH END. FURNISH TWO, 6" DIAMETER GALVANIZED ELBOWS WITH QD FITTINGS. PROVIDE 6" DIAMETER HDPE PIPING PERMANENTLY INSTALLED ON DRY DOCK WALL AS INDICATED ON DETAIL B4/M-302. VERIFY HOSE AND PIPE LENGTHS WITH CONTRACTING OFFICER. TEMPORARY DRAINAGE PUMPS, HOSES AND PIPING SHALL BE TURNED OVER TO THE NAVY AT THE END OF THE CONTRACT. REFER TO DETAIL B4/M-302."

b. **Add** to Keynote 5 "Provide Limatorque MX electronic valve actuator. Actuator shall be 440 volt, 3-phase with a NEMA 4X enclosure."

2. M-302

a. **Replace** drawing with attached. Details A4 and B4 have been added.

3. M-601 (this item replaces Item 14.b of Amendment No. 02)

- a. Temporary Drainage Pump/Schedule (Option 1):
- 1) **REPLACE** "Sump Pit" with "Dry Dock Sump (two locations)."
 - 2) In 'Type' Column, **INSERT** "Submersible"
 - 3) In 'GPM' Column, **INSERT** "1000" (3490 RPM)
 - 4) In 'Total Head' Column, **INSERT** "60 feet"
 - 5) In HP Column, **INSERT** "minimum of 27"
 - 6) In Basis of Design Column, **INSERT** "Flygt model 2670-228"

7) **ADD** Note 2, "Provide permanently installed piping in the dock and furnish non-collapsible hose to connect the pump to the vertical, permanent, HDPE pipe. Furnish hoses and galvanized pipe at the deck coping level to connect to the HDPE pipe and discharge to the river. Refer to Details A4/M-302 and B4/M-302."

(End of Summary of Changes)