

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE OF PAGES
2. AMENDMENT/MODIFICATION NO. 0004		3. EFFECTIVE DATE 19-Mar-2015	4. REQUISITION/PURCHASE REQ. NO.	
6. ISSUED BY NAVFAC MID ATLANTIC PWD PHILADELPHIA NAVAL SUPPORT ACTIVITY BLDG 24 700 ROBBINS AVENUE PHILADELPHIA PA 19111-5098		CODE N40085	7. ADMINISTERED BY (If other than item 6) NAVFAC MID ATLANTIC PWD PHILADELPHIA 4921 S. BROAD STREET BLDG 1, 2ND FLOOR PHILADELPHIA PA 19112	
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)			X	9A. AMENDMENT OF SOLICITATION NO. N40085-15-Q-7531
			X	9B. DATED (SEE ITEM 11) 25-Feb-2015
				10A. MOD. OF CONTRACT/ORDER NO.
				10B. DATED (SEE ITEM 13)
CODE		FACILITY CODE		
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS				
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.				
12. ACCOUNTING AND APPROPRIATION DATA (If required)				
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.				
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.				
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).				
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:				
D. OTHER (Specify type of modification and authority)				
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.				
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)  N40085-15-Q-7531 Structural Repairs at Bldgs 404 & 505 at the Naval Support Activity Mechanicsburg, Pa.  THIS AMENDMENT MUST BE ACKNOWLEDGED WITH RECEIPT OF QUOTE.  Description continues on page 2.				
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.				
15A. NAME AND TITLE OF SIGNER (Type or print)			16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print) SHANNON MACK / CONTRACT SPECIALIST TEL: 215-897-3495 EMAIL: shannon.mack@navy.mil	
15B. CONTRACTOR/OFFEROR  _____ (Signature of person authorized to sign)		15C. DATE SIGNED	16B. UNITED STATES OF AMERICA  BY _____ (Signature of Contracting Officer)	16C. DATE SIGNED  19-Mar-2015

## SECTION SF 30 BLOCK 14 CONTINUATION PAGE

## SUMMARY OF CHANGES

## SECTION SF 30 - BLOCK 14 CONTINUATION PAGE

The following have been added by full text:

AMENDMENT 0004

1. The date for receipt quote **REMAINS** at 3:00 PM ET on 27 MARCH 2015.
2. **NOTE: THIS AMENDMENT MUST BE ACKNOWLEDGED WITH YOUR QUOTE.**
3. NO Additional REQUESTS FOR INFORMATION (RFI) will be accepted.
- 4: RESPONSE to the following RFI:
  - Q1. How long are the steel u-clamps for repair detail "T"? We are shown only profile (2 dimensions) and not the length.  
**A1. The length varies per member, refer to the elevation views to determine which members are being repaired, then estimate the length of the clamp based on these factors**
  - Q2. Building 505: how many timbers are being replaced each at details C.3/DX60 and D.5/DX25? Layers are not shown.  
**A2. Contractor to assume one timber per referenced detail**
  - Q3. Repair Detail A. Can we use all-thread with lock washers and hex nuts at each end of the bolt?  
**A3. No, use 1/2" dia. bolt as specified**
  - Q4. Building 505: repairs 22/B1 is referencing column locations D3 and D4, but chord B1 sits between lines A & B on Truss 22. Please advise.  
**A4. Repair 22/B1 is referring to Truss 22, Bottom Chord 'B1'. D3 and D4 are referring to diagonal bracing not column locations**
  - Q5. Are any columns being replaced? Column replacement was discussed at the Site Visit but we detect none in the documents.  
**A5. No columns are being replaced**
  - Q6. Where is diagonal member 18 on Truss 28? This is not shown on Drawing S403.

A6. D18 is located on the truss in the high bay. The location of the diagonal is shown on S-401

(End of Summary of Changes)