

CONTINUATION SHEET for AMENDMENT 0002

Change	Change Format
Delete/Add Text RFI #38 RFI #89	PART 3 PROJECT PROGRAM, 6.0 ESR A10 FOUNDATIONS, SECTION A1010 STANDARD FOUNDATIONS – VOL. 1, PAGE 632 OF 1520. Delete final paragraph of this section and replace with new paragraph, as follows: “The Boat Storage structure will be supported on a system of shallow spread footings that is independent of the adjacent building, Building 3853. The foundation system shall be designed in accordance with the Contractor’s Geotechnical Engineer’s recommendations and shall incorporate ground improvement measures to limit total and differential settlement. Maximum total and differential settlement of foundations supporting the Boat Storage structure shall be limited to 1 inch and ½ inch, respectively.”
Change Text RFI #40 RFI #59	PART 6 Attachments – Vol 2 page 20 of 138 – A-101 Armory: In room 120 Weapons Maintenance change text from “EYEWASH” to “EYEWASH/SHOWER”.
Change Text RFI #42 RFI #59	PART 6 Attachments – Vol 2 page 20 of 138 – A-101 Armory: In room 119 Weapons Cleaning change text from “EYEWASH” to “EYEWASH/SHOWER”.
Change Text RFI #45 RFI #59	PART 6 Attachments – Vol 2 page 20 of 138 – A-101 Armory: In room 113 Mechanical change text from “EYEWASH” to “EYEWASH/SHOWER”.
Change Text RFI #54 RFI #59	PART 6 Attachments – Vol 2 page 15 of 138 – A-101 Logistics Supply Warehouse: In room 128 Mechanical change text from “EYEWASH” to “EYEWASH/SHOWER”.
Change Text RFI #54 RFI #59	PART 6 Attachments – Vol 2 page 16 of 138 – A-101A Logistics Supply Warehouse: In room 128 Mechanical change text from “EYEWASH” to “EYEWASH/SHOWER”.
Change Text RFI #60	PART 6 Attachments – Vol 2 page 77 of 138 – P-601 Design Development Drawing - Building 3853: Change Plumbing Fixture Schedule note to read: 12. Provide wall mounted urinal with hard-wired electronic sensor flush valve.
Change Text RFI #60 RFI #61 RFI #62	PART 6 Attachments – Vol 2 page 77 of 138 – P-601 Design Development Drawing - Building 3853: Change Plumbing Fixture Schedule “note” reference column as follows: P-3: Change Note Reference 13 to 12

	P-11: Change Note Reference 16 to 15 P-12: Change Note Reference 18 to 17 P-13: Change Note Reference 17 to 16 HB-1: Change Note Reference 14 to 13 WH-1: Change Note Reference 15 to 14 P-16: Change Note Reference 13 to 12.
Replace Drawing RFI #85	PART 6 Attachments – Vol 2 page 12 of 138 – C-901 Civil Drawing: Replace Civil drawing C-901 SITE PLAN – BID OPTION with the attached revised (dated 8/24/15) C-901 SITE PLAN – BID OPTION.
Change Text RFI #86	PART 6 Attachments – Vol 1 Page 738 of 1558 – ESR G30 Section 302090 – Delete this section
Replace Text RFI #63	P-334 LOGSU 2 Operations Facility Building 3853, Drawing P-601, Sump/Effluent Pump Schedule In Row “SP-1” Column “Volts” replace “20” with “120”