

CONTINUATION SHEET for AMENDMENT 0007

Change	Change Format
Replace Text	<p>Part 3, 4.0 Building Requirements, third paragraph, delete in its entirety and replace it with the following paragraph.</p> <p><i>“Provide a total of 117 rooms per the attached “Typical Room Module Layout Plan” in Part 6 of this RFP or UFC 4-721-10 “Navy & Marine Corps Bachelor Housing, including associated common and support space, in a three story structure.” All public areas, including the restrooms, Multi-purpose Space, Vending area and Laundry Room, shall be DOD/ABA compliant. Corridors and elevator access shall be ABA compliant on all floors. ABA accessible routes from parking and vehicle drop offs shall also be provided. The facility shall achieve LEED Silver Certification under LEED - NC V 3.0 Rating System. All acoustical STC ratings shall be per UFC 4-721-10 including change 4 January 2011, unless otherwise noted.</i></p>
PPI #174	<p><i>West feeder demolition and relocation was resolved by construction of building P-984. See “Additional Electrical Site Plans” provided in previous Amendment 4.</i></p> <p><i>Note: Telecommunication outside plant cable was not installed in accordance with “P-984 & P-985 Electrical Site Plans provided in Amendment 4.</i></p>