

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE J	PAGE OF PAGES 1 5
2. AMENDMENT/MODIFICATION NO. 0004	3. EFFECTIVE DATE 01-Apr-2015	4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO.(If applicable)
6. ISSUED BY NAVFAC MID ATLANTIC HAMPTON ROADS IPT 9742 MARYLAND AVENUE NORFOLK VA 23511-3095	CODE N40085	7. ADMINISTERED BY (If other than item 6) See Item 6		
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)		X	9A. AMENDMENT OF SOLICITATION NO. N40085-15-R-0047	
		X	9B. DATED (SEE ITEM 11) 10-Mar-2015	
			10A. MOD. OF CONTRACT/ORDER NO.	
			10B. DATED (SEE ITEM 13)	
CODE	FACILITY CODE			
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS				
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.				
12. ACCOUNTING AND APPROPRIATION DATA (If required)				
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.				
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.				
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).				
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:				
D. OTHER (Specify type of modification and authority)				
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.				
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) SOLICITATION N40085-15-R-0047 - Total Small Business Design-Build, Design-Bid-Build Multiple Award Contract for new construction, renovation, alteration, and repairs for projects in the Hampton Roads Area, Virginia. Seed Project: Design Bid Build P-992, Fast Company Training Facility, Naval Weapons Station, Yorktown Virginia SEE SECTION SF 30 - BLOCK 14 CONTINUATION PAGE				
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.				
15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
		TEL:	EMAIL:	
15B. CONTRACTOR/OFFEROR _____ (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED 01-Apr-2015

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

SECTION SF 30 - BLOCK 14 CONTINUATION PAGE

The following have been added by full text:

AMENDMENT 0004

THE PURPOSE OF THIS AMENDMENT IS TO PROVIDE THE FOLLOWING:

Provide Specification Revision, Drawing Revision, and RFI responses:

N40085-15-R-0047

01 April 2015

DESIGN BID BUILD P992, FAST COMPANY TRAINING FACILITY, NAVAL WEAPONS STATION, YORKTOWN, VIRGINIA

SPECIFICATION REVISIONS

1. ADD the following attached specification sections. The updated Table of Contents is included.

08 14 00	Wood Doors
09 22 00	Supports for Plaster and Gypsum Board
09 29 00	Gypsum Board
09 69 13	Rigid Grid Access Flooring
10 22 26	Accordion Folding Partition

2. CHANGE any references to section 01 33 29 LEED Documentation to “ 01 33 29 Sustainable Requirements”.

3. Section 28 20 00 Electronic Security Systems (ESS), Commercial, subpart 1.4 System Description, CHANGE the first sentence from “Provide new or modify existing Electronic Security Systems (ESS), including associated equipment and appurtenances.” to read “Provide new Electronic Security Systems (ESS), compatible to tie into the existing base Lenel system, including associated equipment and appurtenances. Do not salvage the existing security equipment.”

4. Section 01 58 00 Project Identification DELETE the appendix plates 5, 6,7, 8 & 9.

5. Section 01 45 00 paragraph 1.5.6, ADD the following info to the chart of qualifications:

1. 5 years Experience 08 71 00 Door hardware submittals

2. 5 years experience 23 00 00 all HVAC submittals in section
 3. 5 years experience 23 09 23 all DDC submittals in section
 4. 5 years experience 23 81 28 all VRF submittals in section
 5. 5 years experience 28 20 00 all ESS submittals in section
 6. 5 years experience 28 31 76 all fire alarm submittals in section
 7. 5 years experience 26 12 19 all transformer submittals in section
6. Section 27 10 00 Building Telecommunication Cabling System
- a. subpart 2.3.2.2 – ADD “Provide multimode fiber as per UFC 3-580-01 section 2-4.1.2. “
 - b. subpart 2.4.6 – ADD “Provide fiber optic termination as per UFC 3-580-01 section 2-4.1.2.1. Provide SC. Do not provide ST style adapters for new construction.”
7. Section 01 30 01 Design, Procurement, and Installation of Furniture, Fixtures, and Equipment, subpart 1.2, General Requirements, second paragraph, DELETE the words ”are \$1,256,100.00 and” in the third sentence.
8. CLARIFICATION: Section 05 12 00 Structural Steel, subpart 3.1 the requirements will not be waived.
9. Section 01 30 00 Administrative Requirements, subpart 1.2, ADD “Comply with the specifications regarding photos. A Base photo pass may be required, but there will not be any other restrictions for photos taken at the project site.”
10. Section 01 30 00 Administrative Requirements, subpart 2.1, ADD “No Virginia sales tax is to be included for the A/V or FF&E Planned Modifications. The awardee will be provided with pertinent info for filing with the state.”
11. Section 01 32 17 Network Analysis Schedules (NAS),
- a. subpart 1.4 is correct using Primavera.
 - b. subpart 1.6.1.1 ADD “Comply with specification section 01 20 00 paragraph 1.3 Schedule of Prices, which requires a Cost-loaded Network Analysis Schedule.”
12. Section 01 33 29 Sustainable Requirements, subpart 1.3.4, ADD “The approved third party certification organizations are United States Green Building Council (USGBC) and GBI (Green Building Initiative).
13. Section 01 35 26 Governmental Safety Requirements:
- a. subpart 1.6.1.1 ADD “The entire project is considered to be one “site”, therefore only one SSHO is required.”
 - b. subpart 1.6.1.1.1, ADD “Comply with specification sections 01 35 26 and 01 30 00. One CQC Manager and a minimum of one Projects Superintendent/SSHO.”
 - c. subpart 3.7.1 ADD “ The Government will not provide a list of third party firms.”

14. Section 01 50 00, subpart 3.5.1, ADD “The recommended trailer location is in the NW corner of the inside of the “L” of the 1808 bldg. There is a patio area near door 104B. See civil sheets for utility locations. “

15. Section 01 57 13 Erosion and Sediment Control, subpart 1.4, ADD “This may be part of the overall schedule, but for the purposes of this required submittal, only items required by paragraph 1.4 will be included.”

DRAWING REVISIONS

1. Sheet A-101A ADD Wall Partition Type F under Wall Partition Types. This wall type is indicated on sheet A-102A in Room 112 Shower and is typical along that plumbing chase wall. ADD the following sentence:

“F. 2-1/2” metal studs at 16” OC to 6” above ceiling, with 1/2” glass matt moisture resistant gypsum bd. on one side.”

2. CHANGE Wall Partition Types indicated on Sheets A-101A and A-101B change the phrase “mold resistant gypsum board” to “**water &** mold resistant gypsum board.

3. CHANGE Sheet A-101A, Wall Partition Type B1. “5/* Gyp Bd.” to “5/8” Gyp. Bd.”

4. DELETE Sheet 56 AD901A on Sheet G-002. It is not used and not included in the design drawing set.

5. Drawing E-601B- ADD “General Note- all Medium voltage cables to be 15Kv rated.”

6. Sheet ES101, Cable Schedule, item A, ADD “field verify if the 100 pair copper comm. cable is direct buried. No modification to existing cable is required under this contract.”

7. Sheet FP002, Fire Alarm/ Mass Notification Riser Diagram- ADD note “The basewide MNS system is Federal Signal system.”

8. Sheet ED102A, Demolition Note 3- ADD “Deliver to the Contract Officer at the Transformer Yard at NWS Yorktown.”

9. Sheet B-101, ADD “General Note Geotechnical recommendations and conclusions have been incorporated into the plans and specifications for the project.”

10. Sheet CE105, ADD Sheet Note “4. The temporary road is for emergency vehicles, and will remain in use until the new Fire Lane road is complete and turned over to the government. The contractor will be allowed to use the road for site access, but will be required to keep the road clear of vehicles at all times and will be responsible for maintaining the road.”

SF1442 SOLICITATION REVISIONS

1. Attachment A, item 2, provide an explanation of what work was performed. The percent of project work performed applies to whoever's work is being documented.

- End of Amendment 0004 -

(End of Summary of Changes)