

1. CONTRACT ID CODE		PAGE	OF PAGES
J		1	3
2. AMENDMENT/MODIFICATION 0003	3. EFFECTIVE DATE 9-June-2015	4. REQUISITION/PURCHASE REQ.	PROJECT NO. (If applicable)
6. ISSUED BY NAVFAC MID ATLANTIC HAMPTON ROADS IPT 9742 MARYLAND AVENUE NORFOLK, VA 23511		7. ADMINISTERED BY (If other than item 6.)	
Code OPHA		Code	
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)		<input checked="" type="checkbox"/>	9A. AMENDMENT OF SOLICITATION NO. N40085-15-R-0064
		<input checked="" type="checkbox"/>	9B. DATED (SEE ITEM 11) 6-May -2015
		<input type="checkbox"/>	10A. MODIFICATION OF CONTRACT/ORDER NO.
			10B. DATED (SEE ITEM 13)
CODE	FACILITY CODE		
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS			
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in item 14. The hour and date specified for receipt of Offers <input type="checkbox"/> is extended <input checked="" type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning ___ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.			
12. ACCOUNTING AND APPROPRIATION DATA (if required)			
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.			
<input type="checkbox"/>	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14. ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.		
<input type="checkbox"/>	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATION CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103 (b).		
<input type="checkbox"/>	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:		
<input type="checkbox"/>	D. OTHER: (specify type of modification and authority)		
E. IMPORTANT: Contractor <input checked="" type="checkbox"/> is not <input type="checkbox"/> is required to sign this document and return ___ copies to the issuing office.			
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)			
<p>DESIGN-BUILD/DESIGN-BID-BUILD MULTIPLE AWARD CONSTRUCTION CONTRACT (MACC) FOR NAVFAC MID-ATLANTIC'S ENTIRE AREA OF RESPONSIBILITY, NORTH CAROLINA TO MAINE, INCLUDING WEST VIRGINIA</p> <p>N40085-15-R-0064, RM09-0767, Design-Build Building 30 Renovations at Norfolk Naval Shipyard, Portsmouth, Va. (Work Order #1321161)</p> <p>The purpose of this amendment is to respond to RFIs on the following pages and provide a revised Price Proposal Form. The proposal due date remains unchanged at Friday, June 12 at 2pm local time.</p> <p>You are required to acknowledge ALL amendments in the price proposal form.</p>			
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.			
15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR (Same as Item 8)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA	16C. DATE SIGNED
_____ (Signature of person authorized to sign)		BY _____ (Signature of Contracting Officer)	

Inquiries are numbered in the order they were received. Numbers missing from the sequence below do not yet have a Government response or have appeared in a previous amendment. No inquiry number will be repeated regardless of the amendment it appears in.

Bid Inquiry	Page	Section	Para.	QUESTION	GOVERNMENT RESPONSE
31	2	Part 3 - Chapter 1	Legacy Fiber	Regarding the Legacy Fiber Backbone, are there any requirements related to outage time constraints associated with these fiber interruptions for relocation?	Any relocation efforts will have to be scheduled for outside of normal production hours. (Sat or Sunday)
47		P3-C1-P2		THE SPEC STATES "LEGACY FIBER OPTIC BACKBONE RUNS THROUGH THE BUILDING AND WILL HAVE TO BE RELOCATED PRIOR TO CONSTRUCTION. IS THE GOVERNMENT OR THE CONTRACTOR RESPONSIBLE FOR RELOCATING THE CABLE?"	This work should be completed by the contractor with technical assistance from NNSY Code 1232.
51	Part 3	Chapter 1	Page 6	Building 30 Temporary Offices/Trailer: Per UFC 1-201-01, January 1, 2013 edition Non-Permanent DoD Facilities, the UFC 1-200-01 General Building Requirements does not apply to the Temporary Offices/Trailer unites. Which UFC takes precedence?	UFC 1-201-01 applies to the trailers
69	2	Part 3	Para 11	For the Legacy Fiber Optic Backbone, please provide more information for pricing purposes. Is there active equipment associated with the fiber optic backbone that will need to be relocated? Is there underground conduits that will give us access to the other buildings connected to building 30?	The conduits are attached to the outside of the building, they are external. IT hardware is currently located in Building 30 and operational. This hardware supports multiple buildings.
70		Part 6	Attachment 15	Part 6, attachment 15 NMCI information indicates new communication cable being provided from building 65 and building 31. Are there existing underground conduits that will be utilized to get to building 30? If so, please provide additional site information indicating the conduit locations for pricing purposes.	The conduits are attached to the outside of the building, they are external. IT hardware is currently located in Building 30 and operational. This hardware supports multiple buildings.

106	Part 3	Chapter 1	Page 6	List of applicable UFCs does not include UFC 1-201-01, Jan 1, 2014 for Non-Permanent DoD Facilities. It is our assumption that this document should be considered when designing the Temporary Office Space/Modular Complex. It is noted in this document that UFC 1-200-01 General Building Requirements does not apply and that all other UFCs are considered to be guidance when designing non-permanent facilities. Please confirm whether NAVFAC would prefer the design team to use UFC 1-200-01 General Building Requirements or UFC 1-201-01, Jan 1, 2014 Non-Permanent DoD Facilities to take precedence for the Temporary Office Space/Modular Complex design.	UFC 1-201-01 applies to the trailers
120	5	Part 3 1.0 Description Number 11		Building 0030 Reference is made to multiple fiber optic cable running through the building that must be relocated. Then the cables are referenced as originating in Bldg 30. Do the cables originate within the building? The question leads to the requirement for a temporary enclosure to be constructed. Will the enclosure need to contain fiber splices or will it contain fiber terminations and switches that will require electronic equipment and environmental controls? If equipment is required please identify the quantity and types.	Any IT hardware that supports only Building 30 can be taken offline, this can be done as soon as the personnel are relocated to the temporary facility. The hardware that will be left in Building 30 can be relocated to another building during the outage to relocate the fiber. NNSY Code 1232 will be responsible for patching the fiber back to the required buildings. The existing cabinets could be used to support a temporary enclosure design/solution. The power feeding the cabinet would have to be identified and kept energized and environmental controls maintained until the relocation of the fiber is complete, after the fiber has been relocated, NNSY Code 1232 would authorize the removal of the existing LAN (Local Area Network) cabinet and all of the hardware.
125	4	Part 3- Chapter 2	Temporary Offices	The RFP indicates a location of the trailer farm, but does not indicate utility wiring diagrams or precise tap location and connection requirements. Please provide telecommunications requirements for trailer farms. How many pair of copper conductors. Is fiber required or not?	48 Strands of single mode fiber from Building 65 to the temporary facility location, and 48 strands of single mode fiber from Building 31 to the temporary facility will be required to support the data networks (NMCI/Legacy/SECNET). The copper telephone cabling will need to come from Building 65. Total phone counts X 2 pair per phone= copper pairs.
134	11	Price Proposal Form		0001B & 0001C Unit price for Window Restoration are these units in addition to the 40 we are to include in our base proposal or are these the 40 windows we are to anticipate repairing?	See revised Price Proposal Form in Amendment 03. The four unit cost for windows captures 100% of the windows.

End of Amendment