





REPLACE SIDING – BLDG 405  
NSA, Mechanicsburg, PA

Work Order No: 1350926

Date: 20 Nov. 2014

## **SMALL PROJECT TABLE OF CONTENTS**

10/14

- Part 1 Proposal Forms and Documents**
  - Part 2 General Requirements**
    - Attachment A: Project-Specific General Requirements**
  - Part 3 Statement of Work / Project Program**
  - Part 4 Minimum Materials, Engineering and Construction Requirements**
  - Part 5 Prescriptive Technical Specifications (NOT USED)**
  - Part 6 Attachments**
- 

### **Preface**

This Request for Proposal (RFP) consists of six parts.

Part 1 contains typical contractual forms, procedures, bidding instructions, bond information, clauses and wage decisions.

Part 2 contains general contract administrative and execution requirements including, but not limited to safety, design criteria & process, quality control, security, schedule, invoicing, temporary facilities, and design and construction oversight processes.

Part 2, Attachment A, contains project-specific general requirements that may either modify and/or supplement the corresponding standard paragraphs in the Part 2 "General Requirements" section.

Part 3 lists the project requirements, specific scope items, and expected quality level above and beyond those outlined in Part 4.

Part 4 contains Performance Specifications and minimum quality requirements.

Part 5, prescriptive specifications, is typically not used in this Small Project format.

Part 6 contains background project information, references, and other project-specific requirements.

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

## **PART 1 - PROPOSAL FORMS & DOCUMENTS**

## Small Project Part 2 General Requirements

10/14

1. **DEFINITIONS:** As used throughout the contract, the following terms shall have the meaning set forth below:

Contracting Officer (KO): The individual designated to administer the contract. Throughout this contract this individual will be responsible and possess the authority to act on behalf of the Government with respect to the specific contract.

Contracting Officer Representative (COR): The individual designated by the Contracting Officer as the authorized representative of the Contracting Officer. The COR is responsible for monitoring performance and technical management of the effort required and should be contacted regarding questions or problems of a technical nature.

Contractor: The term Contractor refers to both the prime Contractor and subcontractors, including the Designer of Record.

Designer of Record (DOR): Licensed architect/engineer working as subcontractor to or partner with prime Contractor who provides design for this contract.

Quality Control (QC): Contractor's system to control the quality of design, material, equipment and construction.

Quality Assurance (QA) Program: Government's program to evaluate the effectiveness of the Contractor's quality control. The Government's QA Program is not a substitute for the Contractor's QC Program.

Federal Holidays: New Year's Day, Martin Luther King Jr. Day, President's Day, Memorial Day, Independence Day; Labor Day, Columbus Day, Veterans Day, Thanksgiving Day, and Christmas Day.

Contract: Contract or task order.

2. **ORDER OF PRECEDENCE:** NFAS Clause 5252.236-9312. In the event of conflict or inconsistency between any of the below described portions of the confirmed contract, precedence shall be given in the following order:

- a. Any portions of the proposal or final design that exceed the requirements of the solicitation.
  - 1) Any portion of the proposal that exceeds the final design.
  - 2) Any portion of the final design that exceeds the proposal.
  - 3) Where portions within either the proposal or the final design conflict, the portion that most exceeds the requirements of the solicitation has precedence.
- b. The requirements of the solicitation, in descending order of precedence:
  - 1) Standard Form 1442, Price Schedule, and Davis Bacon wage rates.
  - 2) Part 1 – Contract Clauses.
  - 3) Part 2 – General Requirements.

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

- 4) Part 3 – Statement of Work/Project Program Requirements.
- 5) Part 6 – Attachments (excluding Concept Drawings).
- 6) Part 5 – Prescriptive Specifications, exclusive of performance specifications.
- 7) Part 4 – Minimum Materials, Engineering and Construction Requirements, exclusive of prescriptive specifications.
- 8) Part 6 – Attachments (including Concept Drawings).

3. **POST AWARD KICKOFF MEETING (PAK):** Prior to commencement of design, and within 21 calendar days of award, meet with representatives of the Contracting Officer, installation and client to present the concept design for discussion and acceptance. The project team will develop a mutual understanding relative to the approved proposal, safety program, environmental permits and requirements, quality control procedures, and design and construction schedule. During the meeting, Contractor shall propose and gain acceptance for any critical path work activities requiring advance submittal and approval. If the contract includes work on any fire protection system, including fire alarm and mass notification systems, the Contractor and the appropriate DOR shall meet with the NAVFAC Fire Protection Engineer (FPE) to establish clear expectations of fire protection requirements of the project.

The Contractor's key personnel shall attend at the expense of the Contractor. Key personnel are defined as the Project Manager, Superintendent, CQC representative(s), DOR, major subcontractors and specialized supplementary personnel.

The PAK includes partnering, held during normal work hours with the non-labor –related costs shared by both parties. Partnering is a structured process, as well as philosophy of doing business with Contractors and clients that recognizes common goals through communication and teamwork. It helps create an environment where trust and teamwork prevent disputes, foster good working relationships to everyone's benefit, and facilitate the completion of a successful contract. If included in Attachment A, a Performance Assessment Plan that provides monthly performance feedback to the Contractor, will be discussed during the partnering session.

Key personnel will meet to identify strategies to ensure the project is carried to expeditious closure and turnover to the Client. Start the turnover process at the PAK Meeting utilizing the NAVFAC Red Zone (NRZ) Checklist and convene the Facility Turnover Meetings once the project has reached approximately 75% completion or 3 to 6 months prior to Beneficial Occupancy Date (BOD), whichever comes first. The Contracting Officer's Representative will lead the meetings and guide the discussions based on an agenda provided by the Government. The Facility Turnover effort shall fill in the NRZ Checklist including Contractor, Client, and NAVFAC Checklist Items and assign a person to be responsible for each item and a due date. The Contracting Officer's Representative will facilitate the assignment of responsibilities and fill out the NRZ Checklist. The Contracting Officer's Representative shall develop a Plan of Action and Milestones (POAM) for the completion of all Contractor, Client, and NAVFAC Checklist items.

4. **DESIGN:** Design is the work necessary to ensure functionality, quality, and safety for critical facets of the project. Special coordination requirements, such as for phone, LAN and cable, are included in Attachment A.

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

- a. Provide work in compliance with the following design standards and codes, as a minimum. Government standards listed in this RFP take precedence over industry standards.

This RFP references published standards, the titles of which can be found in the Unified Master Reference List (UMRL) on the Whole Building Design Guide at the Unified Facilities Guide Specification (UFGS) Website. The publications referenced form a part of this specification to the extent referenced.

The advisory provisions of all codes, requirements, and standards shall be mandatory; substitute words such as “shall”, “must”, or “required” for words such as “should”, “may”, or “recommended,” wherever they appear. The results of these wording substitutions incorporate these code and standard statements as requirements. Reference to the “authority having jurisdiction” shall be interpreted to mean Contracting Officer or Contracting Officer Representative. Comply with the required and advisory portions of the current edition of the standard at the time of contract solicitation.

The following list of codes and standards is not comprehensive and is augmented by other codes and standards referenced and cross-referenced in the RFP. Refer to Parts 3 and 4 for specific requirements within other UFC's.

- a) UFC 1-200-01, *General Building Requirements*
  - b) UFC 1-300-08, *Criteria for Transfer and Acceptance of Military Real Property*
  - c) UFC 1-300-09N, *Design Procedures*
  - d) UFC 3-560-01, *Electrical Safety, O&M*
  - e) UFC 3-600-01, *Fire Protection Engineering for Facilities*
  - f) UFC 3-600-10N, *Fire Protection Engineering*
  - g) UFC 3-800-10N, *Environmental Engineering for Facility Construction*
  - h) UFC 4-010-01, *DoD Minimum Antiterrorism Standards for Buildings*
  - i) UFC 4-020-01, *Security Engineering: Facilities Planning Manual*
- b. Part 3 contains the project description, functional and performance requirements, scope items, and expected quality levels that exceed Part 4. Part 4 identifies design criteria, verification requirements, and performance and quality requirements of products. See “Order of Precedence” paragraph in Part 2 for relationships between all parts of this RFP.
  - c. Provide professional registration and design signing and stamping requirements per requirements of UFC 1-300-09N, *Design Procedures*.
  - d. See Attachment A for project-specific submittal requirements.

**5. FIRE PROTECTION AND LIFE SAFETY REQUIREMENTS:** Work shall comply with applicable criteria identified herein and Attachment A. Any project including work on means of egress, fire rated elements, Fire Suppression, Mass Notification, or Fire Alarm Systems shall require the services of a Registered Fire Protection Engineer per Attachment A.

- a. Final Life Safety/Fire Protection Certification Documentation: Unless otherwise specified in Attachment A, provide certification that all life safety and fire protection features and

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

systems have been installed in accordance with applicable criteria, the contract documents, approved submittals, and manufacturer's requirements. This certification shall summarize all life safety and fire protection features.

6. **QUALITY CONTROL:** Maintain quality control for and inspect all work under the contract. The DOR, as a member of the Contractor QC organization, shall remain directly involved during the construction process. For certain projects, the Quality Control Manager, Superintendent, and Site Safety and Health Officer may be combined – see paragraphs 6 and 34 in Attachment A. Further QC requirements are identified in Attachment A.

- a. Submit a QC Plan for Government review and acceptance. The QC plan shall include the following:
  - 1) **NAMES, QUALIFICATIONS and RESPONSIBILITIES:** For each person in the QC organization (design and construction).
  - 2) **OUTSIDE ORGANIZATIONS:** Outside organizations, including architectural and consulting engineering firms and a description of the services these firms will provide.
  - 3) **INITIAL SUBMITTAL REGISTER (DESIGN & CONSTRUCTION):** Include submittal reviewer, estimated date of delivery, and identify which design submittals require Government approval prior to construction, and which construction submittals require DOR or Government approval prior to construction.
  - 4) **TESTING LABORATORIES:** Accredited laboratories as applicable.
  - 5) **TESTING PLAN AND LOG:** Tests required, referenced by specification paragraph number requiring the test, frequency, and person responsible for each test.
  - 6) **LIST OF DEFINABLE FEATURES:** A Definable Feature of Work (DFOW) is a task, which is separate and distinct from other tasks, and has the same control requirements and work crews.
  - 7) **COMMUNICATION PLAN:** Provide a plan for key decisions and possible problems the Contractor and Government may encounter during the design phase of the project. Communication Plan shall indicate the frequency of design meetings and what information is covered in those meetings, key design decision points tied to the Network Analysis Schedule and how the DOR plans to include the Government in those decisions, peer review procedures, interdisciplinary coordination, design review procedures, and comment resolution.
- b. **QC Manager Responsibilities:**
  - 1) Participate in the Post Award Kick-off, Partnering, Design Development and Coordination Meetings and Production Meetings.
  - 2) Ensure that no construction begins before the DOR has signed and stamped the design for that segment of work, and design and construction submittals are approved as required in Attachment A and the QC Plan.
  - 3) Immediately stop any work that does not comply with contract plans and specifications, and direct the removal and replacement of any defective work.
  - 4) Prepare QC Reports.

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

- 5) Hold biweekly QC meetings with DOR, Superintendent and Government technical team; participation shall be suitable for the phase of work.
  - 6) Ensure that safety inspections are performed. Attend weekly Toolbox meetings.
  - 7) Maintain submittal log.
  - 8) Maintain updated as-built drawings on site.
  - 9) Maintain testing plan and log. Ensure that all testing is performed per contract.
  - 10) Maintain deficiency log on site, noting dates deficiency identified, and date corrected.
  - 11) Certify and sign statement on each invoice that all work to be paid under the invoice has been completed in accordance with contract requirements.
  - 12) Perform Punch-out and Pre-final inspections, and participate in Final Inspections. Establish list of deficiencies; correct prior to the Final inspection.
  - 13) Ensure that all required keys, operation and maintenance manuals, warranty certificates, and the As-built drawings are submitted to the Contracting Officer.
- c. Use the Three Phases of Control process for construction QC.
- 1) Preparatory Phase: Review all applicable documents for compliance with all applicable laws, codes, regulations, and the requirements of the contract, including contract drawings and specifications. Determine requirements for testing and certification. Review submittal approvals for materials, equipment, shop drawings, and applicable methods of construction and installation. Include all Preparatory Phase items in the QC Report.
  - 2) Initial Phase: Observe and inspect the initial portion of the work performed under a DFOW to establish the quality of the workmanship, resolve conflicts in construction, ensure that testing is done and certified as required, and to check all work procedures to ascertain the work is in conformance with required safety requirements. Record and report nonconforming work and work not of acceptable quality and requiring correction or rework. Include all Initial Phase items, along with initial phase checklist and, in the QC Report.
  - 3) Follow-Up Phase: Occurs at the completion of each DFOW. Ensure the work is in compliance with contract requirements, quality of workmanship for all work is maintained, and all work performed meets safety requirements. Include all Follow-Up Phase items, including date, in the QC Report.
- d. The QC Manager must possess a current certificate showing successful completion of the NAVFAC Contractor Quality Management (CQM) Training.
7. **SUBMITTAL PROCESS:** Provide to the Government submittals as listed. See Paragraph 4, DESIGN, and Attachment A for specific design and construction submittal format and approval and surveillance requirements. Design drawings may be prepared more like shop drawings to minimize construction submittals after final designs are approved. Therefore, the Contractor is encouraged to prepare and submit with the design drawings, appropriate connection, fabrication, layout, and product specific drawings.
- a. QC Plan, prior to Design/Construction (may be phased).

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

- b. Design and construction submittals, prior to construction, approved IAW QC Plan, The DOR or QC Specialist is the approving authority for submittals unless otherwise indicated in Attachment A.
  - c. DOR-approved design and construction submittals identified in Attachment A for Government surveillance (typically Fire Protection system and Life Safety submittals). Stamp the submittals “FOR SURVEILLANCE ONLY.” Submit Surveillance submittals to the Government prior to starting work for that item. Submittals required for surveillance will be returned only if corrective actions are required.
  - d. Material Safety Data Sheets (MSDS) as applicable.
  - e. Schedule: Provide detailed design schedule and preliminary construction schedule, due prior to PAK.
  - f. Environmental Protection Plan, prior to start of the work.
  - g. Contractor Safety Self-Evaluation Checklist.
  - h. Accident Reports – submit if incidence occurs.
  - i. Safety Submittals: Per Paragraph 34 and Attachment A, prior to construction.
  - j. Schedule of Prices, initial due 21 calendar days after award and a detailed due prior to construction.
  - k. Budget Management Summary: Per Attachment A.
  - l. Record Drawings, due at Beneficial Occupancy
  - m. Operation and Maintenance Information: Per Paragraph 23, Part 2 Attachment A, and Part 4. Due prior to testing as applicable, no later than 30 calendar days before Beneficial Occupancy.
  - n. Licenses and Permits: Per Attachment A and Part 4.
  - o. DD Form 1354: For all new construction, demolition, and any construction on an existing facility that adds new parts, items, or systems that are not maintenance or repair; e.g. replacement of windows, replacement of roofs, replacement of an exterior utility, adding an AC system, adding exterior lighting, the DOR shall prepare DD Form 1354 TRANSFER AND ACCEPTANCE OF MILITARY REAL PROPERTY, in accordance with UFC 1-300-08, available at [http://65.204.17.188/report/doc\\_ufc.html](http://65.204.17.188/report/doc_ufc.html). Submit form for Government approval a minimum of 30 calendar days prior to final acceptance of work.
8. **SUPERVISION:** The Contractor shall have a supervisor fluent in English on the job site during working hours. Additional requirements per Attachment A.
9. **SCHEDULE:** Provide Design and Construction Schedule adequate for Contractor to efficiently manage project and for Government to efficiently manage QA and scheduling interfaces. Include construction phasing and any work restrictions (such as occupied spaces, special hours, potential work disruptions). Schedule shall contain DFOWs and dates for completion of each task including material procurement, and construction activities. Update the schedule at least monthly; use 3-week look-ahead for each QC meeting.
10. **BUDGET MANAGEMENT:** The Contractor shall be responsible for budget management throughout the entire project. It is the intent of the Government to partner with the Contractor to

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

maximize project value while strictly controlling contract modifications and maintaining overall fiscal control. When required in Attachment A, develop a Budget Management System for each phase of the design.

11. **PRECONSTRUCTION CONFERENCE:** Prior to construction or demolition start, meet with representatives of the Contracting Officer to discuss and develop mutual understanding relative to administration of the safety programs, environmental issues, safety of building occupants and surrounding area, hazardous materials, waste disposal, construction QC procedures, construction schedule, labor provisions and other construction phase contract procedures. The Preconstruction Conference shall reinforce partnering philosophy initially established during the PAK.

12. **ACCESSIBILITY:** Provide barrier-free design in accordance with the requirements of the DEPSECDEF Memorandum "Access for People with Disabilities" dated Oct 31, 2008. The memorandum updates the DoD standards for making facilities accessible to people with disabilities. The US Access Board issued an update of the accessibility guidelines which the DEPSECDEF Memorandum implements with military unique requirements specified in the memorandum attachment. The new DoD, "ABA (Architectural Barriers Act) Accessibility Standard" (DoD ABAAS) and the DEPSECDEF Memorandum are located at <http://www.access-board.gov/ada%2Daba/aba-standards-dod.cfm> .

13. **CONTRACTOR'S PRODUCTION REPORTS:** Submit Contractor Production Reports on forms furnished for this purpose. Complete the reports weekly unless otherwise requested by the Contracting Officer. Reports shall include:

- a. Worker hours by classification, move-on and move-off of construction equipment furnished by the prime, subcontractor or the Government, and materials and equipment delivered to the site.
- b. Safety meetings, checks and inspections.
- c. Disposition of Construction Waste Material: Per Environmental Protection Plan.
- d. Design and Construction Services: Including, but not necessarily limited to:
  - 1) Check all Contract Documents for correctness and correlation. If the Contractor notes any discrepancy or ambiguity, immediately notify the COR.
  - 2) Examine the work site as to conditions affecting the work. Field verify the site and scope of work, including but not limited to the measurement and location of all significant items required to perform the work. Failure by the Contractor to familiarize oneself with available information regarding these conditions shall not relieve the Contractor from the responsibility of successfully completing the work.

14. **SCHEDULE OF PRICES:** Submit on forms furnished by the Government. The initial schedule of prices may be preliminary for construction activities until the design is developed. Include a detailed breakdown of the contract price, with quantities for each kind of work. Include General Conditions, profit, and overhead in the unit prices. Break down into design and each construction category if stated in Attachment A. The Contractor may invoice for bonds once the Government has approved the bonds, however, no other requests for payment will be processed without an approved Schedule of Prices.

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

15. **CONTRACTOR INVOICES:** Contractor requests for payment shall conform and will be processed in accordance with the requirements of FAR 52.232-5 and FAR 52.232-27.

a. Content of Invoice: Requests for payment in accordance with the terms of the contract shall consist of the following: (If NFAS Clause 5252.232-9301 is present in the contract, documents shall be provided as attachments in Wide Area Workflow (WAWF). The maximum size limit per attachment is less than 2 megabytes, but you may have an unlimited number of attachments. If a document cannot be attached to WAWF due to system or size restrictions it shall be provided as instructed by the contracting officer). If NFAS Clause 5252.232.9301 is not present in the contract, follow the invoicing instructions provided in the contract.

- 1) Contractor's Invoice on NAVFAC Form 7300/30, which shall show, in summary form, the basis for arriving at the amount of the invoice.
- 2) Contractor's Monthly Estimate for Voucher (LANTNAVFACENGCOM Form 4-4330/110 (New 7/84)), with subcontractor and supplier payment certification.
- 3) Affidavit to accompany invoice (LANTDIV NORVA Form 4-4235/4 (Rev. 5/81)).
- 4) Updated copy of submittal register.
- 5) Updated copy of progress schedule. Furnish as specified in "FAR 52.236-15, Schedules for Construction Contracts."
- 6) Network mathematical analysis.
- 7) Contractor Safety Self Evaluation Checklist (original)
- 8) Final release (for final payment only)

b. Payment:

- 1) Payment will be made on Contractor's submission of itemized requests and will be subject to reduction for overpayments or increased for underpayments from previous payments. The Government may withhold payment or reduce payments for the following:
  - a) Defects in material or workmanship.
  - b) Claims the Government may have against the Contractor under or in connection with this contract.
  - c) Contractor's failure to submit an updated schedule.
  - d) Payroll violations.
  - e) Unless otherwise adjusted, repayment to the Government upon demand for overpayments made to the Contractor.
- 2) Payments may be made for materials, stored off construction sites, under the following conditions:
  - a) Conditions described in Attachment A.
  - b) Materials adequately insured and protected from theft and exposure.
  - c) Materials not susceptible to deterioration or physical damage in storage or in transit to the job site are acceptable for progress payments. Items such as steel, machinery, pipe and fittings and electrical cable are acceptable, but items such as gypsum board; glass, insulation and wall covering are not.

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

- d) Materials in transit to the job or storage site are not acceptable for payment.
- e) Conditions specified in FAR 52.232-5(b) Payments Under Fixed Price Construction Contracts.

16. **PROTECTION OF GOVERNMENT PROPERTY:** Take special care to protect Government property. Return areas damaged as a result of construction under this contract to their original condition. In addition to FAR 52.236-9, *Protection of Existing Vegetation, Structures, Equipment, Utilities, and Improvements*, perform the following:

- a. Remove or alter existing work or facilities in such a manner as to prevent injury or damage to any portion of the existing work or facilities that remain.
- b. Repair or replace portions of existing work altered during construction operations to match existing or adjoining work, as approved by the Contracting Officer. At the completion of operations, existing work shall be in a condition equal to or better than that which existed before new work started.
- c. Preserve the natural resources in accordance with the approved environmental protection plan.

17. **EXISTING UNDERGROUND UTILITIES:** Verify on-site utilities and have them marked out by a utility locator service prior to the start of construction. Where existing piping, utilities, oil and gas lines, and underground obstructions of any type that are to remain are indicated in locations to be traversed by new piping, ducts, and other work provided herein, and such are not indicated or specified to be removed, the elevations of the existing utilities and obstructions shall be determined before the new work is laid closer than the nearest manhole or other structure at which an adjustment in grade could be made. Obtain required dig permits and notify the Contracting Officer 21 calendar days prior to any excavation. Refer to Attachment A for specific station requirements.

18. **LICENSES/PERMITS:** Obtain all appointments, licenses, and permits required to perform work under this contract at no additional expense to the Government. See "Permits Record of Decision" (PROD) form for list of permits. Comply with all applicable federal, state, and local laws, and base regulations and procedures. Provide evidence of such permits and licenses to the Contracting Officer before work commences and at other times as requested by the Contracting Officer (see FAR 52.236-7, *Permits and Responsibilities*). Coordinate permit applications with Navy or local environmental office.

The contractor shall submit a complete PROD form with the first design submittal package. A blank PROD form can be obtained at the Download Tab of Part 6 of the NAVFAC Design-Build website at the following link <http://www.wbdg.org/ndbm/Download/Download.html?Tab=Download>. Contractor shall determine correct permit fees and pay said fees. Copies of all permits, permit applications, and the completed PROD form shall be forwarded to the Government's Civil Reviewer and Environmental Reviewer.

Contractor is exclusively responsible for his full compliance with patent laws and shall affirm that the company is licensed to use equipment and processes the company shall employ in this project.

19. **CONTRACTOR WORK SITE:** Limit use of the premises for work and for storage of material and equipment associated with the contract. Unless otherwise specified or separately agreed to, Government owned material handling equipment, transportation equipment or general tools will not

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

be available for Contractor's use. Clean work area daily and after completion of the work, removing all loose debris and disposing of all non-permanent materials IAW the contractor's Waste Management Plan.

- a. **Temporary Facilities:** The Contractor may provide his own office facilities; coordinate and obtain advance approval from the Contracting Officer. Provide and maintain suitable sanitary facilities within the construction limits of the contract. Dispose of sanitary waste in accordance with the applicable laws, and local regulation.
- b. **Contractor-Furnished Equipment:** Equipment is subject to the inspection and approval of the Contracting Officer, prior to and during the life of the contract. All equipment and vehicles shall display readily visible Contractor identification markings. Relocate stored Contractor equipment which may interfere with operations of the Government or with others on-site.
- c. **Contractor-furnished Material:** Protect and secure products stored at this site.
  - 1) All replacement units, parts, components, and materials to be used in the maintenance, repair and alteration of facilities and equipment shall be new and compatible with the existing equipment on which it is to be used, and shall comply with applicable Government, commercial, or industrial standards such as Underwriter's Laboratories, Inc., and National Electrical Manufacturers Association.
  - 2) In addition, submit a current certificate recognized by the State or local authority that states the Contractor has completed at least 10 hours of training in backflow preventer installations.

**20. TEMPORARY UTILITIES:**

- a. The Government will provide water and power in reasonable quantities at the prevailing rates.
- b. All labor, material, and equipment necessary to affect temporary utility tie-ins, including transformers if necessary, shall be at the expense of the Contractor and under the surveillance of the Contracting Officer.
- c. The Contractor shall be responsible for any damages to Government, private or public facilities and property that may result from the installation and removal of these temporary utility tie-ins. Corrections and repairs shall be made at the Contractor's expense.
- d. The actual location and installation of the temporary tie-in, together with any interruptions of utilities systems, shall be identified and approved by the Contracting Officer prior to execution. Notify the COR and Station Utilities 15 calendar days prior to any tie-ins.
- e. Permanent utility systems, when indicated, will be available for tie-in.
- f. Telephone and Data Service: Make arrangements with local telephone company, NMCI and other pertinent base communication departments.
- g. Maintain utility services to existing facilities surrounding the site at all times during construction.
- h. Contractor shall install and certify back flow preventers on all connections to the potable water supply system.

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

**21. ENVIRONMENTAL CONTROLS AND PROTECTION**

Unforeseen Hazardous Conditions: Do not disturb hazardous materials and report condition immediately to the Contracting Officer potentially hazardous conditions that are uncovered or the Contractor becomes aware of that have not been identified in the RFP. This includes hazardous components and materials and contamination (see UFC 3-800-10 for more information). This includes conditions that are not only hazardous to humans but wildlife, marine life and the environment. Stop work in the area of the questionable material or condition until identification and direction is provided.

**22. WASTE MANAGEMENT:** Develop a Waste Management Plan that identifies all recyclable material and disposal methods for all material. Contractor shall reduce, recycle or salvage as much waste material as possible with a goal of diverting at least 50% of construction waste from landfill. Address waste reduction, recycling and salvage as part of the waste management plan. Report volume or weight of disposed and recycled materials. The Contractor is responsible for removing and disposing of all waste materials generated. Consider all material recyclable or reusable, unless clearly demonstrated the material requiring disposal is waste material.

**23. RECORD DRAWINGS AND OPERATION & MAINTENANCE (O&M) DATA:** Furnish hard copy and electronic format for all as-built and O&M information. Record drawings shall incorporate all changes to the approved final design. Provide O&M data for as-built products, materials, and equipment, including data sheets, test reports, warranties, certificates, list of spare parts suppliers for all pieces of equipment, and approved construction submittals. Refer to Attachment A.

**24. WARRANTY:** Warrant all materials and work for not less than one year after final acceptance of the work, except as otherwise indicated in this RFP. If required to provide remedial repair of previously installed work due to latent defect or unacceptable work performance, warrant the repaired work for one year after the completion and acceptance of the repair. For warranted items, furnish the manufacturers' original written warranty accompanied by a copy of the supplier's receipt showing place of purchase, telephone number of supplier, address, delivery order number if applicable, and ticket number.

**25. PERFORMANCE EVALUATIONS:** The evaluation will take into account all aspects of the Contractor's performance, including evaluations from Performance Assessment Plans when included in Attachment A. Performance evaluations may be completed any time during the contract. The Government will provide a copy of the performance evaluation and an opportunity to discuss the evaluation. The performance evaluations will have an impact on the award of future contracts.

**26. WORK HOURS, ACCESS AND PASSES:** All Contractor employees, including subcontractors, and subcontractors' employees, suppliers, and suppliers' employees shall be required to comply with the Installation Security Requirements regarding personnel, vehicle, and equipment security passes and access the jobsite. Nothing in the contract shall be construed in any way to limit the authority of the Commanding Officer to prescribe new, or to enforce existing security regulations governing the admission or exclusion of persons and the conduct of persons while aboard the station, including but not limited to, the rights of search of all persons or vehicles aboard the station.

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

Coordinate with the Contracting Officer for specific security and access requirements.

- a. Access to Buildings/ Occupied Buildings: The Contractor may work in or around existing occupied buildings. The Contractor is responsible, via the Contracting Officer, to obtain access to building and facilities and arrange for them to be opened and closed. Do not enter the building(s) without prior approval of the Contracting Officer. Keep the existing buildings and their contents secure at all times. Provide temporary closures as required to maintain security. Contract personnel will not be permitted in security-regulated buildings or areas unless cleared by the Security Officer.
- b. Passes and Badges: Contractor employees and representatives performing work under this contract are required to be either United States citizens or documented legal residents (status verified by prime contractor). All Contractor employees shall obtain the required employee and vehicle passes. Each employee shall wear the Government issued badge over the front of the outer clothing. Failure to obtain security and base access passes shall not be a cause for contract performance time extension. The Contractor shall immediately turn in all terminated employee's badges to the issuing office.
  - 1) Personnel will be issued appropriate identification badges when the Contractor submits, in writing on company letterhead, a list indicating that all individuals are bona fide employees. Employees shall complete questionnaires and other forms as required for security. Allow 14 calendar days for background checks and processing. The list shall contain the following information:
    - f) Name of employee
    - g) Social Security Number
    - h) Date of Birth
    - i) Place of Birth
    - j) Citizenship, Statement of (U.S.) or proof of documented legal residency
    - k) Employment Eligibility Verification Form (DHS FORM I-9). This form is available at <http://uscis.gov/graphics/formsfee/forms/files/I-9.pdf>
- c. Contractor Vehicles: All vehicles shall display a valid state license plate and safety inspection sticker, if applicable, and shall be maintained in good repair. The company name shall be displayed in a clearly visible manner and size on each Contractor vehicle used in the course of work. Registration, proof of insurance and driver's licenses are required to obtain a station vehicle pass.
- d. Work Hours: Unless otherwise indicated, work will be located on a Government compound, military installation, or station. Contractor work hours shall be between 0630 and 1700 Monday through Friday, or as indicated in Attachment A. Obtain advance approval from the Contracting Officer for Contractor personnel to remain on site beyond normal working hours. Notify the Contracting Officer at least 48 hours in advance to obtain approval for access to the jobsite or work outside of normal working hours or on Saturday, Sunday, and Federal Holidays.
- e. Contractor Personnel: Provide the Contracting Officer the name(s) of the supervisory person(s) authorized to act for the Contractor. Provide, and update as required, a list of the key personnel for the Contractor and subcontractors including addresses and telephone numbers for use in the event of an emergency.

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

- f. Contractor employees shall conduct themselves in a proper, efficient, courteous and businesslike manner. Remove from the site any individual whose continued employment is deemed by the Contracting Officer to be contrary to the public interest or inconsistent with the best interests of National Security.

27. **SECURITY REQUIREMENTS:** All security requirements apply to all subcontractors and suppliers associated with this contract. Special or extraordinary security requirements are identified in Attachment A. In addition to special or extraordinary security requirements, comply with the following:

- a. Do not publicly disclose any information concerning any aspect of the materials or services relating to this contract, without prior written approval of the Contracting Officer.
- b. Do not disclose or cause to be disseminated any information concerning the operations of the activity's security or interrupt the continuity of its operations.
- c. Do not disclose any information to any person not entitled to receive it. Failure to safeguard any classified information that may come to the Contractor or any person under his control, may subject the Contractor, his agents or employees to criminal liability under 18 U.S.C., Sections 793 and 798.
- d. Direct to the Contracting Officer and or Installation Security Officer for resolution all inquiries, comments or complaints arising from any matter observed, experienced, or learned as a result of or in connection with the performance of this contract, the resolution of which may require the dissemination of official information.
- e. Coordinate photography requirements with the Contracting Office. Some areas restrict or prohibit photographing Government property.

Deviations from or violations of any of the provisions of this paragraph, will, in addition to all other criminal and civil remedies provided by law, subject the Contractor to immediate termination for default and withdrawal of the Government's acceptance and approval of employment of the individuals involved.

28. **REQUIRED INSURANCE:** Within 15 calendar days after award, furnish the Contracting Officer a Certificate of Insurance as evidence of the following insurance coverage amounts not less than the amount specified below in accordance with FAR Clause 52.228-5, *Insurance Work On A Government Installation*:

- a. Comprehensive General Liability: \$500,000 per occurrence.
- b. Automobile Liability: \$200,000 per person, \$500,000 per occurrence for bodily injury; \$20,000 per occurrence for property damage.
- c. Worker's Compensation: As required by Federal and State Worker's compensation and occupational disease and other laws.
- d. Employer's Liability Coverage: \$100,000, except in states where worker's compensation may not be written by private carriers.
- e. Others as required by state law.
- f. Above insurance coverages are to extend to Contractor personnel operating Government owned equipment and vehicles.
- g. The Certificate of Insurance shall provide for 30 calendar days written notice to the Contracting Officer by the insurance company prior to cancellation or material change in policy coverage. Other requirements and information are contained in Attachment A.

**Replace Siding – Bldg 405  
Naval Support Activity, Mechanicsburg, Pennsylvania  
Work Order Number 1350926**

For projects which require removal of asbestos containing materials the Asbestos Contractor or Subcontractor, as the case may be shall provide occurrence-based liability insurance with asbestos coverages in an amount not less than \$1,000,000 and shall name the Government and PQP as additional insureds.

29. **PROPRIETARY RIGHTS:** All field notes, design drawings, specifications, and other documents collected and produced as part of this contract shall be considered property of the Government. These data shall not be used, in whole or part, published or unpublished, as a part of any technical or non-technical presentation without written pre-approval of the Contracting Officer.

30. **GOVERNMENT FURNISHED MATERIAL AND EQUIPMENT:** If applicable, the Government will furnish the materials and equipment for installation by the Contractor pursuant to contract clause FAR 52.245-2, *Government Property (Fixed Price Contracts)*. Notify the Contracting Officer in writing at least 15 calendar days before the materials and equipment are required. Pick up materials and equipment no later than 30 calendar days after such date. When materials and equipment are not picked up by the 30th day, the Contractor will be charged for storage at the prevailing rate. The Contracting Officer will specify the location of materials and equipment and the delivery location.

31. **ORAL MODIFICATION:** No oral statement by any person other than the Contracting Officer, as provided in the contract clause entitled, "CHANGES AND CHANGED CONDITIONS," will in any manner or degree modify or otherwise affect the terms of this contract.

32. **NO WAIVER BY THE GOVERNMENT:** The failure of the Government in any one or more instances to insist upon strict performance to any of the terms of this contract or to exercise any option herein conferred shall not be construed as a waiver or relinquishment to any extent of the right to assert or rely upon such terms or options on any future occasion.

33. **EQUITABLE ADJUSTMENTS – WAIVER AND RELEASE OF CLAIMS:**

- a. Whenever the Contractor submits a claim for equitable adjustment under a clause which provides for equitable adjustment of the contract, such claim shall include all types of adjustments in the total amounts to which the clause entitles the Contractor, including, but not limited to, adjustment arising out of delays or disruptions.
- b. Except as the parties may otherwise expressly agree, the Contractor shall be deemed to have waived: (1) any adjustments to which he otherwise might be entitled under the clause where such claim fails to request such adjustments; and (2) any increase in the amount of equitable adjustments additional to those requested in its claim.
- c. The Contractor agrees that, if required by the Contracting Officer, it shall execute a release, in form and substance satisfactory to the Contracting Officer, as part of the supplemental agreement setting forth the aforesaid equitable adjustment. The Contractor further agrees that such release shall discharge the Government, including its officers, agents, and employees, from any further claims, including, but not limited to, further claims arising out of delays or disruptions caused by the aforesaid change.

34. **SAFETY AND OCCUPATIONAL HEALTH REQUIREMENTS:**

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

- a. References: The publications listed below form a part of this specification to the extent referenced. Use current version of referenced requirements at the time of contract solicitation. The publications are referred to within the text by the basic designation only.

**AMERICAN NATIONAL STANDARDS INSTITUTE (ANSI)**

ANSI Z359.1, *Safety Requirements for Personal Fall Arrest System, Subsystems and Components*

ANSI A10.32, *Fall Protection systems for Construction and Demolition Operations*

ANSI A10.6, *Demolition Operations*

ANSI Z9.2, *Fundamentals Governing the Design and Operation of Local Exhaust Systems*

ANSI Z88.2, *Respiratory Protection*

ANSI Z358.1, *Emergency Eyewash and Shower Equipment*

**ASME INTERNATIONAL (ASME)**

ASME B30.22, *Articulating Boom Cranes*

ASME B30.3, *Construction Tower Cranes*

ASME B30.5, *Mobile and Locomotive Cranes*

ASME B30.8, *Floating Cranes and Floating Derricks*

**AMERICAN SOCIETY OF TESTING AND MATERIALS (ASTM)**

ASTM Standards on Lead-Based Paint Abatement in Buildings

ASTM E 1368, *Visual Inspection of Asbestos Abatement Projects*

**DEPARTMENT OF DEFENSE (DoD)**

MIL-STD-1472F, *Military Standard, Human Engineering Design Criteria for Military Systems, Equipment and Facilities*

DoD-HDBK 743A, *Anthropometry of US Military Personnel*

**DEFENSE LOGISTICS AGENCY (DLA)**

DLA 4145.25, *Storage and Handling of Compressed Gases and Liquids in Cylinders*

**EPA Standards and Documents – General**

15 U.S.C. 2601 – *Toxic Substances Control Act*

EPA Title X – *The Residential Lead Based Paint Hazard Reduction Act*

EPA & HUD – *Lead Safe Work Practices*

HUD Guidelines, *Guidelines for the Evaluation and Control of Lead Based Paint Hazards in Housing*

**NATIONAL FIRE PROTECTION ASSOCIATION (NFPA)**

NFPA 241, *Safeguarding Construction, Alteration, and Demolition Operations*

NFPA 51B, *Fire Prevention During Welding, Cutting, and Other Hot Work*

NFPA 70, *National Electrical Code*

NFPA 70E, *Electrical Safety in the Workplace*

**U.S. ARMY CORPS OF ENGINEERS (USACE)**

EM 385-1-1 *Safety -- Safety and Health Requirements*

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

UNITED FACILITIES CRITERIA (UFC)  
UFC 3-560-01, *Electrical Safety, O&M*

U.S. NATIONAL ARCHIVES AND RECORDS ADMINISTRATION (NARA)  
29 CFR 1910 *Occupational Safety and Health Standards*  
29 CFR 1910.146 *Permit-required Confined Spaces*  
29 CFR 1915 *Occupational Safety and Health Standards for Shipyard Employment*  
29 CFR 1926 *Safety and Health Regulations for Construction*

- b. Submittals: A "G" following a submittal indicates that Government approval action is required.
- 1) Contractor Accident Prevention Plan (APP), comply with EM 385-1-1, Appendix A; G
  - 2) Contractor Safety Self-Evaluation Checklist; G
  - 3) Monthly Work-Hour Reports
  - 4) Crane Critical Lift Plan; G
  - 5) Accident Reports – submit if incidence occurs.
  - 6) Activity Hazard Analyses, as applicable.
- c. Weight Handling Equipment (WHE) Accident: A WHE accident occurs when any one or more of the six elements in the operating envelope fails to perform correctly during operation, including operation during maintenance or testing resulting in personnel injury or death; material or equipment damage; dropped load; derailment; two-blocking; overload; or collision, including unplanned contact between the load, crane, or other objects. A dropped load, derailment, two-blocking, overload and collision are considered accidents even though no material damage or injury occurs. A component failure (e.g., motor burnout, gear tooth failure, bearing failure) is not considered an accident solely due to material or equipment damage unless the component failure results in damage to other components (e.g., dropped boom, dropped load, roll over).
- d. Contractor Safety Self-Evaluation Checklist: Contracting Officer will provide a "Contractor Safety Self-Evaluation checklist" to the Contractor. Complete the checklist monthly and submit with each request for payment. A score of 90 or greater is required. Failure to submit the completed safety self-evaluation checklist or achieve a score of at least 90, will result in a retention of up to 10 percent of the voucher.
- e. Regulatory Requirements: In addition to the detailed requirements included in this contract, work performed shall comply with USACE EM 385-1-1, and the laws, ordinances, criteria, rules and regulations included in Attachment A. Submit matters of interpretation of standards to the appropriate administrative agency for resolution before starting work. Where the requirements of this specification, applicable laws, criteria, ordinances, regulations, and referenced documents vary, the most stringent requirements shall apply. UFC 3-560-01 takes precedence over all other guidance for electrical safety.
- f. Site Safety and Health Officer (SSHO) Qualifications & Duties: SSHO shall perform safety and occupational health management, surveillance, inspections, and safety enforcement for the Contractor. The assignment of the SSHO does not relieve the Contractor from the regulatory requirements governing safety responsibility. The SSHO

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

on this project can be the site superintendent unless otherwise indicated in Attachment A.

In addition to duties required in EM 385-1-1 the SSHO shall perform the following:

- 1) Conduct daily safety and health inspections and maintain a written log which includes area/operation inspected, date of inspection, identified hazards, recommended corrective actions, estimated and actual dates of corrections. Attach safety inspection logs to the daily production report.
- 2) Attend pre-construction conference, pre-work meetings including preparatory inspection meeting, and periodic progress meetings.

Failure to actively apply an acceptable safety program will result in dismissal and a project work stoppage that will remain in effect pending approval of a suitable replacement.

g. Accident Notification and Reports

- 1) For recordable injuries and illnesses, and property damage accidents resulting in at least \$2,000 in damages, the Prime Contractor shall conduct an accident investigation to establish the root cause(s) of the accident, fill out the Contractor Incident Report (CIR) electronically and submit via the NAVFAC Enterprise Safety Applications Management System (ESAMS) within 5 calendar days. The Contracting Officer will provide copies of any required or special forms.
- 2) For any weight handling equipment accident (including rigging gear accidents), the Prime Contractor shall conduct an accident investigation to establish the root cause(s) of the accident, complete the WHE Accident Report (Crane and Rigging Gear) form and provide the report to the Contracting Officer within 30 calendar days of the accident. Crane operations shall not proceed until cause is determined and corrective actions have been implemented to the satisfaction of the contracting officer. The Contracting Officer will provide a blank copy of the accident report form.
- 3) Notify the Contracting Officer as soon as practical, but not later than four hours, after any accident meeting the definition of Recordable Injuries or Illnesses or High Visibility Accidents, property damage equal to or greater than \$2,000, or any weight handling equipment accident. Include contractor name; contract title; type of contract; name of activity, installation or location where accident occurred; date and time of accident; names of personnel injured; extent of property damage, if any; extent of injury, if known, and brief description of accident ( e.g., type of construction equipment used, PPE used). Preserve the conditions and evidence on accident site until the Government investigation team arrives and Government investigation is conducted.
- 4) Monthly Work-Hour Reports: Monthly work-hour reporting to the Contracting Officer is required to be attached to the monthly billing request. This report is a compilation of employee-hours worked each month for all site workers, both prime and subcontractor. The Contracting Officer will provide copies of any special forms.

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

- h. Hot Work: Prior to performing "Hot Work" (e.g., welding, cutting) or operating other flame-producing/ spark-producing devices, request a written permit from the Fire Division. CONTRACTORS ARE REQUIRED TO MEET ALL CRITERIA BEFORE A PERMIT IS ISSUED. It is mandatory to have a designated FIRE WATCH for any "Hot Work" done at this activity. The Fire Watch shall be trained in accordance with NFPA 51B and remain on-site as required after completion of the task or as specified on the hot work permit.
- i. Hazardous Material Use: Each hazardous material must receive approval prior to being brought onto the job site or prior to any other use in connection with this contract. Allow a minimum of 10 working days for processing of the request for use of a hazardous material.

Notwithstanding any other hazardous material used in this contract, radioactive materials or instruments capable of producing ionizing/non-ionizing radiation (with the exception of radioactive material and devices used in accordance with USACE EM 385-1-1 such as nuclear density meters for compaction testing and laboratory equipment with radioactive sources) as well as materials which contain asbestos, mercury or polychlorinated biphenyls, di-isocyanates, or lead-based paint are prohibited. The Contracting Officer, upon written request may consider exceptions to the use of any of the above excluded materials.

The Request for Proposal should have identified materials such as PCB, lead paint, and friable and non-friable asbestos. If material, not indicated, that may be hazardous to human health upon disturbance during construction operations is encountered, stop that portion of work and notify the Contracting Officer immediately. Within 14 calendar days the Government will determine if the material is hazardous. If material is not hazardous or poses no danger, the Government will direct the Contractor to proceed without change. If material is hazardous and handling of the material is necessary to accomplish the work, the Government will issue a modification pursuant to FAR 52.243-4, *Changes*, and FAR 52.236-2, *Differing Site Conditions*.

- j. Pre-outage Coordination Meeting: Apply for utility outages at least 15 days in advance. As a minimum, include the location of the outage, utilities being affected, duration of outage and any necessary sketches. Once approved, and prior to beginning work on the utility system requiring shut down, attend a pre-outage coordination meeting with the Contracting Officer to review the scope of work and the lock-out/tag-out procedures for worker protection. No work will be performed on energized electrical circuits unless proof is provided that no other means exist.
- k. Fall Hazard Protection and Prevention Program: Establish a fall protection and prevention program, for the protection of all employees exposed to fall hazards. Include company policy; identify responsibilities, education and training requirements, fall hazard identification, prevention and control measures, inspection, storage, care and maintenance of fall protection equipment and rescue and evacuation procedures.

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

- 1) Fall Protection for Roofing Work: Implement all protection controls based on the type of roof being constructed and work being performed. Evaluate the roof area to be accessed for its structural integrity including weight-bearing capabilities for the projected loading.
  - a) A safety monitoring system is not adequate fall protection for low sloped roofs and is not authorized.
  - b) Work on steep-sloped roofs, including residential or housing type construction, requires a personal fall arrest system, guardrails with toe-boards, or safety nets.
- 2) Fall Prevention and Design: During design, consider and eliminate fall hazards encountered at the facility during maintenance evolutions whenever possible. If it is not feasible to eliminate or prevent the need to work at heights with its subsequent exposure to fall hazards, include control measures in the design to protect personnel conducting maintenance work after completion of the project. In addition to the detailed requirements included in the provisions of this contract, incorporate the requirements of 29 CFR 1910 Standards in the design (29 CFR 1915 applies for work in Shipyards).

I. Weight Handling Equipment:

- 1) Crane Critical Lift Plan: Prepare and sign weight handling critical lift plans for lifts over 75 percent of the capacity of the crane or hoist (or lifts over 50 percent of the capacity of a barge mounted mobile crane's hoists) at any radius of lift; lifts involving more than one crane or hoist; lifts of personnel; and lifts involving non-routine rigging or operation, sensitive equipment, or unusual safety risks. Submit the plan 15 calendar days prior to on-site work and include the requirements of USACE EM 385-1-1, paragraph 16.C.18. as well as the following:
  - a) For lifts of personnel, demonstrate compliance with the requirements of 29 CFR 1926.550(g).
  - b) For barge mounted mobile cranes, barge stability calculations identifying barge list and trim based on anticipated loading; and load charts based on calculated list and trim. The amount of list and trim shall be within the crane manufacturer's requirements.
- 2) Provide a Certificate of Compliance for each crane entering an activity under this contract (see Contracting Officer for a blank certificate). Certificate shall state that the crane and rigging gear meet applicable OSHA regulations (with the Contractor citing which OSHA regulations are applicable, e.g., cranes used in construction, demolition, or maintenance shall comply with 29 CFR 1926 and USACE EM 385-1-1 section 16 and Appendix H. The Certificate of Compliance shall state that the crane operator(s) is qualified and trained in the operation of the crane to be used. Also certify that all of its crane operators working on the DOD activity have been trained in the proper use of all safety devices (e.g., anti-two block devices). Post these certifications on the crane.
- 3) Notify the Contracting Officer 15 days in advance of any cranes entering the activity so that necessary quality assurance spot checks can be coordinated. Contractor's operator shall remain with the crane during the spot check.

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

- 4) Comply with the crane manufacturer's specifications and limitations for erection and operation of cranes and hoists used in support of the work. Perform erection under the supervision of a designated person (as defined in ASME B30.5). Perform all testing in accordance with the manufacturer's recommended procedures.
  - 5) Comply with ASME B30.5 for mobile and locomotive cranes, ASME B30.22 for articulating boom cranes, ASME B30.3 for construction tower cranes, and ASME B30.8 for floating cranes and floating derricks.
  - 6) Under no circumstance make a lift at or above 90% of the crane's rated capacity in any configuration.
  - 7) When operating in the vicinity of overhead transmission lines, operators and riggers shall be alert to this special hazard and shall follow the requirements of USACE EM 385-1-1 section 11 and ASME B30.5 or ASME B30.22 as applicable.
  - 8) Use cribbing when performing lifts on outriggers.
  - 9) Position the crane hook/block directly over the load. Side loading of the crane is prohibited.
  - 10) Certification records which include the date of inspection, signature of the person performing the inspection, and the serial number or other identifier of the crane that was inspected shall be available for review by Contracting Officer personnel.
  - 11) Written reports listing the load test procedures used along with any repairs or alterations performed on the crane shall be available for review by Contracting Officer personnel.
  - 12) Certify that all crane operators have been trained in proper use of all safety devices (e.g. anti-two block devices).
  - 13) Take steps to ensure that wind speed does not contribute to loss of control of the load during lifting operations. Prior to conducting lifting operations, set a maximum wind speed at which a crane can be safely operated based on the equipment being used, the load being lifted, experience of operators and riggers, and hazards on the work site. Include this maximum wind speed determination in the activity hazard analysis plan for that operation.
- m. Utility Locations and Verification Prior to Excavation: Obtain appropriate digging permit from Base personnel through Contracting Officer prior to digging. All underground utilities in the work area must be positively identified by a private utility locating service in addition to any station locating service and coordinated with the station utility department. Maintain all markings during utility investigation throughout the contract. Locate utilities in accordance with Paragraph 17 and Attachment A.

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

- Physically verify underground utility locations by hand digging using wood or fiberglass handled tools when any adjacent construction work is expected to come within three feet of the underground system. Use hand digging within 0.61 m (2 feet) of a known utility. If construction is parallel to an existing utility, expose the utility by hand digging every 30.5 m (100 feet) if parallel within 1.5 m (5 feet) of the excavation.
- n. **Utilities Within Concrete Slabs:** Utilities located within concrete slabs are extremely difficult to identify due to the reinforcing steel used in the construction of these structures. Whenever work involves concrete chipping, saw cutting, or core drilling, the existing utility location must be coordinated with station utility departments in addition to a private locating service. Outages to isolate utility systems shall be used in circumstances where utilities are unable to be positively identified. The use of historical drawings does not alleviate the contractor from meeting this requirement.
  - o. **Conduct of Electrical Work:** Follow electrical safety criteria specified in UFC 3-560-01, USACE EM 385-1-1, and NFPA 70E during the conduct of all work.
  - p. **Work in Confined Spaces:** In addition to the requirements of Section 06.I of USACE EM 385-1-1, OSHA 29 CFR 1910.146 and OSHA 29 CFR 1926.21(b)(6), comply with the following paragraphs. Any potential for a hazard in the confined space requires a permit system to be used.
    - 1) **Confined Space Signage:** Provide permanent signs integral to or securely attached to access covers for permit-required confined spaces provided by this contract. Signs wording: "DANGER--PERMIT-REQUIRED CONFINED SPACE - DO NOT ENTER -" in bold letters a minimum of 25 mm (one inch) in height and constructed to be clearly legible with all paint removed. The signal word "DANGER" shall be red and readable from 1.52 m (5 feet).
    - 2) **Entry Procedures.** Prohibit entry into a confined space by personnel for any purpose, including hot work, until the qualified person has conducted appropriate tests to ensure the confined or enclosed space is safe for the work intended and all potential hazards are controlled or eliminated and documented. (See Section 06.I.06 of USACE EM 385-1-1 for entry procedures.) Review all hazards pertaining to the space with each employee during AHA process.
    - 3) **Forced air ventilation** is required for all confined space entry operations. Maintain minimum air exchange requirements to ensure exposure to any hazardous atmosphere is kept below its' action level.
    - 4) **Sewer wet wells** require continuous atmosphere monitoring with audible alarm for toxic gas detection.
  - q. **Ergonomics Considerations During Design:** Design facilities, processes, job tasks, tools and materials to reduce or eliminate work-related musculoskeletal (WMSD) injuries and risk factors in the workplace. Design maintenance access to reduce WMSD risk factors to the lowest level possible. In addition to requirements included in this contract, design shall incorporate the requirements of MIL-STD-1472F.

-- End of Section --

## Small Project Part 2, Attachment A Project-Specific General Requirements

10/14

The following requirements are project specific and may either supplement and/or modify those requirements contained in the body of Part 2, General Requirements. Paragraph numbers in Part 2 correspond to paragraph numbers used in Part 2, Attachment A.

### Paragraph 3 POST AWARD KICKOFF MEETING (PAK)

The PAK meeting shall be held in the Facilities Engineering & Acquisition Division (FEAD) conference room, Bay E/27, in Building 305 and shall include a site visit to the project location. The following individuals should be present: from the contractor's side – DOR, QC Manager, Superintendent, Site Safety & Health Officer; from the Navy side – Tenant Activity Representative, Project Manager, Engineering Technicians conducting QA, Security, Fire, Environmental and Safety Representatives. This will be the primary meeting for planning the entire project from design through mobilization, construction and close-out. An abbreviated Pre-Construction meeting will also be held just prior to mobilization to deal primarily with actual construction start-up, scheduling with the tenant activity and setting up traffic and pedestrian controls.

### Paragraph 4 DESIGN

The DOR shall resolve any and all design questions, procedures and options during the design process. It is the intention of this RFP to have the DOR, construction contractor and Navy work closely together and to have as many on site meetings as necessary to produce a final design package. The design package for review, in the opinion of the DOR, should actually be the finished product. Design drawings shall be submitted with details and data to demonstrate compliance with contract requirements. The DOR shall provide a title sheet, plan sheets with notes, demolition plans, existing/new elevations, new details and notes to accomplish the required work items. All plan sheets will be assigned NAVFAC and PWD sheet numbers by the Navy to be placed in the title blocks by the DOR. The Navy will provide an AutoCAD drawing of the standard plan sheet with title blocks. **See AutoCAD drawing "NAVFAC 24" x 36" in Part 6.**

The DOR shall submit four (4) full size paper sets of development plans and an electronic copy for progress review and a proposed design/construction schedule (but not tied to a specific start date). Also submit three (3) complete sets of manufacturer's data information including: calculations to verify the attachment system of the insulated panels will meet the wind resistance requirements, color samples of the insulated metal wall panels, hollow metal door frames, insulated metal doors, door hardware, building identification signs along with any other design calculations. On-board progress meetings between the DOR, construction contractor and the government will be conducted to review the government comments a minimum of two (2) weeks after the progress review package submission. The progress review design packages will be delivered to the Navy Project Manager in Building 305, Naval Support Activity, 5450 Carlisle Pike, Mechanicsburg, PA 17055.

Submit design drawings, calculation and manufacturer's data to demonstrate compliance with contract requirements.

Provide hard and electronic copies of design submittal package to the following reviewers 2 weeks prior to the progress review meeting.

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

Deliverable	FEAD/ ROICC	IPT	PWO	User
Design Development (Pre-Final, 70%)				
Full-Size Drawings (Paper)	4			
Manufacturer's Cut Sheets	3			
Design/Construction Schedule	4			
Calculations	3			
Final Design for Review, 100%				
Full-Size Drawings (Paper)	4			
Manufacturer's Cut Sheets (Only if they have changed)	3			
Design/Construction Schedule - Final	4			
Calculations (Only if they have changed)	3			

1. After the Final Design Review the contractor shall make necessary changes and prepare final bid documents. The DOR shall provide the final plans and one CD containing the final drawings in AutoCAD (compatible with AutoCAD 2010), and in .pdf format. **See government supplied Specification Section 01 33 10.05.20, "Design Submittal Procedures" in Part 6.** The final design submittal (CAD & pdf) must be professionally signed and sealed by the DOR and forwarded to the Contracting Officer prior to the start of construction. Provide four sets of full size plans on paper and one set of full size plans on mylar.

2. Construction submittals are to be Contractor-approved, except those listed below:

a. Government Approval required for:

1. Aluminum sheet metal gauges and colors.
2. All components of doors, frames and hardware for personnel doors.
3. Overhead coiling doors.
4. Overhead door security screens.
5. All components of the insulated metal wall panel system.
6. Building Identification Signs.
7. Paint colors and finish material colors.

**Replace Siding – Bldg 405  
 Naval Support Activity, Mechanicsburg, Pennsylvania  
 Work Order Number 1350926**

**Paragraph 6 QUALITY CONTROL**

The Superintendent may **NOT** serve as the Quality Control Manager on this project.

The Superintendent or the Quality Control Manager may serve as the Site Safety and Health Officer. **See government supplied Specification Section 01 45 00.00 10, “Quality Control” in Part 6.**

**Paragraph 7 SUBMITTAL PROCESSING**

	<b>SUBMITTAL/BENCHMARK</b>	<b>DURATION</b>	<b>BENCHMARK</b>	<b>RECEIVED</b>	<b>STATUS</b>
1	Quality Control Plan				
2	Material Safety Data Sheets				
3	Design/Construction Schedule				
4	Waste Management Plan				
5	Safety and Health Plan				
6	Schedule of Prices				
7	Record Drawings				
8	Operation and Maintenance Information				
9	Licenses and Permits				
10	Statement of Acknowledgement SF 1413				
11	Design Development Docs				
12	Final Design Docs				
13	Performance/Payment Bonds				
14	Environmental Protection Plan				
15	Certificates of Insurance				
16	DD Form 1354				

**Paragraph 9 SCHEDULE**

**See government supplied Specification Section 01 32 16.05 20, “Design and Construction Progress Documentation” in Part 6.**

**Paragraph 14 SCHEDULE OF PRICES**

The Base Bid, Lump Sum Price, shall include the total price for providing all work associated with completing the removal and replacement of 960 square feet of deteriorated wood siding uncovered on the building walls and replacing it with ¾ inch thick CDX plywood sheathing and 100 board feet of miscellaneous wood framing material, number 2 or better for any deteriorated framing in the proposal.

**Replace Siding – Bldg 405  
Naval Support Activity, Mechanicsburg, Pennsylvania  
Work Order Number 1350926**

**Paragraph 15 CONTRACTOR INVOICES**

INVOICING PROCEDURES ELECTRONIC – See the following Contract Clause in Part 1:

252.232-7006 WIDE AREA WORKFLOW PAYMENT INSTRUCTIONS (MAY 2013)

**Paragraph 18 LICENSES/PERMITS**

No work at the Naval Support Activity base can occur until a Work Permit is issued. The Work Permit process includes review of the project drawings and specifications by various base organizations including Engineering, Fire, Safety, Environmental, Utilities and Security departments. The DOR shall provide two sets of full size drawings and other pertinent information and allow three weeks for review. These two sets are part of the four set submission for Progress Review.

**Paragraph 19 CONTRACTOR WORK SITE**

The contractor shall coordinate any work inside the building with the tenant activity and the contracting officer. Any openings in the building envelope shall be closed with a minimum of wood/metal studs and ¾ inch plywood secured to the existing building wall at the end of each work day.

**Paragraph 21 ENVIRONMENTAL CONTROLS AND PROTECTION**

The Contractor is required to complete and submit evidence of completion of the Environmental Compliance Assessment Training and Tracking (ECATTS) program. **For more detailed information on ECATTS see government supplied Specification Section 01 57 19.00 20, “Temporary Environmental Controls” in Part 6.**

The DOR must ensure state and local regulations are met within the edited Section 01 57 19.00 20, “Temporary Environmental Controls”. The DOR must ensure state and local regulations are met within the edited UFGS section.

The DOR is required to edit and submit UFGS 02 82 16.00 20, Engineering Control of Asbestos Containing Materials. The DOR must ensure the requirements of ASHARA, state and local regulations are met within the edited UFGS section.

Submit evidence of DOR qualifications as an EPA and Pennsylvania state accredited Asbestos Project Designer.

All hazardous waste must be properly manifested by the contractor. Manifests will be reviewed and signed by the base Environmental Officer “PRIOR” to removal of waste. A 24 hour advance notice will be required to ensure timely review/signature. Contact 717.605.2179 for coordination of manifests.

Completed and signed manifest from the receiving TSDF (Transfer/Storage/Treatment/Disposal) facility must be received within 45 days by the Environmental office.

Report all spills by calling 911 and notify the Base Fire Department and the Contracting Officer. If the contractor’s response is inadequate, the Navy may respond. If this should occur, the contractor will be required to reimburse the government for spill response assistance and analysis.

**Replace Siding – Bldg 405  
Naval Support Activity, Mechanicsburg, Pennsylvania  
Work Order Number 1350926**

The contractor is responsible for verbal and written notifications as required by the federal 40 CFR 355, State, local regulation and Navy instructions. Spill response will be in accordance with 40 CFR 300 and applicable State and local regulations. Contain, clean up and dispose of spill materials without cost to the government. If base materials are expended in the process of assisting in spill clean-up, the contractor will be responsible to reimburse in kind materials to the government.

The DOR is required to edit UFGS 02 83 13.00 20, Lead in Construction.

Submit evidence of DOR qualifications as an EPA and Pennsylvania state accredited Lead Project Designer.

**Paragraph 23 RECORD DRAWINGS AND OPERATION & MAINTENANCE (O&M) DATA**

Provide the Contracting Officer with four copies of full size as-built drawings, one copy of full size mylar as-built drawings (24" x 36", 4 mil doubled matted) and two CDs containing drawings (in both pdf and AutoCAD format compatible with version 2010), and all construction submittals.

**Paragraph 24 WARRANTY**

Provide the insulated metal panel manufacturer's standard 20 year warranty for the finish system on the panels and any other warranty information on items that carries a warranty longer than the standard one year warranty at no additional cost.

**Paragraph 26 WORK HOURS, ACCESS AND PASSES**

See government provided edited Specification Section 01 14 00, "Work Restrictions" in Part 6.

**Paragraph 34 SAFETY AND OCCUPATIONAL HEALTH**

See government provided edited Specification Section 01 35 26, "Government Safety Requirements" in Part 6.

**Sub-Paragraph c & I., Weight Handling Equipment**

See government provided edited Specification Section 01 35 26, "Government Safety Requirements" and "ALMECH INSTRUCTION 11450.1" in Part 6.

*\*\*End of PART 2 Attachment A\*\**

## Small Project Part 3 Statement of Work / Project Program

11/14

### Table of Contents

**CHAPTERS**

<b>1. PROJECT DESCRIPTION.....</b>	<b>2</b>
<b>2. PROJECT OBJECTIVES.....</b>	<b>9</b>
<b>3. SITE ANALYSIS.....</b>	<b>9</b>
<b>4. BUILDING REQUIREMENTS.....</b>	<b>9</b>
<b>5. ROOM REQUIREMENTS.....</b>	<b>Not Used</b>
<b>6. ENGINEERING SYSTEMS REQUIREMENTS</b>	<b>10</b>

A10	Foundations	Not Used
A20	Basement Construction	Not Used
B10	Superstructure	Not Used
B20	Exterior Closure	10
B30	Roofing	Not Used
C10	Interior Construction	12
C20	Stairs	Not Used
C30	Interior Finishes	Not Used
D10	Conveying Systems	Not Used
D20	Plumbing	Not Used
D30	HVAC	Not Used
D40	Fire Protection Systems	Not Used
D50	Electrical Power and Lighting	14
E10	Equipment	Not Used
E20	Furnishings	Not Used
F10	Special Construction	Not Used
F20	Selective Building Demolition	15
G10	Site Preparations	16
G20	Site Improvements	Not Used
G30	Site Mechanical Utilities	Not Used
G40	Site Electrical Utilities	Not Used

**1. PROJECT DESCRIPTION:**

Part 3 contains the project description, functional and performance requirements, scope items, and expected quality levels that exceed Part 4. Part 4 identifies design criteria, verification requirements, and performance and quality requirements of products. See “Order of Precedence” paragraph in Part 2 for relationships between all parts of this RFP.

The project requires the exterior renovations of Building 405. The existing building is a wood structure, approximately 202’ by 602’, with 4’-3” high brick foundation walls with concrete sill, and the remainder of the perimeter walls covered with cement asbestos board sheathing and/or exterior insulation and finish system which is placed over the original steel sash windows to an approximate height of 15 feet above ground level on the east and west sides of the building and an approximate varying height of 15 feet to 17 feet on the north and south ends of the building. The existing roof overhang is approximately 4 feet wide on the east and west sides of the building.

**Replace Roof – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

The building is divided into a 20' X 20' grid or bays for reference purposes. The bays are labeled in the East-West direction from A to K (there is no letter I) beginning at the North-West corner, and in the North-South direction from 1 to 30 beginning at the North-West corner.

There is one (1) monitor (clearstory) on the roof at the North end of the building. The monitor is 20' wide X 120' long and about 8'high. There are steel sash windows on the North & South sides. The exterior of this monitor has been covered with EIFS in 2011 when the roofing system was replaced. The monitor is not part of this contract.

Additionally, there may be lead base paint on various items on the exterior walls that include but not limited to wood trim around cement asbestos board sheathing, wood trim/framing around existing personnel and overhead doors, existing metal sash windows behind the exterior insulation and finish system, wood panel overhead doors and any other painted items on the exterior of the building and shall be handled and/or disposed of properly. It shall be the contractor's responsibility to identify and remove all existing cement asbestos board sheathing and any other asbestos containing items and all lead based painted items in accordance with all state and federal regulations.

Any deteriorated wood sheathing located behind the removed existing cement asbestos board siding shall be replaced with new  $\frac{3}{4}$ " CDX plywood. The contractor shall include 960 square feet of new  $\frac{3}{4}$ " CDX plywood for wall repairs and 100 board feet of miscellaneous wood framing material, number 2 or better for any deteriorated framing in the proposal.

The exterior walls of the building shall be covered with new insulated metal wall panels (2  $\frac{1}{2}$ " thickness) to match existing wall panels used on previously renovated building structures on the installation (**see Specification Section 07 42 63, Fabricated Wall Panel Assemblies in Part 6**), after removal of existing cement asbestos board sheathing and exterior insulation and finish system. 30# felt paper shall be installed over existing/new wall surfaces after removal of the existing exterior wall coverings and prior to installation of the new insulated metal panels; as an option, the contractor may use a flash spun high-density polyethylene synthetic material in lieu of the felt paper. The purpose of the felt paper/synthetic material is to provide protection to the building from water between the time the existing wall materials are removed and the installation of the new insulated metal wall panels. Installation of the new insulated wall panels shall set on the existing concrete sill, which shall be covered with metal flashing, of the brick foundation wall and extend to the underside of the existing overhang outlookers or to the roof parapet coping on the north and south ends. New metal insulated wall panels shall be attached to metal hat channels attached to the existing building wall and metal sash windows. Provide all insulated wall panel accessories and metal trim at sills, corners, edges and joints as required by the insulated wall panel manufacturer. Provide 3 inch rigid insulation above the new insulated metal wall panels to the underside of the existing roof deck between the existing overhang outlookers attached to the existing building wall. New aluminum trim at the concrete sill shall match the existing building roof trim color. Provide new aluminum coping on the parapet walls to match the existing aluminum gage and color. Install wood or metal framing below the overhangs on the East & West sides to provide space to accommodate the conduits and junction boxes attached to the underside of the overhangs. Provide new aluminum soffits at roof overhangs. The soffit shall extend from the new fascia to a new edge trim piece attached through the new insulated metal wall panels into the wood sheathing. Access panels shall be installed in the soffit at each junction box and other locations as required. Soffit color shall match the existing building trim color.

Provide new 8' X 8' building identification signs (6 total) mounted on the building corners. Signs shall be constructed of an aluminum composite panel to match the configuration of the existing building identification signs. There will be no building signs on the North elevation. Sign verbiage shall be as follows:

South Elevation – 5<sup>th</sup> Ave/405  
East Elevation – F St/405  
West Elevation – E St/405

**Replace Roof – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

Various informational signs located on the exterior building walls shall be replaced with new signs of similar size and verbiage as indicated. Signs shall be constructed of an aluminum composite panel. Signs are as follows:

All new overhead doors shall have a bay location sign mounted above the door. These signs shall be similar to the existing sign at Bay A-19, use white signs with black lettering.

Replace the sign at Bay A-20 with a new sign of the same size and lettering.

**See Part 6 for sample sign details and information.**

**See Part 6 for additional building information which includes miscellaneous civil drawings (.tif files), miscellaneous drawings for previous energy conservation (EIFS installation) and AutoCAD drawings for Building 209 which is a similar project for installation of insulated metal wall panels.**

Other items of work shall include:

There are four personnel doors that shall be replaced. They are at the following locations:

Bay A-1 North: double flush door

Bay A-1 North: single flush door

Bay A-29: single metal door with ½ glass

Bay A-2: double metal door with louvers

A new personnel door shall be cut into the wall and installed at Bay A-22. This will be an exit door only but shall have a door pull (handle) on the exterior but no locks.

Provide new insulated hollow metal frames and doors to match the features of the existing doors at the above locations. Doors and frames shall be 16 gauge, extra heavy duty, Level 3, physical performance Level A, model 2. The window in the door with ½ glass at Bay A-29 shall be (tempered and opaque); double door at Bay A-2 is for an existing electrical room so the door and frame are not required to be insulated. All exterior doors shall be provided with heavy duty hinges (brass base or stainless), closers, weather stripping, thresholds, mortise exit devices (with entrance by lever with keyed cylinder; 7 pin tumblers compatible with Best Locks), (Push button lock on door A-29 shall be reinstalled), astragals (as required) and kick plates (aluminum). Doors shall be painted on the interior and exterior sides of the door and frame. All door hardware shall be Grade 1. Provide two coats of paint on all new hollow metal frames and doors; color to match the existing building trim color. Provide miscellaneous wood trim on the interior of new frames to provide a finished installation. Do not use wood trim on the exterior unless it is wrapped in aluminum.

Remove all existing wood panel overhead doors, coiling doors, tracks and motor operators. These doors will either be replaced with new overhead panel doors, new coiling doors or the openings will be closed in. Overhead door openings to be closed shall receive brick (in line with and matching the existing brick wall and 8" concrete masonry unit backup to the height of the existing wall. Install wood or metal framing (2 x 4 and ¾" CDX plywood with R-19 insulation to close in the upper portion of the door opening. Then install insulated metal panels over the exterior in line with the adjacent wall panels. The existing metal angle guards on the existing brick jambs shall be removed. Overhead doors to be closed in are located at bays K-7, K-10, K-14, K-17, K-21, K-24, K-28, A-28, A-26, A21, A-14, A-12 and A-7.

Some old wood panel doors (Bays K-5, K-12, K-19 and K-26) are to be replaced with new coiling doors they shall be as follows. They shall be insulated metal coiling doors mounted on the interior of the building, shall match the door opening size and be similar to Overhead Door Corporation Model 627. There is an asbestos heat duct mounted on the interior wall just above the existing overhead doors. This makes it impossible to install the coiling door at the proper height to permit a full opening height. Build a header at the top of the door opening to support the new coiling door. The door itself shall still be sized for the full height so that when the heat duct is removed in the future, the header can be removed and the

**Replace Roof – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

door can be remounted at its proper height. The new overhead coiling doors shall have a factory powder coated paint system, including the frame and coil hood, with the color matching the existing building trim color. The door shall be provided with an electrical door operator with controls mounted on the interior of the building only.

Some old wood panel doors (Bays A-5, A-10, A-19, A-24, C-30 and H-30) are to be replaced with new insulated metal panel doors matching the existing door size. These doors shall have vision windows, motor operators with controls mounted on the interior only. The new overhead panel doors shall have a factory powder coated paint system with the color matching the existing building trim color.

Provide coiling security grilles at new overhead doors, both panel doors and coiling doors, similar to Overhead Door Corporation Model 676. No security grilles shall be provided for the 11 overhead doors at the north end of the building. Coiling security grilles shall be mounted on the exterior of the building. Steel frame, brackets and hood shall have a factory powder coated finish to match the existing building trim color. The coiling security grilles shall be provided with a motor operator with controls mounted on the interior of the building only.

The white metal panel overhead doors at the north end of the building shall be replaced; Bays A-3, B-1, C-1, D-1, E-1, F-1, G-1, H-1, J-1, K-1 and K-3. These existing doors are explosion proof and have wicket doors. The new doors shall be insulated metal coiling doors similar to the coiling doors described above. They shall not be explosion proof or have wicket doors. The controls shall be mounted on the exterior and secured similar to the way they are now. They shall also be factory powder coated in the trim color. No coiling grilles are required on these doors.

Replace and repoint any damaged brick at existing door jambs, overhead door jambs and/or wall areas. The brick repair is minimal. All brick walls shall be pressure washed.

The roofing system was completely replaced in 2011 with an insulated EPDM roofing system. Parapet walls were constructed around the perimeter of the roof and covered with aluminum coping and aluminum flashing. The fascia on the West & East sides was covered with EIFS. It is the intension to replace the coping in kind and removed the aluminum flashing and EIFS fascia. The fascia shall be replaced with the same insulated metal panels that will be used to cover the exterior walls. The Firestone EPDM 20 year roofing system warranty must be maintained. Any roofing repairs or flashing must be done by a contractor certified by Firestone. There are seven (7) street lights attached to the edge of the roof that were replaced during the roofing project. These street lights shall remain and shall be detached and reattached after the metal siding is installed. There are new painted 4" Schedule 40 PVC downspouts that run from the roof drains through the roof overhangs down to a cast iron pipe at grade. These downspouts shall be repainted and reused. The downspouts shall be modified at the top and bottom, at the top they must be extended down from the roof drains to clear the new metal soffits and at the bottom a cleanout shall be installed where the downspout goes into the cast iron pipe. The cast iron pipe receivers at grade are about 3' high and they shall be cleaned and repainted. **The construction plans for the recent roofing project, in CAD and in pdf files, will be attached in Part 6 for information.**

All existing metal angle iron guards at existing overhead doors that are to be replaced shall be replaced if necessary and/or cleaned and painted to match the existing building trim color.

Any demolition or removal that opens the building envelope is required to be secured at the end of each work day. Temporary closure shall consist of wood or metal studs covered with ¾" plywood and secured to the existing building structure.

There are four sprinkler drain lines and three sprinkler test ports that shall be modified. The sprinkler drain lines extend through the exterior wall at about 4'6" above grade. These are located at Bays K-5, K-12, k-19 and K-26. The sprinkler test ports extend through the exterior wall at about 13' above grade. These are located at Bays K-15, K-17 and K-30 south elevation. All of these lines shall be re-plumbed

**Replace Roof – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

with metal pipe sown the interior wall and extended through the brick foundation wall to the exterior at 2' above grade. Install a ball valve on each line.

Disconnect and remove the wall mounted exterior lighting and emergency lighting remote heads at personnel doors listed below and replace with new full cut-off LED wall packs and emergency lighting remote heads at all the locations listed below:

<u>Bay</u>	<u>New Light</u>
A-29	Wall Pack & Emergency Light
A-20	Wall Pack & Emergency Light

The remaining locations are exit doors. They currently have an emergency light that shall be replaced with a new full cut-off LED emergency light: Bays K-4, K-13, K20, K27, A-27, A-13, A-4 and A-2. At bay A-1 North there are two doors, a single door and a double door. Install an emergency light at the single door only. Also, install a new emergency light at the new exit door at Bay A-22. This location will require wiring from a panel box or acceptable power source. A motor operated louver is being removed at this location and perhaps the power for the louver could be used for the emergency light?

Concrete aprons shall be constructed from the building to the street at the following overhead door locations: A-5, A-10, A-24 and C-30 south elevation. The sidewalk area shall be rebuilt with new concrete walk and curb at the following bay locations: A-7, A-21 and A-28. The concrete sidewalk shall be at least 5" thick with wire mesh and the new curb shall match the adjacent curbs. Timber ramps with diamond plate were built inside the building at the following locations: A-7, A-10, A-21, A-24, and A-28. These ramps shall be disassembled and removed.

**ADDITIONAL INFORMATION:**

Additional detail information regarding the scope of work for the North, East, South & West Elevations will be presented in the following sections.

**NORTH ELEVATION:**

The exterior wall on the North elevation of Bldg 405 is constructed of concrete block from ground level to a height of about 13' and is painted. The block wall shall be cleaned and repainted to match the new insulated metal wall panels. The wall above the CMU is still covered with asbestos board (transite) to the roof edge. The roof edge is covered with new aluminum coping and below that is a new aluminum flashing piece. The metal flashing and the transite shall be removed and replaced with insulated metal panels and the coping shall be replaced with new aluminum coping matching the existing building trim color.

There are numerous conduits attached to the wall that shall be cleaned and painted if they are attached to the surface of the CMU wall. There are numerous conduits running the length of the north elevation attached to the asbestos transite. These conduits shall be moved or replaced behind the new insulated metal panels or perhaps inside the building. There are three fire alarm pull boxes, a fire alarm gong, red warning light and a warning bell that shall remain. There is a flush double metal door and a flush single metal door located at Bay A-1 that shall both be replaced. There is a 4" diameter vent pipe located at Bay A-1 that runs from ground level to above the roof edge that shall be cleaned and painted.

**Replace Roof – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

There are nine (9) white metal panel overhead doors, each with a wicket door, along the north elevation. There are door controls mounted on the wall at each overhead door. These doors shall be replaced with insulated coiling doors without wicket doors. There are no 8'X8' building identification signs on the north elevation. All new overhead doors shall have a bay location sign mounted above the door. These signs shall be similar to the existing sign at Bay A-19, use white signs with black lettering.

**EAST ELEVATION:**

The exterior wall at Bays K-1, K-2 & K-3 is constructed of concrete block from ground level to a height of about 13' and is painted. The block wall shall be cleaned and repainted to match the new insulated metal wall panels. The top of the block wall is located at the top of the existing steel sash windows. The wall above the block is still covered with transite up to the underside of the overhang. The transite shall be removed and the area covered with insulated metal panels.

Bay K-2: There is a fire alarm pull box and conduit that shall remain. The conduit shall be cleaned and painted.

Bay K-3: There is a white metal panel overhead door with a wicket door that shall be replaced as previously described. There are door controls mounted on the wall that shall remain.

Bay K-4: There is a new flush metal exit door with light mounted at the top of the door. The door and frame shall be repainted. A radon vent pipe extends through the wall and extends to above the roof edge that shall be detached and reattached after siding replacement.

Bay K-5: There is a 14' wide X 12' high wood panel overhead door with motor operator. There is a fire sprinkler drain pipe extending through the wall at about 4 ½' above grade.

Bay K-6: There is a new 4' X 8' wall mounted louver that shall remain. See the 2011 roofing plans for details.

Bay K-7: There is a 14' wide X 12' high wood panel overhead door with motor operator.

Bay K-8: There is a new 4' X 8' wall mounted louver that shall remain. There is also a new street light and 12' safety that shall be removed and reinstalled after the siding is replaced on the fascia. See the 2011 roofing plans for details.

Bay K-10: There is a 14' wide X 12' high wood panel overhead door with motor operator.

Bay K-11: There is a new 4' X 8' wall mounted louver that shall remain. See the 2011 roofing plans for details.

Bay K-12: There is a 14' wide X 12' high wood panel overhead door with motor operator and metal scissors gate. All existing scissors gates shall be removed. There is a fire sprinkler drain pipe extending through the wall at about 4 ½' above grade.

**Replace Roof – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

Bay K-13: There is a new flush metal exit door with light mounted at the top of the door. The door and frame shall be repainted.

Bay K-14: There is a 14' wide X 12' high wood panel overhead door with motor operator. The door has a wood frame and canvas shroud attached to the wall around the door constructed for weather protection when trucks were being loaded and unloaded. This wood frame and shroud shall be removed.

Bay K-15: There is a metal oil filler box located on the sidewalk close to the wall that shall remain and shall be repainted. There is a fire sprinkler test pipe extending through the wall located at about 13' above grade. There is a brick fire wall about 30" running from grade to above the roof edge and 12' safety railing that shall be removed and reinstalled after the siding is replaced on the fascia. Brick fire walls shall not be covered with insulated metal panels.

Bay K-16: This is the boiler room for Bldg 405. The exterior wall is constructed of brick to the top of the steel sash windows. The brick wall shall not be covered with insulated metal panels. There is a boiler signal light, red indicator light attached to the overhang, a police call box and a fire alarm box. The police call box shall be removed.

Bay K-17: There is a blue indicator light attached to the overhang and a sprinkler test pipe extending through the wall located above the steel sash window at a height of about 13'. There is a 14' wide X 12' high wood panel overhead door with motor operator and metal scissors gate.

Bay K-18: There is a new 4' X 8' wall mounted louver that shall remain. There is a new aluminum building ladder with safety cage and security door attached to the building wall and extending through the roof overhang. The ladder shall be removed, modified as necessary to provide the proper stand-off distance and remounted to the building after the siding is replaced. There is 12' of safety railing attached to the roof edge at the building ladder. The safety railing shall remain or be reinstalled after the siding installation. See the 2011 roofing plans for details of the louver, building ladder and safety railing. There is a roofing system information plaque attached to the wall near the top of the ladder that shall remain.

Bay K-19: There is a 14' wide X 12' high wood panel overhead door with motor operator and metal scissors gate. There is a fire sprinkler drain pipe extending through the wall at about 4 ½' above grade.

Bay K-20: There is a new flush metal exit door with light mounted at the top of the door. The door and frame shall be repainted.

Bay K-21: There is a 14' wide X 12' high wood panel overhead door with motor operator and metal scissors gate. The door has a wood frame enclosure attached to the wall around the door constructed for weather protection when trucks were being loaded and unloaded. The wood frame shall be removed.

Bay K-22: There is a new 5' X 8' wall mounted louver that shall remain. There is also a new street light and 12' safety railing that shall be removed and reinstalled after the siding is replaced on the fascia. There is a brick fire wall about 30" wide at this location. See the 2011 roofing plans for details.

Bay K-23: There is a new 5' X 8' wall mounted louver that shall remain. See the 2011 roofing plans for details.

**Replace Roof – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

Bay K-24: There is a 14' wide X 12' high wood panel overhead door with motor operator and metal scissors gate.

Bay K-26: There is a 14' wide X 12' high wood panel overhead door with motor operator and metal scissors gate. There is a fire sprinkler drain pipe extending through the wall at about 4 ½' above grade.

Bay K-27: There is a new flush metal exit door with light mounted at the top of the door. The door and frame shall be repainted.

Bay K-28: There is a white metal panel overhead door with motor operator and metal scissors gate. There is also a wind screen made of strips of heavy plastic. The wind screen shall be removed. There is a fire sprinkler drain pipe extending through the wall at about 4 ½' above grade.

Bay K-29: there is a 2' X 2' metal louver with expanded metal screen located at the middle of the steel sash window that shall be removed and the opening closed.

Bay K-30: There is a new 4' X 8' wall mounted louver that shall remain. There is a door control mounted to the wall that shall be removed.

**SOUTH ELEVATION:**

Bay K-30: there is a sprinkler pipe extending through the wall located above the steel sash window at a height of about 13'.

Bay H-30: There is a white metal panel overhead door with motor operator and metal scissors gate. There are door controls located on both sides of the overhead door. There is a shoe-box style light mounted on a steel pole and attached to wall. This light shall be replaced with an LED street light matching the street lights on the building.

Bay E-30: there is a street light attached to the wall that shall be removed and reattached after the siding is replaced.

Bay C-30: There is a white metal panel overhead door with motor operator. The door area is partially closed in with wood framing and plywood. There are 4" X 4" steel angle iron corner guards installed at the edge of the brick foundation wall on both sides of the overhead door. These corner guards shall be replaced. There is a shoe-box style light mounted on a steel pole and attached to wall. This light shall be replaced with an LED street light matching the street lights on the building.

Bay A-30: There is a window AC unit extending through the wall and an aluminum hopper style window. The window shall be replaced with a bronze anodized hopper style window. The window AC unit shall be eliminated and the opening closed.

**WEST ELEVATION:**

Bay A-30: There is a hopper style aluminum window with a window AC unit mounted through the wall above the aluminum window. The window shall be replaced. The window AC unit shall be removed and

**Replace Roof – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

the opening closed. There is a new street light attached to the roof edge that shall be removed and reinstalled after the siding is replaced on the fascia.

Bay A-29: There is a metal personnel door with ½ glass, wood trim and push button lock. The door and frame shall be replaced. The lock shall be reused. There are two lights located above the door. There is an 18" diameter exhaust fan mounted through the wall that shall remain.

Bay A-28: There is a 14' wide X 12' high wood panel overhead door with motor operator. The door has a wood frame and canvas shroud attached to the wall around the door constructed for weather protection when trucks were being loaded and unloaded. The lower part of the door opening has been filled in with timber construction including a dock leveler. The door and all of the in-fill shall be removed and the opening closed.

There are offices in bays A-30 to A-28. Four existing window AC units are to be removed as described above. Replace the air conditioning and or heat with split systems with the outdoor units mounted on the roof.

Bay A-27: There is a new flush metal exit door with light mounted at the top of the door. The door and frame shall be repainted. There is a new sprinkler alarm bell mounted on the wall and a new red indicator light attached to the roof overhang that shall remain.

Bay A-26: There is a 14' wide X 12' high wood panel overhead door with motor operator and metal scissors gate. There are several loose wires attached to the wall near the top of the windows that start at this bay and run to Bay A-8. These wires shall be removed.

Bay A-25: There is a new 5' X 8' wall mounted louver that shall remain. See the 2011 roofing plans for details.

Bay A-24: There is a 14' wide X 12' high wood panel overhead door with motor operator. The door has a wood frame and canvas shroud attached to the wall around the door constructed for weather protection when trucks were being loaded and unloaded. The lower part of the door opening has been filled in with timber construction including a dock leveler.

Bay A-22: There is a new 5' X 8' wall mounted louver that shall be removed. The control wire shall be removed back to the thermostat and power wire shall be removed to the electrical panel. There is 12' of safety railing mounted along the roof edge that shall be removed and reinstalled after the siding is replaced on the fascia. There is a brick fire wall about 30" wide at this location. See the 2011 roofing plans for details. There is also an 18" diameter exhaust fan extending through the wall that shall be removed.

Bay A-21: There is a 14' wide X 12' high wood panel overhead door with motor operator.

Bay A-20: There is a metal personnel door with ½ glass, wood trim and push button lock. The door and frame shall be repainted. The lock shall remain and the wood trim shall be covered with aluminum flashing. There are two lights located above the door. There is a red indicator light mounted under the overhang and a new sprinkler alarm bell attached to the wall. The indicator light and gong shall remain or be reused.

**Replace Roof – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

Bay A-19: There is a 14' wide X 12' high wood panel overhead door with motor operator and metal scissors gate.

Bay A-18: There is a hopper style aluminum window and a window AC unit mounted through the wall. The window shall be replaced. The AC unit shall be removed. There is a propane gas tank setting on the sidewalk with a gas line mounted to the exterior wall. Install a split system in the office at this bay to provide air conditioning with the outdoor unit mounted on the roof. There is also a furnace located in this bay. Install modification to the furnace to provide heat for the office.

Bay A-16: There is a new double door with full louvers and wood trim around the door. The door and frame shall be repainted and the wood trim shall be covered with aluminum flashing. There are two 4" electrical conduits and large junction box attached to the wall that shall be repainted. There is 12' of safety railing mounted along the roof edge that shall be removed and reinstalled after the siding is replaced on the fascia. There is a brick fire wall about 30" wide at this location. See the 2011 roofing plans for details.

Bay A-15: There is a new 5' X 8' wall mounted louver that shall remain. There is also an 18" diameter exhaust fan extending through the wall that shall be removed.

Bay A-14: There is a 14' wide X 12' high wood panel overhead door with motor operator and metal scissors gate. The door has a wood frame and canvas shroud attached to the wall around the door constructed for weather protection when trucks were being loaded and unloaded.

Bay A-13: There is a new flush metal exit door with light mounted at the top of the door. There is wood trim around the door that shall be covered with aluminum flashing. The door and frame shall be repainted. There is a new sprinkler alarm bell mounted on the wall and a new red indicator light attached to the roof overhang. The indicator light and alarm bell shall remain or be reused.

Bay A-12: There is a 14' wide X 12' high wood panel overhead door with motor operator and metal scissors gate.

Bay A-10: There is a 14' wide X 12' high wood panel overhead door with motor operator. The door has a wood frame and canvas shroud attached to the wall around the door constructed for weather protection when trucks were being loaded and unloaded. The lower part of the door opening has been filled in with timber construction including a dock leveler.

Bay A-9: There is 12' of safety railing mounted along the roof edge that shall be removed and reinstalled after the siding is replaced on the fascia. There is a brick fire wall about 30" wide at this location. See the 2011 roofing plans for details. There is a new 5' X 8' wall mounted louver that shall remain.

Bay A-8: Just north of the fire wall there are some roof deck boards in the roof overhang that are broken. The EPDM roofing system shall be opened up at this location and the wood deck shall be repaired using 2"X8" lumber. The Firestone roofing system shall be repaired by a contractor certified by Firestone to maintain the 20 year warranty. There is a new 5' X 8' wall mounted louver that shall remain.

**Replace Roof – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

Bay A-7: There is a 14' wide X 12' high wood panel overhead door with motor operator and metal scissors gate.

Bay A-6: There is a new 5' X 8' wall mounted louver that shall remain.

Bay A-5: There is a 14' wide X 12' high wood panel overhead door with motor operator. The door has a wood frame and canvas shroud attached to the wall around the door constructed for weather protection when trucks were being loaded and unloaded. The lower part of the door opening has been filled in with timber construction including a dock leveler.

Bay A-4: There is a new flush metal exit door with light mounted at the top of the door. There is wood trim around the door that shall be covered with aluminum flashing. The door and frame shall be repainted. There is a new sprinkler alarm bell mounted on the wall. There is a 12" X 18" metal louver mounted in the wall near the top of the window that shall be removed and the opening closed.

Bay A-3: There is a white metal panel overhead door with a wicket door. There are door controls and a fire alarm pull box mounted on the wall that shall remain.

Bay A-2: There is a double door with louvers and wood trim around the door. The door and frame shall be replaced. There is a light mounted at the top of the door. There are conduits and a pipe vent mounted on the wall.

The exterior wall at Bays A-1, A-2 & A-3 is constructed of brick from ground level to a height of about 4' and concrete block from the top of the brick to a height of about 13' and is painted. The block wall shall be cleaned and repainted. The top of the block wall is located at the top of the existing steel sash windows that are covered with EIFS. The wall above the block is still covered with transite up to the underside of the overhang. The transite shall be removed and the area covered with insulated metal panels.

Disclaimer: The requirements for this project are very detailed in this scope of work. However, there may still be some changes or revisions made during the design process. These changes shall be considered as part of this contract.

## **2. PROJECT OBJECTIVES**

The project objective is to renovate the existing exterior walls surfaces of Building 405 with new insulated metal wall panels to match previously renovated building structures on the installation. Special attention shall be given to planning and scheduling of the contractor's work; the existing building will remain in operation during construction. The majority of the building is warehouse and is inactive.

### **2.1 APPLICABLE CODES AND STANDARDS:**

In addition to the codes and standards listed in Part 4, the design and construction shall be in accordance with the latest revision/edition of the following referenced codes and standards. The term "Latest Revision/Edition" is defined as the version as of the project award date.

**Replace Roof – Bldg 405  
Naval Support Activity, Mechanicsburg, Pennsylvania  
Work Order Number 1350926**

U.S. Army Corps of Engineers (USACE), EM 385-1. Sept. 2008, Safety and Health Requirements Manual

## **2.2 SUSTAINABLE DESIGN**

In accordance with Executive Order 13423, NAVFAC Engineering & Construction Bulletin (ECB) 2008-01 and other pertinent directives, integrate sustainable principles into the design, development and construction of the project. Reduce the total cost of ownership of the facility using a whole building, life-cycle approach.

Provide integrated sustainable design strategies and features to minimize the energy consumption of the facilities; conserve resources; minimize adverse effects to the environment; and improve occupant productivity, health, and comfort.

Provide narrative describing sustainable goals and completed LEED checklist.

## **3. SITE ANALYSIS**

The existing work area consists of the complete exterior perimeter of Building 405. Additionally, other interior work areas will need to be included for various electrical work as required. All work locations will need to be coordinated with the contracting officer and the building occupants (the existing building will remain in operation during construction). The areas surrounding the building will be available for work vehicles, dumpsters and material storage which will be determined during the PAK meeting. Mechanical and electrical work will require the contractor be in other parts of the building, which is occupied, and will require prior approval before entering.

## **4. BUILDING REQUIREMENTS**

### **4.1 EXTERIOR CHARACTER**

Renovations to the existing exterior walls surfaces of Building 405 with new insulated metal wall panels shall match previously renovated building structures on the installation in color and texture. The specification section contained in Part 6 contains all of the required panel characteristics.

## **5. ROOM REQUIREMENTS**

**Not used.**

## **6. ENGINEERING SYSTEMS REQUIREMENTS (ESR)**

A10 Foundations  
A20 Basement Construction  
B10 Superstructure  
B20 Exterior Closure  
B30 Roofing  
C10 Interior Construction

**Replace Roof – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

C20 Stairs  
C30 Interior Finishes  
D10 Conveying Systems  
D20 Plumbing  
D30 HVAC  
D40 Fire Protection Systems  
D50 Electrical Power and Lighting  
E10 Equipment  
E20 Furnishings  
F10 Special Construction  
F20 Selective Building Demo  
G10 Site Preparations  
G20 Site Improvements  
G30 Site Mechanical Utilities  
G40 Site Electrical Utilities

## **A10 FOUNDATIONS**

Not used.

## **A20 BASEMENT CONSTRUCTION**

Not used.

## **B10 SUPER STRUCTURE**

Not used.

## **B20 EXTERIOR ENCLOSURE**

### **B2010 EXTERIOR WALLS**

The primary exterior material of the building shall be insulated metal wall panels with concealed fasteners. Provide 30# felt paper or a flash spun high-density polyethylene synthetic material on existing/new walls as soon as the existing transite siding is removed. Existing exterior metal sash windows shall remain in place, where exterior insulation and finish system has been removed, and prepared with metal hat sections to accept attachment of the new insulated metal wall panels. New insulated metal wall panels shall match existing insulated wall panels used on previously renovated building on base.

Two overhead doors will be removed and will require closing in of the existing opening with materials to match the existing adjacent wall to include brick masonry for the lower portion of the walls and prefinished insulated metal panels with concealed fasteners set on the existing/new brick foundation walls for the upper portion to match existing renovated structures on the base.

Brick masonry details shall be consistent with the existing adjacent building walls. The existing/new concrete/concrete block sill on the brick masonry foundation walls shall be covered with metal flashing to match existing renovated structures on the base.

Back-up wall system for brick veneer construction shall be 8 inch concrete masonry for the lower portion of the wall infill. Provide vertical metal reinforcement set in the existing concrete foundation

**Replace Roof – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

wall and new 8 inch concrete masonry wall with cores filled solid. The upper portion of the wall infill will consist of 2" x 6" wood/metal studs covered with ¾ inch CDX plywood with horizontal metal hat channels for attachment of new insulated metal wall panels.

**Insulation and Vapor Retarder**

Provide insulation (R-19) in upper portion of new wall infill areas. Provide vapor barrier on all new and existing wall surfaces for protection of surfaces and prior to installation of new insulated metal wall panels.

**Exterior Soffits**

Provide aluminum exterior soffit at the roof overhang; soffit color shall be factory applied to match the building trim color.

**Exterior Coatings**

Provide field applied exterior coatings for all items that are not prefinished, and to prefinished items when required to provide a color other than a standard prefinished color. All paint shall be in accordance with the Master Painter Institute (MPI) standards for the exterior architectural surface being finished.

**Joint Sealants**

Provide exterior application of joint sealants to seal joints and prepare for finish material installation.

**Exterior Signs**

Provide new building identification signs (6 total) mounted on the new insulated metal wall panels on the building corners and other building signs as listed in the project description. Signs shall be constructed of an aluminum composite panel to match existing building identification signs on other building with insulated metal wall panels.

**B2030 EXTERIOR DOORS**

Provide solid door assemblies. Exterior doors and frames shall be non-corroding galvanized steel.

Doors shall be Extra Heavy Duty Doors Level 3, physical performance Level A, Model 2, as specified in the project.

Door hardware finish shall be satin chromium plated brass or bronze or satin stainless steel.

**Solid Doors**

Provide solid steel door assemblies including heavy-duty, non-corroding, insulated doors with frames and hardware. Also provide accessories and wall opening elements such as sills and flashings.

**Glazed Doors**

Glazed Doors - Provide Exterior Glazed Doors including steel framed door assemblies with insulated glazing, frames, and hardware and wall opening elements such as sills, weather stripping and joint sealers.

**Overhead and Roll-up Doors**

Overhead and roll-up doors shall be NAGDM 102 Industrial designation.

Doors shall be insulated rolling coil service type. Doors shall have automatic operation. Doors shall be operated by three-button electric power conforming to NEMA MG 1, NEMA ICS 1, NEMA ICS 2, and NEMA ICS 6 with auxiliary hand chain operation.

**Replace Roof – Bldg 405  
Naval Support Activity, Mechanicsburg, Pennsylvania  
Work Order Number 1350926**

**Gates/Grilles**

Coiling security grilles shall be mounted on the exterior of the building. Steel brackets and hood shall have a factory powder coated finish or be painted to match the existing building trim color. The coiling security grilles shall be provided with an electrical operator with controls mounted on the interior of the building.

Coiling grilles shall have automatic operation. Coiling grilles shall be operated by three-button electric power conforming to NEMA MG 1, NEMA ICS 1, NEMA ICS 2, and NEMA ICS 6 with auxiliary hand chain operation.

**Exterior Door Hardware**

Provide the services of a certified door hardware consultant to prepare the door hardware schedule.

New doors shall be provided with heavy duty full mortise hinges, closers, weather stripping, sills, Series 4000 locksets with interchangeable core (7 pin tumblers compatible with Best Locks), astragals, kick plates and panic hardware. All door hardware shall be Grade 1. Exit devices shall be push pad Type 3 (Mortise Exit Devise), with entrance by lever with keyed cylinder (Key locks or unlocks lever). Double doors shall be provided with lever extension flush bolts.

**B30 ROOFING**

Not used.

**C10 INTERIOR CONSTRUCTION**

Not used.

**C20 STAIRS**

Not used.

**C30 INTERIOR FINISHES**

Not used.

**D10 CONVEYING SYSTEMS**

Not used.

**D20 PLUMBING**

Not used.

**D30 HVAC**

Not used.

## D40 FIRE PROTECTION SYSTEMS

Not used.

## D50 ELECTRICAL

The electrical design shall comply with the design criteria specified in UFC 3-500-10N, *Electrical Engineering*, and its referenced documents.

### D5010 ELECTRICAL SERVICE & DISTRIBUTION

Provide an insulated equipment grounding conductor in all raceways for systems operating at greater than 50 volts.

### D5020 LIGHTING & BRANCH WIRING

Provide lighting consisting of exit and emergency lighting and exterior LED area lighting and automatic controls.

All conductors shall be copper.

## E10 EQUIPMENT

Not used.

## E20 FURNISHINGS

Not used.

## F10 SPECIAL CONSTRUCTION

Not used.

## F20 SELECTIVE BUILDING DEMOLITION

### F2020 HAZARDOUS COMPONENT ABATEMENT

A report for the following: asbestos and lead based painted items is “**NOT**” provided to support this project. It shall be the contractor’s responsibility to identify all asbestos containing materials and lead base painted items prior to start of construction.

Prior to the start of the work the ECATTS trained contractor is required to inspect the work area with the designer of record, and government representative to address existing potentially hazardous components as part of the work. The contractor is required to provide a list of hazardous components, locations and quantities that must be addressed as part of the work.

**Replace Roof – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

Remove and dispose of the following hazardous materials: existing cement asbestos board siding located on exterior walls and lead based painted items. Asbestos removal and removal of lead based painted items shall be in accordance with all Pennsylvania state and federal regulations.

**Private Qualified Person (PQP)**

The Contractor is required to hire a PQP to ensure compliance with the approved work plans and perform independent inspections, testing and verification of the hazardous components work including: asbestos and lead containing paint.

**Asbestos**

Remove and dispose of the following known asbestos-containing materials:

Existing cement asbestos board siding on the exterior walls of the building.

The Contractor may elect to leave Category I & II Non-Friable Asbestos-Containing Materials in place during demolition and dispose of the entire waste contents as Category I & II ACM. If the Contractor elects to follow this method, all procedures, monitoring, waste disposal, and dust control measures shall be addressed within the asbestos work plan. In addition, the Contractor will not be allowed to segregate/salvage waste materials, or compact debris for transport. The Contractor shall also submit certification that the landfill to be used for disposal has been notified and is willing to accept Category I & II ACM.

**Paint Related Work**

The work will require disturbance of paint containing lead. The following is a list of items that have been known to contain lead based paint:

Exterior wood trim around cement asbestos board siding, wood trim at overhead doors, wood overhead doors and metal sash windows behind the exterior insulation and finish system.

**Disposal**

All waste materials shall become the property of the Contractor and shall be transported, disposed of or recycled in accordance with all state and federal regulations.

**Landfill Approval**

Submit written evidence that the landfill is for asbestos disposal by the U.S. Environmental Protection Agency, Region 3, Air Enforcement Section (38W12), and local regulatory agencies. Within 3 working days after delivery, submit detailed delivery tickets, prepared, signed, and dated by an agent of the landfill, certifying the amount of asbestos materials delivered to the landfill. Submit a copy of the waste shipment records within 1 day of the shipment leaving the project site.

- a. The Contractor is responsible for obtaining and preparing appropriate manifests for transport of all asbestos to the authorized disposal facility. The Contractor shall present all asbestos manifests to the Naval Support Activity, Mechanicsburg, NAVFAC MidLant Environment Office, Building 305, for review and signature twenty four (24) hours in advance of removing the asbestos from the installation. **THE NAVFAC ENVIRONMENTAL OFFICE REPRESENTATIVES ARE THE ONLY PERSONNEL AUTHORIZED TO APPROVE OR SIGN AN ASBESTOS MANIFEST.**

**Disposal of Asbestos**

**Replace Roof – Bldg 405  
Naval Support Activity, Mechanicsburg, Pennsylvania  
Work Order Number 1350926**

- a. The Contractor shall submit a certificate of disposal for each load of asbestos removed from the installation, within thirty (30) days following disposal of hazardous waste and provide a letter to the Government certifying date, time, and location where such destruction was accomplished. The Certificate of Destruction shall be forwarded to:

Naval Support Activity  
Facilities Engineering and Acquisition Division  
5450 Carlisle Pike, Building 305  
Mechanicsburg, PA 17055-0788

## **G10 SITE PREPARATION**

### **G1010 SITE CLEARING**

Burning will not be allowed.

All residue, demolished material, rubbish and debris generated by this project shall be hauled off-site and off station by the Contractor.

## **G20 SITE IMPROVEMENTS**

Not used.

## **G30 SITE MECHANICAL UTILITIES**

Not used.

## **G40 SITE ELECTRICAL UTILITIES**

Not used.

-- End of Section --

## Small Project Part 4 Minimum Materials, Engineering and Construction Requirements

10/14

**1. GENERAL REQUIREMENTS:** The requirements indicated here are minimum performance requirements. More specific project functional and performance requirements, scope items and expected quality levels over and above the standards in Part 4 are identified in Part 3 of the Request for Proposal or Basic Ordering Agreement. The Contractor is encouraged to exceed the minimum requirements. The Contractor's performance evaluation will be based in part on enhancements to materials, engineering, design and construction provided for the contract that exceed minimum requirements.

**Part 4 is a general section. Not all items in Part 4 will be required for this project.** See Part 3 for project-specific requirements. See "Order of Precedence" paragraph in Part 2 for relationships between all parts of the RFP.

In general, unless otherwise indicated, Contractor shall provide all labor, equipment and materials necessary to complete the work required for the contract. All work shall be in conformance with all applicable referenced criteria, construction standards, laws and regulations, including applicable building and fire, life safety codes.

### **Recycled Materials Considerations:**

An Affirmative Procurement Program has been established within the Federal government to promote the purchase of products containing recovered materials. This program promotes the purchase of products containing materials recovered from the solid waste stream. The intent is to conserve resources and reduce solid waste by developing markets for recycled products and encouraging manufacturers to produce quality recycled content products. The contractors shall use products that meet or exceed the EPA guideline standards for recovered content as required by the Federal Acquisition Regulations (FAR). Availability lists of manufacturers and EPA research on product usage are on the Construction Criteria Base (CCB) at <http://www.ccb.org> under Documents Library, NAVFAC Criteria. A partial list of products containing recycled materials for possible use is as follows:

- Rock Wool Insulation
- Fiberglass Insulation
- Cellulose Insulation
- Structural Fiberboard and Laminated Paperboard
- Cement and Concrete - Coal Fly Ash
- Carpet including backings and cushions
- Floor Tiles
- Reprocessed and Consolidated Latex Paint.

**1.1 MATERIALS AND METHODS OF CONSTRUCTION.** Only new materials and equipment shall be installed in the work. All materials, equipment and appliances shall be of the current manufacturers' products. No obsolete or discontinued materials, equipment and appliances shall be used, except that construction materials containing recycled content as described in Paragraph 1 of this Part that completely comply with all materials specifications found elsewhere in this Part may be used.

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

**1.2 APPLICABLE CODES AND STANDARDS:**

The design and construction shall be in accordance with established construction practices, and the latest revision/edition of the following referenced codes and standards. The term "Latest Revision/Edition" is defined as the version as of the project award date. References are available at [www.wbdg.org/ndbm/](http://www.wbdg.org/ndbm/). The advisory provisions of all codes and standards shall be mandatory, as though the word "shall" had been substituted for "should" wherever it appears. Reference to the "authority having jurisdiction" shall be construed to mean "Contracting Officer". Comply with the required and advisory portions of the current edition of the standard at the time of contract award. UFC 1-200-01, *General Building Requirements* is the building code guide and contains references to other UFCs and Codes that are to be used for all sections in this contract. UFC 1-300-09N, *Design Procedures*, provides design guidance and contains references to other UFCs and Codes that are to be used for all sections in this contract.

1. Unified Facilities Criteria (UFC) 1-200-01, *General Building Requirements*
2. UFC 1-300-09N, *Design Procedures*
3. American Gas Association (AGA).
4. Associated Air Balance Council (AABC)
5. National Environmental Balancing Bureau (NEEB)
6. International Mechanical Code (IMC).
7. American Society of Heating, Refrigeration, and Air Conditioning Engineers (ASHRAE) Standards
8. Sheet Metal and Air Conditioning Contractors National Association (SMACNA) guidelines.
9. International Plumbing Code (IPC).
10. Illuminating Engineering Society North America (IESNA) Handbook
11. National Electrical Manufacturers Association (NEMA).
12. Electronic Industries Alliance (EIA)
13. Telecommunications Industry Association (TIA)
14. American Woodwork Institute
15. Architectural Woodwork Institute
16. APA – The Engineered Wood Association.
17. Steel Door Institute (SDI).
18. American Aluminum Manufacturers Association (AAMA)
19. National Wood Window and Door Association (NWWDA).
20. NRCA, *Roofing and Waterproofing Manual* found at <http://www.nrca.net/rp/technical/manual/manual.aspx>
21. American Hardware Association (AHA).
22. Building Hardware Manufacturers Association (BHMA).
23. Federal, State, County, and local environmental regulations.
24. ASHRAE Std. 90.1, *Energy Standards for Buildings Except Low Rise Residential Buildings*
25. American Society of Testing and Materials (ASTM)
26. American Water Works Association (AWWA)
27. National Fire Protection Association (NFPA) Codes and Standards
28. IEEE C2, *National Electrical Safety Code*

**1.3 LOCATION-SPECIFIC CODES AND STANDARDS:** See Part 3

**1.4 DISCREPANCIES:** When discrepancies in the referenced standards and the contract requirements occur, the more stringent requirements shall govern. The word "should" in all NFPA publications shall be interpreted as a requirement. The Authority Having Jurisdiction in the interpretation of the codes and standards, and approving the exceptions allowed in the referenced standards, shall be the Contracting Officer, and the parties designated by the Contracting Officer.

**Replace Siding – Bldg 405  
Naval Support Activity, Mechanicsburg, Pennsylvania  
Work Order Number 1350926**

## **2. PERFORMANCE TECHNICAL SPECIFICATIONS**

Note: The paragraph numbers used correspond with the numbers used in UNIFORMAT II/Work Breakdown Structures (WBS) as listed in the Whole Building Design Guide, Navy Design Build Master, accessible at this website: [www.wbdg.org/ndbm](http://www.wbdg.org/ndbm).

### **SECTION A. SUBSTRUCTURE**

#### **A10 FOUNDATION**

Foundations shall be reinforced concrete slabs-on-grade with continuous strip footings or isolated spread footings. Concrete slabs shall not be less than 4 inches in thickness and footings shall not be less than 18 inches below the lowest adjacent grade. Foundations shall be designed and constructed of reinforced concrete. All design and construction shall comply with IBC and with applicable requirements in Section B Shell. For the purposes of interpreting IBC Chapter 18, the “Owner” and “Building Official” shall mean the “Government”, and the “Applicant” shall mean the “Contractor/Designer of Record”.

- 1. Contractor-Foundation Design:** The Designer of Record shall evaluate the RFP data, and obtain and evaluate all additional data as required to support the design and construction.
- 2. Geotechnical Site Data required in Design Drawings:** The Contractor's final design drawings shall include:
  - a. Notes identifying the soil allowable bearing capacity used in design.
  - b. Subsurface soil information, be it Government provided or Contractor obtained, that represents subsurface conditions existing on the project site (such as boring logs, test pits, laboratory test results and groundwater observations). The locations of all borings shall be indicated on the drawings.
- 3. Performance Verification and Acceptance Testing:** Verification of satisfactory construction and system performance shall be via Performance Verification Testing, as detailed in this part of the RFP.
  - a. **Earthwork:** Perform quality assurance for earthwork in accordance with IBC Chapter 17. See Section G1030.

### **SECTION B. SHELL**

Building shell may be of any materials and design allowed by applicable codes and standards, subject to specific requirements that may be applicable to a particular Activity, such as the Base Exterior Architecture Plan (BEAP) and UFC 4-010-01.

#### **B10 SUPERSTRUCTURES**

Superstructure work includes structural frames, bearing walls, floors, roofs, roof canopies, and balcony construction. Unless otherwise specified in Part 3, superstructures may be designed and constructed using any materials or combination of different materials allowed by applicable codes and standards. All design and construction shall comply with IBC. Special inspection, testing, approvals,

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

certifications, observations and quality assurance plans as prescribed in Chapter 17 of the IBC are required.

1. **Concrete:** All concrete shall be constructed in accordance with ACI 301. Concrete shall have a 28-day minimum compressive strength of 3,000 psi. Slump shall be between 2 and 4 inches in accordance with ASTM C143. Provide joints as required to minimize cracking. All concrete shall be reinforced. Provide joints as required by applicable ACI standards. Unless otherwise specified in Part 3 or as indicated by the contracting officer, provide steel trowel finish for all exposed floor surfaces.
2. **Masonry:**
  - a. All concrete masonry shall be constructed in accordance with ACI 530.1. Concrete masonry shall have a minimum 28-day compressive strength of 1500 psi. Concrete masonry units shall conform to ASTM C90, grade A1. Broken blocks are not allowed. Use only standard size and shape blocks. Block may be cut when necessary. Mortar shall be Type S.
  - b. When used, brick shall conform to ASTM C216. In exposed construction, broken brick shall not be allowed. Standard size brick may be cut to fit job condition. Use Type S mortar.
  - c. Provide metal anchors for masonry and brick, including veneer construction as required by IBC.
3. **Structural Steel:** Structural steel exposed to weathering shall be adequately protected to prevent corrosion.
4. **Steel deck:** Steel form deck shall have a G90 galvanized finish, and must have a minimum 26-gage thickness. All other steel deck shall have a G90 galvanized finish, and must have a minimum 20-gage thickness.
5. **Cold-formed metal framing:** Cold-formed steel studs, joists and track shall be galvanized with a minimum thickness of 20-gage.
6. **Wood framing:** Wood framing members shall be new lumber, unless otherwise allowed by Part 3. Timber can be Douglas Fir, Douglas Fir-Larch, Hem-Fir, Southern Pine or other structurally competent species allowed by applicable codes and standards. Wood framing shall meet the following minimum grading requirements:
  - a. Studs - #3
  - b. Joists and rafters- #2
  - c. Beams, 4x and larger - #1
  - d. Posts, 4x and larger - #1
  - e. Blocking - #3
  - f. Fascia, trim - #1
  - g. Wood Structural Panel Sheathing (Exterior Glue)
  - h. Roof - APA rated with span index of 24/0 – minimum thickness ½ inch
  - i. Walls - APA rated with span index of 32/16 – minimum thickness ½ inch
  - j. Flooring- APA rated with span index of 48/24 – minimum thickness ¾ inch

**Replace Siding – Bldg 405  
Naval Support Activity, Mechanicsburg, Pennsylvania  
Work Order Number 1350926**

**B20 EXTERIOR ENCLOSURE**

**B2010 EXTERIOR WALLS**

**1. Exterior Wall Performance:**

- a. **Vapor Transmission Analysis:** Perform a job specific vapor transmission analysis in accordance with ASHRAE 90.1 or WUFI. The conclusion of the analysis shall indicate the appropriate locations of needed vapor retarders, air barriers, and anticipated dew-point locations in the exterior enclosure during different critical times of the year.
- b. **Maximum Air Infiltration:** The maximum allowable air leakage for any material used as part of the air barrier system for the opaque enclosure shall be 0.02 L/s/M<sup>2</sup> @ 75 Pa (liters/second per square meter at 75 Pa pressure) [0.004 cfm / sf at 1.57 psf], as tested according to ASTM E 2178 test protocol.
- c. **Wind Loads:** Provide wind load calculations for exterior cladding in accordance with ASCE-7 with comparative analysis of the cladding system to be provided.
- d. **Water Penetration:** No water penetration shall occur at a pressure of 39 Kg/m<sup>2</sup> (8 psf) of fixed area when tested in accordance with ASTM E 331.
- e. **Insulating Value:** The complete wall system shall have a minimum insulating value as required by the building code and as required to meet ASHRAE Standard 90.1 as modified by the Energy Policy Act of 2005.

**2. Masonry Veneer Exterior Wall Closure Components:** Masonry veneer shall include load bearing and non-load bearing exterior walls of the structure, and shall include colored mortar, special shapes such as sills, headers, trim units and copings of brick masonry, precast concrete, concrete masonry units, or other approved material. Utilize BIA Technical Notes to design, detail, and construct brick masonry walls. Substitute directive language in the place of BIA suggestive language. The results of these wording substitutions change this document to required procedures. The veneer shall be tied to the backup wall system with a system that allows the veneer to move independently of the backup wall system, while being structurally supported. The masonry veneer shall allow for expansion and contraction of the veneer without cracking the exterior material.

- a. **Masonry Veneer Installation:** Conform to ACI 530.1 for masonry veneer installation, including cold weather construction. Antifreeze admixtures are not to be used.
- b. **Mortar:** Provide factory-tinted colored mortar conforming to ASTM C270, unless DOR directs otherwise.
- c. **Expansion/Control Joints:** Locate expansion/control joints and seal with proper backing material and ASTM C 920 polyurethane sealant, or preformed foam or rubberized expansion joint closure. Conform to UFC 3-100-10 and BIA Technotes 18, 18A.
- d. **Brick:** shall be ASTM C216, Grade SW, type FBS, or type FBX for detail work. ASTM C67 test rating shall be "Not effloresced". Use FBA brick only for special architectural effects requiring a non-uniform size.
- e. **Split Faced or Ground Faced Masonry:** ASTM C 90

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

- f. **Cast Stone Trim Units:** Cast Stone shall meet or exceed the requirements of ASTM C 1364.
- g. **Wall Cavity:** shall Comply with the and BIA Technical Notes 21A, 21B, 21C, 28B
- h. **Through-Wall Flashing Components:** Through-wall flashing with weep holes shall be incorporated in cavity wall construction. Flashing shall be 7 ounce copper flashing with a 3 ounce bituminous coating on each side or a fiberglass fabric bonded on each side of the copper sheet; 16-ounce uncoated copper, 28 gauge Type 302 or 304 stainless steel is also acceptable. Flexible membrane flashing, plastic or PVC-based membrane flashing is prohibited.
- i. **Reinforcing in Veneer Layer:** Reinforcing in the veneer layer shall be galvanized in accordance with ASTM A 123/A123M, ASTM A153/A153M, or ASTM A653/A653M, Z275 (G90) coating, and be of sufficient size to eliminate damage to the veneer layer from wind and other live and dead loads imposed on the veneer layer.
- j. **Masonry Cleaning:** Clean the masonry in accordance with manufacturer's instructions and BIA Technote 20.

**3. Metal Wall Panel Exterior Closure**

Panels shall have factory applied, baked coating to the exterior and interior of metal wall panels and metal accessories. Exterior finish topcoat shall be of 70 percent polyvinylidene fluoride (PVDF) resin with not less than 0.8 mil dry film thickness (DFT). Exterior primer shall be standard with panel manufacturer with not less than 0.8 mil dry film thickness (DFT).

Wall system and attachments shall resist wind loads as determined by ASCE 7, with a factor of safety appropriate for the material holding the anchor. Maximum deflection due to wind on aluminum wall panels shall be 1/60. Maximum deflection due to wind on steel wall panels and girts behind aluminum or steel wall panels shall be limited to 1/120 of their respective spans, except that when interior finishes are used the maximum allowable deflection shall be limited to 1/180 of their respective spans.

Conformations - Non-insulated steel or aluminum wall panels shall have configurations for overlapping adjacent sheets or interlocking ribs for securing adjacent sheets and shall be fastened to framework using concealed fasteners, or choose the option for exposed fasteners when exposed fasteners are acceptable at the installation. Length of sheets shall be sufficient to cover the entire height of any unbroken wall surface.

**a. Steel Wall Panels:**

- 1) **Material and Coating:** Form sheets from steel conforming to ASTM A 653/A 653M, Structural Grade 40, galvanized coating conforming to ASTM A 924/A 924M, Class G-90; aluminum-coated steel conforming to SAE AMS 5036; or steel-coated with aluminum-zinc alloy conforming to ASTM A 792/A 792M, except that coating chemical composition shall be approximately 55 percent aluminum, 1.6 percent silicon, and 43.4 percent zinc with minimum coating weight of 0.5 ounce per square foot.
- 2) **Gage:** Minimum 22 U.S. Standard Gage for wall panels, but in no case lighter than required to meet maximum deflection requirements specified.

**b. Aluminum Wall Panels:**

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

- 1) Material and Coating - Form sheets of Alloy 3004 or Alclad 3004 conforming to ASTM B 209 having proper temper to suit respective forming operations.
  - 2) Thickness - Minimum 0.81 mm (0.032 inch) nominal, but in no case thinner than that required to meet maximum deflection requirements specified.
- c. **Insulated Aluminum or Steel Wall Panels:** Insulated wall panels shall be steel or aluminum factory-fabricated units with insulating core between metal face sheets securely fastened together and uniformly separated with rigid spacers. Panels shall have a factory color finish. Wall panels shall have edge configurations with interlocking ribs for securing adjacent panels. System shall utilize factory fabricated corners and trim pieces at intersections with other materials. Insulated wall panels shall be fastened to framework using concealed fasteners.
- 1) Insulated Steel Panels - Zinc-coated steel conforming to ASTM A 653/A 653M; or Aluminum-zinc alloy coated steel conforming to ASTM A 792/A 792M, AZ 55 coating. Uncoated wall panels shall be 0.61 mm (0.024 inch) thick minimum.
  - 2) Insulated Aluminum Panels - Alloy conforming to ASTM B209, temper as required for the forming operation, minimum 0.81 mm (0.032 inch) thick.

**4. Stucco Exterior Wall Closure**

- a. **Portland Cement Plaster:** ASTM C150, gray Portland cement Type II with 13 mm (1/2 inch) maximum chopped alkali resistant fiberglass strands, minimum 1.5 percent by weight to cement; .68 kg (1 1/2 pounds) per sack of cement. Lime shall conform to ASTM C206, Type S. System shall utilize stainless steel or zinc corner beads, J-beads and other accessories. Unless specifically deleted, the system shall utilize an acrylic admixture or coating to give additional moisture suppression to control fungus growth.
- b. **Exterior Insulation and Finish System (EIFS):** EIMA TM 101 and 01 EIMA TM 101.86. EIFS shall be used as the non-primary or the primary exterior finish material only for projects where it is necessary to match existing EIFS.

**5. Precast Concrete Wall Panels:** ACI 211.1 and ACI 301. PCI MNL-116 or PCI MNL-117. Concrete shall have a minimum 28-day compressive strength of 281 Kg/cm<sup>2</sup> (4000 psi). Joints shall include properly sized and placed backing material and fully loaded and tooled sealant joint of no less than 1/4 inch sealant material thickness.

**6. Other Wall Finish Systems**

- a. **Horizontal Wood Siding:** Horizontal Wood Siding: DOC PS 20, exterior, lap type, 6 inches wide, maximum practicable lengths, 11 mm (7/16 inch) thick, smooth face. All surfaces of wood siding and trim shall be shop coated with an alkyd primer.

Species and Grades 1. Grade 1 Common spruce-pine-fir; NELMA, NLGA, WCLIB, or WWPA.  
2. Grade Prime or D finish, pressure-preservative-treated hem-fir; NLGA, WCLIB, or WWPA.  
3. Grade D Select (Quality) eastern white pine, eastern hemlock-balsam fir-tamarack, eastern spruce, or white woods; NELMA, NLGA, WCLIB, or WWPA. 4. Grade D Select northern white cedar; NELMA or NLGA. 5. Grade B & B, pressure-preservative-treated southern pine; SPIB.

- b. **Vinyl Siding System:** Integrally colored, vinyl siding complying with ASTM D 3679.

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

- c. **Manufactured Faced Panels Systems Exterior Wall Siding:** Glass Fiber Reinforced Cementitious Panels System: Siding made from fiber-cement board that does not contain asbestos fibers; complies with ASTM C 1186, Type A, Grade II; horizontal or vertical pattern in plain or beaded-edge style. Texture: Rough sawn or smooth, factory primed.

**7. Exterior Wall Backup Construction**

- a. **Concrete Unit Masonry:** Provide concrete unit masonry to comply with ACI 530.1. Load-bearing units: ASTM C90, Non-load bearing- units: ASTM C129, Type I or II. Provide ground face units, split-faced units, ground-faced units, or split-ribbed units for exposed exterior walls. Provide water repellent admixture to masonry units where the exterior face of the units will not receive a waterproof coating such as paint
- b. **Dampproofing:** Dampproof the cavity-facing wythe of the backup masonry using asphaltic primer according to ASTM D 41, if dampproofing is not provided by a sprayed on foam or other DOR-approved membrane insulation system.

**8. Load-Bearing Metal Framing System**

If permitted, provide load-bearing metal framing including top and bottom tracks, bracing, fastenings, and other accessories necessary for complete installation. Framing members shall have the structural properties indicated. Where physical structural properties are not indicated, they shall be as necessary to withstand all imposed loads. Design framing in accordance with AISI SG-673. Installation shall be in accordance with DOR-approved shop drawings and manufacturer's installation instructions.

**9. Exterior Studs:**

<u>Max. Deflection Criteria</u>	<u>Exterior Finish</u>
L/360 Panels	Cement Plaster, Wood Veneer, Synthetic Plaster, Metal
L/600	Brick Veneer, Stone Panels

Wall deflections shall be computed on the basis that studs withstand all lateral forces independent of any composite action from sheathing materials. Studs abutting windows or louvers shall also be designed not to exceed 1/4-inch maximum deflection and as required in UFC 4-010-01.

- 1) Studs - ASTM A 1003/ASTM A 1003M, Structural Grade 50, Type H minimum; provide Z180 (G60) galvanized coating in accordance with ASTM A 653/ASTM A 653M. Do not expose studs to direct moisture contact
- 2) Bracing - Provide horizontal bracing in accordance with design calculations and AISI SG-673, consisting of, as a minimum, runner channel cut to fit between and welded to the studs.
- 3) Sheathing - Provide sheathing to withstand structural loads imposed on the wall structure. Cover sheathing with either a 15 pound asphalt-impregnated building paper, or air barrier as required by the wall moisture analysis. Sheathing shall be one of the following:
  - a) Plywood: C-D Grade, Exposure 1;

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

- b) Structural-Use and OSB Panels;
- c) Gypsum: ASTM C 79/C 79M and ASTM C 1177/C 1177M, 13 mm (1/2 inch) thick fire retardant (Type X) 15 mm (5/8 inch) thick; 1.2 meters (4 feet) wide with square edge for supports 400 mm (16 inches) o.c. with or without corner bracing of framing. Gypsum sheathing shall be faced with materials capable of resisting six months of weathering exposure without degradation of the covering or the gypsum. Seal all joints as recommended by the manufacturer.

**10. Wood Framing System:** All materials shall be kiln-dried lumber complying with DOC PS 20. Installation shall be in accordance with AF&PA T11. System shall use preservative pressure treated lumber at sill plates and other members in contact with concrete and masonry surfaces.

- a. **Species and Grades:** Provide species and grades listed: 1) Grade 2 Common spruce-pine-fir; NELMA, NLGA, WCLIB, or WWPA; 2) Grade 2 Common, hem-fir; Douglas-fir; NLGA, WCLIB, or WWPA; 3) Grade 2 Common, southern pine; SPIB.
- b. **Sheathing:** Sheathing shall withstand structural loads imposed on the wall structure. Cover sheathing with either a 15 pound asphalt-impregnated building paper, or air barrier as required by the wall moisture analysis. Sheathing shall be as for Metal Studs.

**11. Cast-in-place Concrete System:** Concrete construction must be in accordance with ACI 301.

**12. Insulation and Vapor Retarder:** Insulation, Vapor Retarders, and Air Barrier Systems in or on Exterior Enclosure shall include: insulation, liquid, sheet or continuous film materials installed separately in or on wall assemblies to provide resistance to heat loss/gain, and vapor penetration.

- a. **Vapor retarder:** Comply with ASTM C755. Incorporate in the exterior wall system where required by vapor transmission calculations or dew point analysis indicates the need or in conditions of high moisture exposure.
- b. **Bituminous Dampproofing:** Bituminous Dampproofing shall be ASTM D449, Type I or Type II bituminous dampproofing on the exterior surface of the interior wythe of masonry in a cavity wall (back-up wall for masonry veneer).
- c. **Building Paper:** FS UU-B-790, Type I, Grade D, Style 1.
- d. **Air Barrier:** Building wrap consisting of air barrier sheeting complying with ASTM E 1677, Type 1, not less than 3 mils thick with a permeance of not less than 575 ng/Pa x s x sq.m. (10 perms). Building wrap shall have a flame spread index of less than 25 in accordance with ASTM E 84. Provide building wrap over sheathing of wood or metal framed construction to reduce air penetration and airborne vapor penetration. Provide building wrap tape as recommended by the manufacturer for sealing all joints in the building wrap. Installation shall be in accordance with manufacturer's instructions. Air barrier installation at windows shall be in accordance with ASTM E 2112.
- e. **Insulation Systems:** Vertical and horizontal polystyrene insulation conforming to ASTM C578 or rigid polyisocyanurate board wall insulating products conforming to ASTM C591 or mineral-fiber blanket insulation conforming to ASTM C 665 shall be provided.

**13. Parapets:** Avoid parapets when possible, but when necessary, provide parapets with the same materials as the exterior wall construction. Provide scuppers and wall edge according to SMACNA.

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

- 14. Exterior Louvers and Screens:** If required, provide louvers for Screened Equipment Enclosure or as louvers for exterior doors.

Storm shutters shall comply with ASTM E 1996-03.

- 15. Balcony Walls and Handrails:** Balcony walls to match exterior construction. Handrails to comply with the IBC and OSHA.

- 16. Exterior Soffits:** Exterior soffit system.

- 17. Exterior Painting and Special Finishes;** All painting and coating materials shall be low VOC. Painting practices shall comply with applicable federal, state and local laws enacted to insure compliance with Federal Clean Air Standards. Apply coating materials in accordance with SSPC PA 1. SSPC PA 1 methods are applicable to all substrates.

All paint shall be in accordance with the Master Painters Institute (MPI) standards for the exterior architectural surface being finished. The current MPI, "Approved Product List" which lists paint by brand, label, product name and product code as of the date of contract award, will be used to determine compliance with the submittal requirements of this specification. Provide paint systems tested to "Detailed Performance Level" standard as defined by MPI.

- 18. Exterior Joint Sealant:** Sealant joint design, priming, tooling, masking, cleaning and application shall be in accordance with the general requirements of Sealants: A Professionals' Guide from the Sealant, Waterproofing & Restoration Institute (SWRI). All sealant shall conform to ASTM C 920.

- 19. Sun Control Devices:** Sun control devices shall be manufactured devices to provide sun control on exterior windows and storefronts. Sun control devices shall be designed and installed to withstand the wind loads prevailing at the project site.

## **B2020 EXTERIOR WINDOWS**

All windows and doors in new or existing buildings, which are subject to Anti-terrorism Standards, must be blast-resistant as prescribed in UFC 4-010-01.

Unless otherwise allowed by Part 3, windows for new facilities shall be aluminum. In building additions or renovations windows shall match existing window materials. Exterior windows design, dimension, and construction shall meet or exceed the requirements for Anti Terrorism Force Protection requirements. In addition, exterior windows shall meet or exceed Energy Star requirements. The design and placement of exterior windows shall take into considerations view, natural light, privacy, and protection for the occupants of the facilities. Provide operable hardware and insect screen for exterior windows. Windows shall be fabricated by manufacturers normally involved in the manufacturing of windows and shall be of the current make and model. No obsolete or discontinued windows shall be used. Provide weather stripping, STC and IIC rating, commensurate with the intended use of the facility. Submit catalog information and manufacturer's specifications for approval by Contracting Officer prior to purchase of windows.

Windows shall consist of fixed and operable sash used singly and in multiples. Provide operable sash in spaces occupied by people as a minimum. Include operating hardware, non-corroding framed metal screens for operable sash, integrated blinds set between glass panels and security grilles. Provide jamb support for larger windows where recommended by manufacturer.

- 1. Metal Windows:** All windows shall conform to ANSI/AAMA/WDMA 101. Metal windows with insulating glass shall have thermally broken frames and sash. Factory finish aluminum windows

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

and provide with aluminum frame screens with aluminum mesh at operable sash, hardware and locks, and tinted glazing. Aluminum screens shall comply with ANSI/SMA 1004.

2. **Wood Windows:** Clad wood and wood windows shall consist of complete units including sash, glass, frame, weatherstripping, insect screen, and hardware. Window units shall meet the requirements of AAMA 101, except maximum air infiltration shall not exceed 0.30 CFM per linear foot of sash crack when tested under uniform static air pressure difference of 7.66 Kg/m<sup>2</sup> (1.57 psf).
3. **Storefronts:** Provide one-story storefront system fabricated from formed and extruded aluminum and glass components for exterior use. Utilize the specific section of the Standard Design-Build Performance Technical Specifications Section B202002 for the storefront to be provided. Storefront framing shall meet or exceed the structural requirements, as measured in accordance with ANSI/ASTM E330: Design system to withstand this as a minimum and comply with design pressure established within the required ASCE 7-05 Wind Speed Calculations determined by the overall average opening within the project.
4. **Glazing: All exterior glazing shall be insulating glass.**
  - a) Clear Glass - Type I, Class 1 (clear), Quality q4 (A);
  - b) Heat-Absorbing Glass - ASTM 1036, Type I, Class 2 Quality q3 (select) ray frames;
  - c) Wire Glass - Type II, Class 1, Form 1, Quality q8 Mesh m1 or Form 2, Quality q7;
  - d) Laminated Glass - ASTM 1172, total thickness shall be nominally 6 mm (1/4 inch);
  - e) Insulating Glass Units - Typically ASTM C 1036, Type I, Class 1, Quality q4, minimum 6 mm;
  - f) Tempered Glass - ASTM C 1048, Kind FT (fully tempered);
  - g) Patterned Glass - ASTM 1036, Type II, Class 1 (translucent), Form 3 (patterned), Quality q7 (decorative), Finish f1 (patterned one side), Pattern p2 (geometric) 5.55 mm (7/32 inch) thick.

### **B2030 EXTERIOR DOORS**

Exterior doors shall be heavy duty insulated steel doors and frames for service access. Door frames shall have welded corners. Use heavy-duty overhead holder and closer to protect doors from wind damage. Steel shall have G60 galvanized coating in accordance with ASTM A 924/A 924M and ASTM A 653/A 653M when the job site is located within 300 feet from a body of salt water. Provide commercial quality, coating Class A zinc coating in accordance with ASTM A591 for other steel or steel skin hollow metal doors at other locations. Provide kickplates on the inside face of all exterior doors. Weather-protect all exterior doors and related construction with low infiltration weatherstripping and sealants. Provide threshold with offset to stop water penetration while maintaining accessibility compliance. Conform to the design criteria of ASCE 7. See the hardware schedule for door hardware requirements.

1. **Steel Doors:** Exterior doors shall comply with ANSI A250.8-1998 (SDI-100). Hardware preparation shall be in accordance with ANSI A250.6. Doors shall be hung in accordance with ANSI A115.16.
  - a. Doors Required:
    - 1) Standard Duty Doors - Level 1, MSG # 20 (IP 0.032", 0.8 mm), physical performance Level C, Model 1 or 2.
    - 2) Heavy Duty Doors – MSG # 18 (IP 0,042", 1 mm), physical performance Level B, Model 1 or 2.

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

- 3) Extra Heavy Duty Doors – Level 3, MSG #16, (0.053", 1.3 mm) physical performance Level A, Model 1, 2, or 3.
  - 4) Maximum Duty Doors – Level 4 (IP 0.067", 1.6 mm), physical performance Level A, Model 1 or 2.
- b. Insulated steel doors and frames are required for entrances to dwelling units, and may also be specified as a Contractor's option to Level 1 standard hollow metal doors. Do not use wood doors for exterior doors, unless they are fully protected from the elements, an exterior grade species, and specially finished. If wood doors are used, provide in accordance with Standard Design-Build Performance Technical Specification Paragraph B203001 2.
2. **Standard Steel Frames;** ANSI A 250.8. Form frames with welded corners for installation in exterior walls. Form stops and beads of 20 gage steel. Frames shall be set in accordance with ASTM A250.11. Anchor all frames with a minimum of three jamb anchors and base steel anchors per frame, zinc-coated or painted with rust-inhibitive paint, not lighter than 18 gage. Mortar infill frames in masonry walls, and infill with gypsum board compound at each jamb anchor in metal frame walls. Only use surface exposed bolted anchors in concrete walls.
  3. **Door and Frame Finishes:** a) Exterior Doors, Factory-Primed and Field Painted Finish - Doors and frames shall be factory primed with a rust inhibitive coating as specified in ANSI A250.8. Factory prime doors on six sides of the door; b) Exterior Doors Galvanized Finish -- Shall be Commercial Quality, Coating Class A, zinc coating in accordance with ASTM A 591 when facility is located further than 91 meters (300 feet) from the ocean. When facility is located within 91 meters (300 feet) of the ocean, provide G60 galvanized coating in accordance with ASTM A 924/A 924M and ASTM A 653/A 653M.
  4. **Upward Acting Doors:** Upward acting doors shall be capable of withstanding the design wind loading of ASCE 7. Provide galvanized steel tracks not lighter than 14 gage for 50 mm (2 inch) tracks and not lighter than 12 gage for 75 mm (3 inch) track. Provide a positive locking device and cylinder lock with two keys on manually operated doors.
  5. **Overhead and Roll-up Doors:** Large exterior overhead and roll-up doors system shall consist of manual or automatic exterior doors and door assemblies.
  6. **Rolling Service Doors and Grilles:** Coiling overhead doors shall have minimum 22 gage thermal insulated slats. Electric operators shall have three-button switches conforming to NEMA MG 1, NEMA ICS 1, and NEMA ICS 2, and auxiliary hand chain operation, weather-stripping and wind-locks. Doors shall be capable of withstanding the design wind loading of ASCE 7 and still operate normally. Finish of the door shall be hot-dipped galvanized with a painted finish.
  7. **Sectional Overhead Doors:** Sectional overhead doors shall conform to NAGDM 102, Residential or Commercial or Industrial door standards. If doors are electrically operated, pushbuttons shall be full-guarded to prevent accidental operation, and include limit switches to automatically stop doors at the fully open and closed positions. Limit switch positions shall be readily adjustable.
  8. **Hardware:** Provide the services of a Certified Door Hardware Consultant to prepare the door hardware schedule.

Provide all new hardware with satin chrome finish throughout. Hardware shall be commercial grade, suitable for the operational requirements and in compliance with life safety code and handicapped accessibility requirements, similar in quality to the hardware shown in C1020 Interior Doors and Hardware below.

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

Coordination: Provide a master keying system compatible with the existing base system. Provide an emergency access key box for exterior door fireman key access. Coordinate with the local authority and the Contracting Officer to determine the local requirements for hardware, keying and master keying.

**B30 ROOFING**

For repair of existing roofing, the cutting of the existing roof shall be kept to a minimum and, where necessary, shall be made in a clean and orderly manner to prevent the appearance of a patch.

Repair all damage to existing and new roofing caused by the work of this Contract at no additional cost to the Government. The work shall be executed in such a manner as to maintain the integrity of the existing roofing manufacturer's warranty.

- 1. Pre-Roofing Conference:** Prior to beginning roofing work, the Contractor shall hold a Pre-Roofing Conference with the personnel directly responsible for the roofing systems work, as well as the roofing manufacturer's technical representative.
- 2. Roof Design Assurance:** If the roofing project is significant (Significant Roof – A single or group of buildings greater than 1,400 m<sup>2</sup> (15,000 sf)), or where extenuating circumstances of the roof project such as building use, content, safety, or visibility require a roofing consultant, the Contractor shall utilize the services of a Registered Roof Consultant (RRC) certified by the Roof Consultant Institute, or a Registered Professional architect or Engineer who specializes in roofing, to approve the roof design. The roof consultant must be engaged in roofing design and roofing construction as his primary endeavor. The roof consultant shall verify in writing that the design for the project is in accordance with the current edition of *NRCA Roofing and Waterproofing Manual*, UFC's, and RFP, and standard industry practices and building codes.

If a Roof Design Assurance Consultant is needed, consider using a Registered Roof Observer as a QC specialist.

**B3010 ROOF COVERINGS**

Roof coverings and procedures shall comply with the requirements of UFC 3-110-03, *Roofing*, and NRCA, *Roofing and Waterproofing Manual* found at <http://www.nrca.net/rp/technical/manual/manual.aspx> as the primary NAVFAC roofing criteria. Roof selection shall comply with UFC 3-330-02A, *Design: Commentary on Roof Systems*. Determine wind uplift using wind speed in accordance with ASCE-7.

- 1. STEEP SLOPE ROOF SYSTEMS:** Steep slope systems shall be roofs with a pitch greater than 3 in 12. Steep Slope Systems are slate roofing, Asphalt Shingles, Roof Tiles, Foam Set Tiles, Metal Roof Panels (Architectural Standing Seam Metal Roofs on supported substrate), and Structural Standing Seam Metal Roof (SSSMR). Asphalt shingles can only be used for residential construction and light commercial construction.
- 2. LOW SLOPE ROOF SYSTEMS:** Low slope systems shall be roofs with a pitch 3 in 12 or less. Low slope roofing systems shall be built-up asphalt roofing (aggregate surfaced, with modified bituminous components), modified bituminous membrane roofing of a minimum of 3 plies with aggregate surface or granular surface modified bitumen cap sheet, or structural standing seam metal roofing. Use epdm systems only to match existing construction.
- 3. ROOF COMPONENTS:**

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

- a. **Insulation:** For existing structures, provide insulation in accordance with ASHRAE 90.1. For new construction, provide R-30 insulation in the ceilings, attic spaces and soffit areas for interior spaces. Injected polyurethane and Urea Formaldehyde Foam field applied shall not be used. Provide acoustical insulation above walls separating bathroom/restrooms and corridor and adjacent occupied spaces, and between offices and corridors. Insulation shall have a minimum sound attenuation rating of STC-55.

Insulation shall be Polyisocyanurate Rigid Board Insulation , Mineral Fiber Blanket Insulation to conform to ASTM C 991, with Glass Mat Gypsum Roof Board for use above the deck or insulation conforming to ASTM C 1177/C 1177M, where necessary.

Only on portions of the roof where the sloping of structure does not allow the minimum slopes, provide a factory tapered roof insulation system to provide positive drainage of roof system, and to include drainage around curbs, penetrations, and projections through the roof plane.

Provide Glass Mat Protection Board meeting ASTM C 1177 for use as a thermal barrier (underlayment) or protection board for hot-mopped applications.

- b. **Vapor Retarder:**—Determine the need and location in the roof assembly for a vapor retarder. Where the mean January temperature is 40 degrees Fahrenheit or less, and the expected interior relative humidity is 45% or greater, use a vapor retarder. Otherwise, use ASHRAE 90.1 for the determination.
- 1) Vapor Retarders as Integral Facing - Alloy conforming to ASTM B 209, or Vapor Retarders Separate from Insulation - Vapor retarder material shall be 10 mil polyethylene sheeting conforming to ASTM D 4397.
  - 2) A slip sheet is required to separate the roofing panels from the insulation facing where the facing would be in direct contact with the roofing panels. If a slip sheet is necessary for use with a vapor retarder, use a 5 lb. per 100 square feet rosin-sized, unsaturated building paper.
- c. **EPDM Rubber Boots:** Flashing devices around pipe penetrations shall be flexible, one-piece devices molded from weather-resistant EPDM rubber.
- d. **Prefabricated Curbs and Equipment Support:** Provide Prefabricated curbs and equipment supports shall be of structural quality, hot-dipped galvanized or galvanized sheet steel, factory primed and prepared for painting with mitered and welded joints. Integral base plates and water diverter crickets shall be provided. Minimum height of curb shall be 8 inches above finish roof.
- e. **Fasteners:** Shall meet all requirements of the NRCA and Factory Mutual
- f. **Wood Nailers:** Wood nailers shall be pressure-preservative-treated in accordance with AWPA M2 Standards, permanently marked or branded, and installed flush with the top of the adjacent insulation board.
- g. **Flashing and Sheet Metal:** Provide flashing and sheet metal work including scuppers, splash pans, and sheet metal roofing. Flashing and sheet metal shall be provided in accordance with roof manufacturer's printed installation instructions and in compliance with NRCA and SMACNA recommendations. Fabricate Flashing and sheet metal components

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

from Copper, Lead-Coated Copper sheet, Steel Sheet, Zinc-Coated (Galvanized) - ASTM A 653/ A 653M, Stainless Steel - ASTM A 167, Type 302 or 304, 2D finish, or Pre-Finished Aluminum.

- h. **Gutters and Downspouts:** Provide gutters and downspouts compatible with roofing material and finish. Concealed (interior) gutters and downspouts are prohibited. Provide splash guards at points of discharge.
- i. **Roof Openings and Supports:** Provide flashings for roof openings and supports as recommended by the NRCA. Assure all penetration flashings extend minimum 200 mm (8 inches) above the finished roof surface.
- j. **Roof Hatches:** Provide roof hatch where required by OSHA, and as access to roof when roof mounted equipment is used or other routine roof maintenance is required.
- k. **Glazed Roof Openings:** Skylights and other glazed roof openings shall be used only to supplement interior lighting levels (generally in steep slope or vertical applications), and otherwise, are discouraged from use.
- l. **Guards:** Provide rails or guards as required by the OSHA, the International Building Code or other applicable safety standards.
- m. **Traffic Pads:** Provide on roof system to protect roof from foot traffic. Provide traffic pads around roof mounted mechanical equipment and underneath removable mechanical equipment access panels. Traffic pads shall be of compatible material to roof.

#### **4. OTHER ROOFING**

- a. **Lightning Protection:** Lightning protection component penetrations and attachments shall be sealed and flashed and anchored in a permanent manner and in a manner to avoid the degradation of the watertight integrity of the roof system.
- b. **Roof Drains (Existing):** Where existing roof drains are to be reused in roof replacement construction, the contractor shall provide new, compatible flashing materials, a new drain clamping ring and new bolts for anchorage. Reuse of existing clamping ring and bolts is unacceptable.

### **SECTION C. INTERIORS**

#### **C10 INTERIOR CONSTRUCTION**

##### **C1010 PARTITIONS**

- 1. **Fixed Partitions:** wood frame; light gage steel frame; concrete masonry complying with ACI 530.1/ASCE 6/TMS 602 and associated ASTM Standards; or cast-in-place concrete complying with UFC 1-200-01, ACI 117 and ACI 301/301M. In addition, interior partitions shall comply with tables for sound isolation and noise reduction in Chapter 1, "Architectural Graphic Standards". Include a statement of adherence to the applicable criteria.

Gypsum board/stud partitions may be standard gypsum board, moisture resistant, or impact resistant. Use cement board in showers and other wet areas. Reinforce points where doorknobs can strike a wall and anchorage points for wall mounted equipment.

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

2. **Demountable or Removable Partitions:** shall be of materials allowed by code and shall be anchored firmly to the structure to carry their own weight as well as impact forces and seismic lateral forces. Sound Transmission Class (STC) rating and Impact Isolation Class (IIC) rating shall be in accordance with ASTM E 90 or ASTM E 413 for frequency data, and shall meet the requirements of the intended use in Part 3.
3. **Glazed Partitions and Interior Windows:** shall be of the materials allowed by code IBC, and shall comply with fire and smoke separation requirements. Provide safety glazing and fire resistant rating where they are required.

**C1020 INTERIOR DOORS**

1. **Wood Doors:** Stile and rail wood doors shall be WDMA I.S.6A-01, premium or custom grade, heavy duty or extra heavy duty. Flush wood doors shall be WDMA I.S.1A-04, premium or custom grade, heavy duty or extra heavy duty; or WDMA I.S.-97 (PC-5 5-ply particleboard core or SCLC-5 5-ply structural composite lumber core). Doors adjacent to paneling or millwork shall comply with corresponding AWI millwork grade. Provide interior fire doors.
2. **Steel doors:** shall be ANSI A 250.8, Level 1, (occasional use, low abuse types such as closet doors without locks); Level 2, (low use, moderate abuse types such as office/storeroom doors); Level 3, (moderate use, high abuse types such as BEQ sleeping room doors); Level 4, (high use, high abuse types such as corridors, stairways, assembly spaces, and main entry doors), with a physical performance level of 'A'. Maximum door undercut shall not exceed 19 mm (3/4 inch).
3. **Sound Insulated Doors and Frames:** Utilize Sound Insulated Doors and Frames with sound control weatherstripping in rooms requiring wall assemblies to be sound insulated with a Sound Transmission Class (STC) rating as required. The STC rating for the door and frame assembly shall be not less than the wall assembly STC rating.
4. **Aluminum Doors and Frames:** Provide swing-type aluminum doors and frames complete with framing members, transoms, side-lites, and accessories. Fabricate of ASTM B 221, Alloy 6063-TS for extrusions.
5. **Steel Door Frames:** ANSI A 250.8. Form frames with welded corners for installation in masonry partitions and knock-down field assembled corners for installation in metal stud and GWB partitions. Frames shall be set in accordance with SDI 105. Form stops and beads with 20 gauge steel.

Provide a minimum of three jamb anchors and base steel anchors per frame, zinc-coated or painted with rust-inhibitive paint, not lighter than 18 gauge. Secure frames to previously installed concrete or masonry with expansion bolts in accordance with SDI 11-F. Provide mortar infill of frames in masonry walls, and gypsum board compound infill at each jamb anchor in metal frame walls.

6. **Fire doors:** Provide in conformance with NFPA 80 and NFPA 105. Fire doors and frames shall bear the label of UL, FM or WHI attesting to the rating required. Door and frame assemblies shall be tested for conformance per NFPA 252 or UL 10B (for neutral pressure) or UL 10C (for positive pressure). Wood fire doors shall also comply with ASTM E 152.

Provide stainless steel astragals complying with NFPA 80 for fire-rated assemblies and NFPA 105 for smoke control assemblies.

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

7. **Interior Door Hardware:** Provide the services of a certified door hardware consultant to prepare the door hardware schedule. Unless otherwise noted, interior doors shall include latch, hinges, door stops and door silencers. Provide closers and kick plates for fire-rated, corridor, stairway and high-use non-residential doors.
- a. **Hinges** - BHMA A156.1, Grade 1, 108 x 108 mm (4 1/2 x 4 1/2 inches) with non-removable pin or anti-friction bearing hinges.
  - b. **Locks and Latches** - For non-residential buildings use Series 1000, Operational Grade 1, Security Grade 2 for stairways, building entrances, corridors, assembly spaces, and other high use interior doors. Use Series 4000, Grade 1 for non-residential locations not using Series 1000 hardware. For residential buildings use Series 4000, Grade 2 for interior doors.
    - a) Mortise Locks and Latches - BHMA A 156.13, Series 1000, Operation Grade 1, Security Grade 2.
    - b) Bored Locks and Latches - BHMA A 156.2, Series 4000, Grade 1, or Grade 2.
  - c. **Exit Devices** - BHMA A 156.3, Grade 1. Touch bars shall be provided in lieu of conventional crossbars and arms. Use manufacturer's integral touch bars in aluminum storefront doors.
  - d. **Card Key Access** - Provide card key type access units for specialized entries. Provide lithium battery powered, magnetic stripe keycard locksets that are ANSI/BHMA A156.13, Series 1000, Grade 1, mortise or ANSI/BHMA A156.2, Series 4000, Grade 1, cylindrical locks, tamper resistant, UL listed with 25 mm (1 inch) throw deadbolt, 19 mm (3/4-inch) throw latch bolt, auxiliary dead-locking latch, and 68.75 mm (2-3/4 inch) backset.  
  
Provide hardware keying compatible with the existing base-wide keying system. Replacement interchangeable cores shall be compatible with the Best Lock system.
  - e. **Key Cabinet:** Provide a Key Cabinet with 30% over capacity.

**C1030 SPECIALTIES**

- 1. **Compartments, Cubicles, & Toilet Partitions:** FS A-A-60003. Provide toilet compartments at multi-fixture toilet rooms of Type I, Style B-Ceiling Hung, C-Overhead Braced, or F-Overhead braced-alcove. Reinforce panels to receive partition-mounted accessories. Urinal screens shall be FS A-A-60003. Type III, Style A, floor supported and wall hung or Style D, wall hung. Wall hung urinal screens shall be secured with continuous flanges to urinal screen and wall. Steel and Plastic toilet partitions shall have a recovered materials content of 20 to 30 percent. Chrome-plated or stainless steel door latches and coat hooks. Provide one coat hook per compartment door. Latches and hinges for handicapped compartments shall comply with UFAS & ADAAG.
- 2. **Toilet and Bath Accessories:** Provide toilet and bath accessories and install per ADAAG and manufacturers' requirements.
- 3. **Marker Boards and Tack Boards:** Provide porcelain enamel marker boards fused to a nominal 28 gauge steel sheet and tack boards of cork, with a tensile strength of at least 40 psi when tested according to ASTM F 152, with woven or vinyl covering.
- 4. **Identifying Devices:** All interior doors shall have an identifying device. All handicap accessible facilities shall utilize signage which meets current ADAAG requirements with regard to Braille, raised characters, finishes (contrast), size and mounting height. If room names are subject to frequent change, provide an interchangeable strip to be utilized to facilitate removal and replacement.

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

5. **Lockers:** Provide lockers to meet FS AA-L-00486 (Rev J), enameled steel with special bases.
6. **Shelving:** Provide steel shelving.
7. **Counters:** Provide solid plastic or plastic laminate counter tops and back splashes, AWI Custom grade.
8. **Cabinets:** Provide cabinetry and millwork items with associated accessories and hardware. Cabinetry shall be AWI premium or custom grade and have concealed hinges with adjustable standards for shelves.
9. **Casework:** Provide all built-in premanufactured metal cabinetry for specialized functions such as laboratories, libraries, medical and dental facilities. Casework shall comply with Mil Std 1691.
10. **Closets:** Provide premanufactured or millwork closets or prefabricated coat closets
11. **Fire Extinguisher Cabinets:** Provide fire extinguisher cabinets. Size and locate fire extinguisher cabinets to encase extinguisher as required by NFPA 10 & 101. Fire extinguishers will be provided by the Customer.
12. **Firestopping Penetrations:** Provide all sleeves, caulking, and flashing for firestopping penetrations.
13. **Entrance Floor Grilles and Mats:** Provide recessed pan or surface floor mats at main only or all building entrances.
14. **Ornamental Metal Work:** Provide ornamental metalwork
15. **Other Interior Specialties:** Motorized projection screen shall be wall or ceiling or above-ceiling mounting. Pull-down projection screens shall be provided in lieu of motorized projection screens as approved by the Activity.

## **C20 STAIR CONSTRUCTION**

Provide interior and exterior stair construction. Stair design, materials and construction shall comply with IBC, and applicable codes and standards, including NFPA 101. Provide refuge area at top of stair in accordance with applicable Americans with Disability Act Design Guide requirements.

## **C30 INTERIOR FINISHES**

### **C3010 WALL FINISHES**

Unless otherwise noted in the RFP, primary wall finishes shall be painted gypsum wall board. Provide fire resistive construction and finishes for fire separation between areas of the building in accordance with the latest adopted version of the IBC, and NFPA 101. Provide water resistant cementitious board at floors and walls of tubs and showers.

1. **Ceramic Tile:** Provide ceramic tile wall systems as defined in the Tile Council of America (TCA) handbook for ceramic tile installation and materials for the service requirements listed. Provide installation and materials in accordance with ANSI A108/A118 series standards, except do not use organic adhesives. Provide manufacturer's full range of colors and styles. Tile shall be a minimum of one grade above base grade. Coordinate with ceramic bath accessories for modularity. Include all trim pieces, caps, stops, and returns to complete installation.

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

2. **Wallcovering:** Vinyl wallcovering shall conform to ASTM F793, Category V Type II, 371 g to 624 g (13.1 to 22 ounces) total weight per square yard and width of 1370 mm (54 inches). Provide ASTM F793, Category VI, Type III, 624 g (22 ounces) and above to cover rough textured walls such as masonry. High performance fabric wallcovering shall be woven or non-woven Class A, fire resistive material, a minimum of 1219 mm (48 inches) wide, with a soil repellent finish and a minimum of 340 g (12 ounces) per square yard exclusive of backing. "Tackable" wall covering shall be "self-healing" from tack penetration through the covering into the substrate. Acoustical wallcovering shall be textured, woven or non-woven, Class A fire resistive material with an acrylic backing, a minimum of 1219 mm (48 inches) wide and a minimum of 454 g (16 ounces) per square yard. The material shall have an NRC rating of .15 on gypsum board in accordance with ASTM C423.

**C3020 FLOOR FINISHES**

Provide new flooring materials as required. All flooring materials, adhesives, finish coats, sealers and mortar materials shall meet or exceed EPA requirements for toxic substance content restrictions and air quality requirements; and shall meet or exceed fire protection requirements, such as smoke and flame spread requirements. When laying broadloom carpets and resilient flooring, use the widest sheet materials available to avoid or minimize the number and extent of seams. When seams are required, locate seams at infrequent traffic areas. Contractor is required to submit seam layout to Contracting Officer for approval prior to installation.

1. **Ceramic Tile:** Provide ceramic tile floor systems as defined in the Tile Council of America (TCA) handbook for ceramic tile installation and materials for the service requirements listed. Provide installation and materials in accordance with ANSI A108/A118 series standards, except do not use organic adhesives. Provide manufacturer's full range of colors and styles. Tile shall be a minimum of one grade above base grade.

Provide ceramic or porcelain tile with a minimum breaking strength of 202kg (300 pounds), ASTM C648, and a maximum absorption rate of 0.5%, ASTM C373. Tile shall have a minimum coefficient of friction (wet and dry) of 0.6, ASTM C1028.

2. **Resilient Flooring:** Shall meet or exceed applicable ADA horizontal requirements, and shall be installed per manufacturer's recommended methods and adhesives. Provide manufacturers full line of color and pattern selections, including multi-color patterns.

Linoleum Sheet or Tile Flooring shall be 2.5 mm (0.10 inch) gage; minimum 250 psi static load limit, ASTM F970; and with multi-color pattern and color extending throughout thickness, ASTM F2034, Type I. Resilient homogeneous vinyl sheet flooring shall be commercial quality, 2.0 mm (0.080 inch) overall gage, with minimum 1.6 mm (.066 inch) thick wear layer, protective urethane finish, ASTM F1303, Type II, Grade 1, Class A. Resilient vinyl composition tile shall be commercial grade, 3 mm (.125 inch) gage, FS SS-T-312B (1), Type IV, Comp. 1, Class 2, through pattern.

3. **Carpet:** Carpet manufacturer and installer shall be experienced, established and in good standing with the industry. Carpet, broadloom or tile, shall be installed per the Carpet & Rug Institute's recommendations. Carpet shall be tufted, textured loop, cut/loop or tip sheared, a minimum of 26 oz. face weight, minimum density of 6600, 100% premium branded yarn- or solution-dyed, Type 6 or 6.6 continuous hollow filament nylon. Carpet shall be multi-color and patterned for soil and wear hiding properties. Carpet shall have high performance backing warranted against zippering, edge raveling and delamination, be anti-static and anti-microbial. Carpet shall meet Flammability ratings; generate less than a 450 rating, ASTM E662; meet the Critical Radiant Flux Classification of not less than 0.45 W/sq. cm., ASTM E648. Where indicated

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

in the room requirements, provide attached polyurethane cushion or separate polyurethane cushion for double stick pad installations, ASTM 1667 and ASTM 3676.

- 4. Wall Base:** Provide porcelain or ceramic tile base for porcelain or ceramic tile floor. Provide solid, through color preformed rubber or vinyl base for carpeted/resilient flooring areas. Provide a sealant between base and floor finish in all wet areas.

### **C3030 CEILING FINISHES**

Unless otherwise noted in the room requirements, acoustical ceiling panels shall be 24 inch by 24 inch, with a minimum light reflectance of .75, Class A, flame spread 25 or less and smoke development of 50 or less, ASTM E84. Acoustical ceiling panels shall have minimum 60% recycled content and conform to ASTM E1264. Panels shall have a factory-applied standard washable painted finish or Type IV with factory-applied plastic membrane-faced vinyl, Form: 1, 2 or 3. Provide square edge except as noted.

Unless otherwise noted in the room requirements for entrance lobby, restrooms and showers, provide a painted, suspended gypsum board ceiling. Exposed structural systems shall be painted.

### **C3040 PAINTING**

All painting and coating materials shall be low VOC, comply with local air quality control laws and regulations; and conform to the Master's Painters Institute's (MPI) *Architectural, Interior Systems Manual* and the MPI's *Maintenance and Repainting Manual* recommendations for paint systems, surface preparation and applications.

Provide minimum of one prime coat and two finish coats. The prime coat shall not be combined with texture or other coatings. Seal and prime all surfaces to cover underlying stains or discoloration that may affect finish paint. Finish coats shall provide full coverage of undercoats and substrates. All walls and ceilings in wet area shall have semi-gloss paint. All wood or metal cased openings, door trims and casings, window trims and casing, and other finish trim shall have semi-gloss paint. All interior walls and ceilings shall have satin or eggshell finish. For previously painted surfaces, prime all surfaces to ensure compatibility of finish coats. Do not paint prefinished surfaces except as noted.

Provide Institutional Low Odor/Low VOC Latex paint or High Performance Architectural Latex systems as defined and approved by the MPI Systems Manual for the various substrates required to be painted.

**Paint/Color Selection:** Provide paint systems tested to "Detailed Performance Level" standard as defined by MPI. Paints shall be readily available for purchase in standard colors.

## **SECTION D. SERVICES**

**D10 CONVEYING** Elevators and Escalators - Not used

### **D20 PLUMBING**

Provide plumbing fixtures, appliances, and equipment complete and usable as required by Part 3. All plumbing fixtures, appliances and equipment, piping, valves, accessories, and appurtenances shall comply with International Plumbing Code (IPC) and all other applicable codes and standards, including energy, water conservation, and local activity regulations and standards.

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

- 1. Domestic Water:** Provide ASTM B 88 Type K or L copper tubing and fittings for pipe sizes 4 inches or smaller. Provide Type L tubing above ground with solder fittings. For buried piping, use Type K tubing with solder fittings, or Chlorinated polyvinyl chloride (CPVC) Plastic pipe, fittings, and solvent cement per ASTM D 2846/D 2846M for sizes 4 inches and smaller.

Provide mineral fiber insulation with vapor barrier on domestic water (hot and cold) supply and recirculation piping. Provide re-circulating pumps or instantaneous water heaters for hot water systems with fixtures greater than 100 ft from hot water source. Provide water hammer arrestors per PDI STD WH-210 as required for rapid water shut off scenarios. All water valves except for fixture shut off valves shall be ANSI B16.18 brass, full port ball type. All plumbing fixtures shall have separate shut off valves. All piping shall be concealed in walls, attic spaces, or in crawl spaces under floors. Provide access panels for valves behind walls. No under slab water piping is allowed. Fittings for annealed copper tubing shall conform to ANSI B16.22. Solder and flux shall be lead free. Exposed exterior piping is prohibited unless otherwise not practical. Provide identification for piping and equipment.

- 2. Wall Penetrations:** Piping which penetrates fire rated walls shall be completely sealed to maintain fire resistance integrity as required by Code. Penetrations through walls that are not fire rated shall be adequately supported and sealed. Pipe penetrations through exterior walls shall be sleeved, caulked with weatherproof sealant and provided with finish trim.

## **D2010 PLUMBING FIXTURES**

Fixtures shall be provided complete with fittings, and chromium-plated, or nickel-plated brass (polished bright or satin surface) trim. All fixtures, fittings, and trim, shall be from the same manufacturer and shall have the same finish. Access panels shall be provided for all bathtubs and showers, except at exterior and party walls and where tub or showers are back to back. Provide cleanouts in accordance with the plumbing code. Rotate or extend cleanouts required to facilitate maintenance and clearing of blockage in waste piping.

- 1. Faucets:** All faucets shall be brass construction, washerless type, with seals and seats combined in one replaceable ceramic disk valve cartridge designed to be interchangeable with all lavatories, bathtubs and kitchen sinks, or having replaceable seals and seats removable either as a seat insert or as a part of a replaceable valve unit. Faucets provided shall be of the same type and manufacturer throughout the facility, unless otherwise noted. Lavatory faucets shall be U.S. Environmental Protection Agency (EPA) Watersense® certified and labeled bathroom sink faucets.
- 2. Water Closets:** Water closets shall be in accordance with ANSI A112.19.2, with trim conforming to A112.19.5. Water closets shall be vitreous china and have an elongated bowl with trip lever, unlined tank, close coupled siphon jet, floor outlet with wax gasket, flange and an anti-siphon float valve. Provide white closed front seat and cover for private toilets and open front seat cover for public facilities. Water consumption shall be no greater than 1.6 gallon maximum per complete flushing cycle. Provide self-closing metering type flush valve on flush valve type water closets, unless electronic control is specified in Part 3. Maximum flush volume shall not exceed 1.28 gallon per flush (GPF) (4.8 Liter per flush (LPF)) for single function flush valves. Dual function flush valves shall provide a flush of 0.8 to 1.6 GPF (3.0 to 6.0 LPF) or 1.28 GPF (4.8 LPF) average for 2 low volume flushes and one high volume flush. Tank type water closets shall be U.S. Environmental Protection Agency (EPA) Watersense® certified and labeled toilets.
- 3. Urinals:** Provide U.S. Environmental Protection Agency (EPA) Watersense® certified and labeled ceramic-type urinals.

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

Non Water Use Urinals: ASME A112.19.2, white vitreous china, wall-mounted, wall outlet, non-water using, integral drain line connection, with sealed replaceable cartridge or integral liquid seal trap insert. The urinal and trap assembly shall maintain a sufficient barrier of a biodegradable immiscible liquid to provide the trap seal and inhibit the backflow of sewer gases. For urinals that use a replaceable cartridge, provide four additional cartridges for each urinal installed. Provide an additional quart of biodegradable liquid for each urinal installed. Provide ASME A112.6.1M concealed chair carriers. Installation and testing shall be in accordance with the manufacturers' recommendations. Drain lines that connect to the urinal outlet shall not be made of copper tube or pipe. Urinal design and installation shall be ADA compliant. Slope the sanitary sewer branch line for non-water use urinals a minimum of 1/4-inch per foot. Manufacturer shall provide an operating manual and on-site training for the proper care and maintenance of the urinal.

4. **Lavatories:** Unless otherwise specified by Part 3, lavatories shall be integral to the vanity countertops. Each lavatory shall be provided with hot and cold water tempered by means of a mixing valve or combination faucet.
5. **Sinks:** ASME/ANSI A112.19.3M sink, 20 gage stainless steel with integral mounting rim, minimum dimensions of 840 mm (33 inches) wide for two compartment or 560 mm (21 inches) wide for one compartment by 560 mm (21 inches) front to rear, with ledge back and undersides coated with sound dampening material.
6. **Water Coolers:** ARI 1010, wall-mounted, bubbler style, air-cooled condensing unit, 4.20 mL per second (4.0 gph) minimum capacity, stainless steel splash receptor, double wall heat exchanger, and all stainless steel cabinet. Install in accordance with the manufacturers instructions.
7. **Showers:** Provide U.S. Environmental Protection Agency (EPA) Watersense® certified and labeled showerheads connected to concealed pipe connected to copper alloy single control type mixing valve with front access integral screwdriver stops. Anchor the mixing valves and the pipe to each showerhead in wall to prevent movement. Unless otherwise specified by Part 3, showers shall be supplied with water at a temperature no more than 110°F by means of a pressure balance, tempering or mixing valve.
8. **Service sinks:** ASME A112.19.1M, white enameled cast-iron or ASME A112.19.2M white vitreous china, wall mounted and floor supported by wall outlet cast-iron P-trap, minimum dimensions of 560 mm (22 inches) wide by 457 mm (18 inches) front to rear with 230 mm (9 inch) splashback, and stainless steel rim guard. Provide ASME A112.18.1M copper alloy back-mounted combination faucets with vacuum breaker and 20 mm (0.75 inch) external hose threads
9. **Mop Sinks:** Pre-cast terrazzo or ASME A112.19.2M white vitreous china floor-mounted mop sink, 914 mm x 914 mm x 305 mm (36 inches x 36 inches x 12 inches). Terrazzo shall be made of marble chips cast in white Portland cement to a compressive strength of not less than 25 mPa (3625 PSI) 7 days after casting. Provide brass body drains with nickel bronze strainers cast integral with mop sink. Provide stainless steel rim guard for mop sink. Provide chrome-plated exposed hot and cold water faucets ASME A112.15.M wall-mounted copper alloy faucets swing spout with 20 mm (3/4 inch) hose connection, vacuum breaker, and pail hook. Provide mop hanger on wall above sink suitable for four mops.
10. **Laundry Sinks:** ANSI Z124.1, plastic, two compartment, minimum dimensions of 1016 mm wide by 533 mm (40 inches wide by 21 inches) front to rear, with floor-supported steel mounting frame secured to wall. Provide ASME A112.18.1M copper alloy centerset faucets, swing spout with aerator, and stainless steel drain outlets with cup strainers, and 40 mm (1.5 inch) adjustable P-trap with drain piping to vertical vent stack.

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

- 11. Emergency Eyewash:** ANSI Z358.1, wall-mounted self-cleaning, non-clogging eye and face wash with quick opening, full-flow valves, stainless steel eye and face wash receptor. Provide copper alloy control valves. Pressure-compensated tempering valve is required for emergency fixtures, with leaving water temperature setpoint adjustable throughout the range 15.5 and 35 degrees C (60 to 95 degrees F) unless cold water supply meets temperature criteria.

**D2020 DOMESTIC WATER DISTRIBUTION**

- 1. Natural Gas or Propane Fired Storage Water Heaters:** Provide high efficiency storage type natural gas or propane fired water heaters per ANSI Z21.10.1 or ANSI Z21.10.3 meeting AGA requirements. Unit efficiency shall meet or exceed that listed in the Title-24 Standards. Water heaters shall be equipped with glass-lined steel tanks, minimum R-15 polyurethane foam insulation, replaceable anodes, and adjustable range thermostat to allow hot water settings between 43 and 71 degrees C (110 and 160 degrees F). Water heater warranty shall be a minimum of 10 years. Provide vent in accordance with NFPA 54. Provide low NOx burners that meet SCAQMD requirements. Install in accordance with manufacturer's instructions and the code. Where earthquake loads are applicable, water heater supports shall be designed and installed for seismic forces in accordance with the International Building Code.
- 2. Electric Water Heaters:** Provide electric water heaters with double heating element per UL 174. Unit efficiency shall meet or exceed that listed for FEMP or ENERGYSTAR, or as listed in ASHRAE 90.1, whichever is greatest. Water heaters shall be equipped with glass-lined steel tanks, high efficiency type, insulated with polyurethane foam insulation, replaceable anodes, and adjustable range thermostat to allow hot water settings between 43 and 71 degrees C
- 3. Domestic Water Boilers:** Boilers shall be designed, tested, and installed per ASME CSD-1 (Controls and Safety Devices) and ASME BPVC (Boiler and Pressure Vessel Code). The boiler shall meet the requirements of the UL 795, NFPA 85, ANSI Z83.3, and ASME CSD. Boilers must be certified by Naval Personnel or a contractor approved by the Contracting Officer.

**D2030 SANITARY WASTE & VENT**

All new sewers below concrete slab shall be solid core, minimum schedule 40 (DWV Type), ABS in accordance with ASTM 2661. New waste and vent piping above floor shall be Schedule 40 PVC (DWV Type) ASTM 2665 or ABS ASTM 2661. Use of ABS plastic pipe shall conform to the IBC and IPC. Provide pipe sizing, configurations, and cleanouts as required by the IPC. Cellular core plastic pipe is not allowed. SOVENT systems are not allowed.

**D2040 RAINWATER DRAINAGE**

Below concrete slab shall be solid core, minimum schedule 40 (DWV Type), ABS in accordance with ASTM 2661. Above floor shall be cast iron hubless, or hub and spigot, or Schedule 40 PVC (DWV Type) ASTM 2665 or ABS ASTM 2661 as indicated in Part 3. Pipe materials shall conform to the IBC and IPC. Provide pipe sizing, configurations, and cleanouts as required by applicable codes and standards.

**D2090 OTHER PLUMBING SYSTEMS**

**Natural Gas Piping Systems:** Exterior above grade natural gas piping shall be schedule 40 galvanized steel pipe with threaded fittings and joints. Underground exterior gas piping shall be polyethylene pipe that satisfies the requirements of NFPA 54, ASTM D2513-01, and ASME B31-

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

8. Provide warning tape at 12 inches below grade directly above buried gas pipes. Below grade metal gas piping is prohibited. Interior gas piping shall be ASTM A 53, schedule 40 black steel with ASME B16.3 threaded fittings and joints. The use of semi-rigid tubing and flexible connectors for gas equipment and appliances is prohibited except for final connections to the equipment and appliances where they shall be provided. Provide flexible gas connections in accordance with ANSI Z21.45 and not more than 40 inches long. Provide accessible gas service with shutoff valve for all equipment. Gas piping shall conform to NFPA 54 and shall be pressure tested in accordance therewith. Gas piping is considered a fragile utility in the content of UFC 4-010-01, *DOD Minimum Antiterrorism Standards for Buildings*.

**D30 HEATING, VENTILATION AND AIR CONDITIONING (HVAC) SYSTEMS:**

The HVAC systems shall comply with the latest edition of the International Mechanical Code, International Plumbing Code, ASHRAE Standards, National Electrical Code, National Fire Protection Association Publications, International Building Code, and California Title 24 or ASHRAE 90.1 energy efficiency standards (the more stringent of the two) unless otherwise specified in Part 3. All equipment, appliances, ductwork and accessories shall comply with applicable codes and standards. For projects located in California, also comply with California Energy Commission (CEC) efficiency rating requirements as stated in Ca. AB 970 Title 24. The Contractor shall certify that the installation is in conformance with the applicable codes and standards at the completion of the contract, prior to final invoice being processed and final acceptance.

1. **Equipment Clearance:** Provide working space around all equipment. Provide all required fittings, connections and accessories required for a complete and usable system. All equipment shall be installed per the manufacturer's recommendations. Where the word "should" is used in manufacturer's instructions, substitute the word "shall".
2. **Material and Equipment Qualifications:** All materials and equipment shall have been in satisfactory commercial or industrial use for 2 years prior to the bid opening. The 2-year use shall include applications of equipment and materials under similar circumstances and of similar size. The product shall have been for sale on the commercial market through advertisements, manufacturer's catalogs, or brochures during the 2-year period.
3. **Motors:** Single-phase fractional-horsepower alternating-current motors shall be high efficiency types corresponding to the applications listed in NEMA MG 11. Select polyphase motors based on high efficiency characteristics relative to the applications as listed in NEMA MG 10. Additionally, all polyphase squirrel-cage medium induction motors with continuous ratings shall meet or exceed energy efficient ratings per Table 12-10 of NEMA MG 1. Provide controllers for 3-phase motors rated 0.75 kW (1 hp) and above with phase voltage monitors designed to protect motors from phase loss and over/under-voltage. Provide means to prevent automatic restart by a time adjustable restart relay. For packaged equipment, the manufacturer shall provide controllers including the required monitors and timed restart. Provide reduced voltage starters for all motors 25 hp and larger.
4. **Equipment Support:** Provide housekeeping pads and vibration isolators under all floor-mounted equipment.
5. **Coatings:** When required in Part 3, provide chiller and air handler coils with copper tube/copper fin coil construction or immersion applied, baked phenolic or other approved coating. Field applied coatings are not acceptable. Mechanical equipment casings shall have painted finishes that pass a salt-spray test conducted per ASTM B117 for duration of at least 500 hours.

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

6. **Equipment Insulation:** Provide insulation on all chilled water equipment. Insulate hot and chilled water pumps and equipment as suitable for the temperature and service in rigid block, semi-rigid board, or flexible unicellular insulation to fit as closely as possible to equipment. Provide vapor retarder for chilled water applications.
7. **Acoustical considerations:** Noise levels in all areas served (supply, return, and exhaust) by a mechanical system shall comply with ASHRAE Design Guidelines for HVAC related background sound in rooms as indicated in the lasted ASHRAE Fundamentals Handbook. The RC-rating method shall be utilized.

**D3020 HEAT GENERATING SYSTEMS**

1. **Boilers:** Boilers shall be designed, tested, and installed per ASME CSD-1 (Controls and Safety Devices) and ASME BPVC (Boiler and Pressure Vessel Code). The boiler shall meet the requirements of the UL 795, NFPA 85, ANSI Z83.3, and ASME CSD. Do not provide watertube boiler(s) for hydronic heating when size permits otherwise. Provide insulated boiler stack in accordance with manufacturer's recommendations and conform to NFPA 211 or provide pre-manufactured, multi-wall stacks complying with NFPA 54 or NFPA 58 and UL-listed. Low pressure boilers shall be equipped with one or more pressure relieving devices, adjusted and sealed to discharge at a pressure not to exceed the maximum allowable working pressure of the boiler. The combined capacity of these devices shall be such that with the fuel burning equipment installed and operating at maximum capacity, the pressure cannot rise more than 5 psi for steam boilers or 10% for water boilers above the maximum allowable working pressure of the boiler. Pressure relieving devices shall be installed as required by the referenced code, be ASME stamped and rated, and shall be installed with the valve spindle in the vertical position. Provide with manual lifting device for periodic testing. Boilers shall comply with the local air quality regulations. Boilers shall be equipped with pressure and temperature gauges as required for proper maintenance and operation. Thermometers shall also be provided at the inlet and exit of the boiler, and shall be visible to the operator from the operating area.
2. **Furnaces:** UL-listed, factory assembled, self contained, forced circulation, furnace. Provide electronic ignition system. Unit shall be design certified by AGA, GAMA efficiency rating certified, for gas furnaces and NFPA 31 for oil furnaces. Provide with cooling coil as necessary. Furnaces shall comply with the local air quality regulations.

**D3030 COOLING GENERATING SYSTEMS**

1. **Chillers:** Air-cooled chillers shall be type indicated in Part 3 and meet the requirements of ARI 550/590-98. Provide control panel with the manufacturers' standard controls and protection circuits. If DDC system is required in project, provide a control interface for remote monitoring of the chiller's operating parameters, functions and alarms from the DDC control system central workstation. Provide complete start-up and operational testing of chiller equipment.
2. **Direct expansion systems:** Provide units factory assembled, designed, tested, with ducted air distribution and rated in accordance with ARI 210/240 or ARI 340/360. Refrigerant piping size shall be per the manufacturer's recommendations. Insulate refrigerant piping suction lines and condensate drain.
3. **Refrigerants:** The use of Ozone Depleting Substances (ODS) as well as the qualifications and credentials of personnel servicing equipment that contains ODS is restricted. Refrigerants shall have an Ozone Depletion Factor (ODF) of 0.055 or less. The ODF shall be in accordance with the

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

"Montreal Protocol on Substances That Deplete the Ozone Layer", September 1987, sponsored by the United Nations Environment Program.

**D3040 DISTRIBUTION SYSTEMS**

1. **Ductwork:** All ductwork shall be provided in accordance with the latest SMACNA guidelines. Flexible duct lengths shall not exceed 6 feet. Provide galvanized sheet metal ducts except for special exhaust systems and the following:
  - a. For fume hood exhaust, kitchen hood exhaust, and dishwasher exhaust, provide stainless steel ductwork.
  - b. For shower area exhausts, provide aluminum or stainless steel ductwork and sloped to drain provisions. After the shower exhaust is mixed with a volume of general exhaust air equal to 200% of the shower exhaust rate, standard galvanized construction may be used.
  - c. Internal insulation-lined ductwork is prohibited in all areas. For ductwork located exterior to the building, provide externally insulated systems with sheet metal cladding. Provide external thermal insulation for all ductwork. Insulate ductwork in concealed spaces with blanket flexible mineral fiber. Insulate ductwork in Mechanical Rooms and exposed locations with rigid mineral fiber insulation. Provide insulation with factory applied all-purpose jacket with integral vapor retarder. In exposed locations, provide a jacket with white surface suitable for painting. Flame spread/smoke developed rating for all insulation shall not exceed 25/50. Minimum insulation thickness shall be the minimum thickness required by ASHRAE 90.1. Insulate the backs of all supply air diffusers with blanket flexible mineral fiber insulation.
  - d. The ductwork shall be sealed with an approved duct sealer and in accordance with SMACNA standards. If leakage testing is indicated in part 3, the duct leakage shall not exceed 2%.
  - e. Provide manual volume dampers in each branch take-off from the main duct to control air quantity. Dampers shall conform to SMACNA DCS. Dampers shall be installed in accessible locations.
2. **Fire Dampers:** Fire dampers shall be rated per UL 555. Fire dampers shall be dynamic type rated for closure against a moving airstream. Provide fire dampers that do not intrude into the air stream when in the open position.
3. **Piping:**
  - a. Provide insulated, steel piping for sizes 4 inches and larger and insulated copper piping for sizes less than 4 inches for water supply and return piping to serve the HVAC equipment throughout the facility.
  - b. Provide system flushing and start-up for water systems.
  - c. Oil piping: ANSI/ASTM A53 or A106 piping with associated ASME fittings or ASTM B88, type L or M copper tubing with ASME B16.26 flared fittings or compression type fittings.
4. **Exhaust Fans And Ducts:**

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

- a. **General:** Exhaust fans shall be sized to move the volume of air required to comply with International Mechanical Code for the areas requiring exhaust.
  - b. **Bathroom, restrooms and Utility Room Exhaust Fans:** Exhaust fans shall be sized to give not less than 10 air changes per hour in the space to be ventilated. Fans shall have a maximum sound level of 3 sones and be separately switched from light.
  - c. **Flues:** When required, provide new Type B, U.L. listed, double wall flues. Flue installation shall be in accordance with the International Mechanical Code.
5. **Air handling units:** Modular construction, double wall air handling units with minimum of 25 mm (1 inch) casing insulation. Provide ARI 430 certified fans and ARI certified coils. Provide stainless steel, positive draining condensate drain pan. For 100% outside air units provide capability for cooling, heating, dehumidification and reheat.

**D3050 TERMINAL AND PACKAGE UNITS**

1. **Unit ventilators:** Unit shall be factory assembled unit ventilator capable of up to 100% outdoor air ventilation and UL-listed.
2. **Unit heaters:** ANSI Z83.8 and AGA label. Equip each heater with individually adjustable package discharge louver. Provide with thermostat.
3. **Fan coil units:** UL-Listed, factory assembled and tested fan coils, ARI 440 and ARI certified.
4. **Packaged units:**

Factory packaged rooftop units in accordance with ARI 430 and suitable for outdoor installation. Provide with manufacturer's roof curb.

Packaged through wall units shall be factory assembled air conditioner or heat pump and rated in accordance with ARI 310 or ARI 380 and ARI certified. Unit shall include heat and operate under the standard unit controls. Units shall be designed to allow ease of maintenance by use of a wall sleeve. Units shall have internal condensate removal (condensate shall not be externally drained).

**D3060 CONTROLS AND INSTRUMENTATION**

1. **General:** Provide stand-alone or distributed direct digital controls, as required in Part 3.
2. **Distributed Direct Digital Controls (DDC):** DDC hardware shall be UL-916 rated. Use controllers in a distributed control manner. Controllers shall be stand alone with an internal clock and modem. The total number of I/O hardware points shall not exceed 48 in any controller. Provide sufficient memory for each controller to support required control, communication, trends, alarms, and messages. Provide communications ports for controller to controller, on-site interface, remote workstation interface, and telecommunications interface. When providing a partial DDC system or connecting to an existing DDC system, provide a laptop computer with all necessary software for user interface.

**Replace Siding – Bldg 405  
Naval Support Activity, Mechanicsburg, Pennsylvania  
Work Order Number 1350926**

**D3070 SYSTEMS TESTING AND BALANCING**

All HVAC water and air systems, both new and retrofit, shall be TABed in accordance with NEBB or AABC standards. As part of any TAB air balancing effort, acceptable air quantity variations shall be 0 to –10% for exhaust systems and 0 to +10% for supply air systems.

**D40 FIRE PROTECTION**

Provide new or extend existing Automatic Fire Sprinkler systems, Smoke and Heat detection systems, Fire Alarm and Mass Notification systems as required. The work for fire sprinklers, fire alarm, smoke detection, and heat detection shall be provided by contractors licensed to perform such work.

**Project Requirements:** Prior to the start of design, the Designer of Record shall meet with the Government's Fire Protection Engineer to determine the extent and types of fire protection required.

**D4010 FIRE ALARM AND DETECTION**

Fire alarm system shall include manual stations, system smoke detectors, duct smoke detectors, heat detectors, audio/visual alarms, connection to basewide fire alarm monitoring, electrical supervision of fire pump controllers, and electrical supervision of all sprinkler system alarm and supervisory devices as required.

**D4020 FIRE SUPPRESSION WATER SUPPLY AND EQUIPMENT**

The water supply information is provided for bidding purposes. The design point of connection to existing water supply shall require the approval of the Contracting Officer. The FPE DOR shall conduct additional flow tests after contract award prior to any design submissions. Tests shall be coordinated through the Contracting Officer.

**D4040 SPRINKLERS**

Areas subject to freezing shall be provided with a dry pipe system.

**D50 ELECTRICAL**

**D5010 ELECTRICAL SERVICE & DISTRIBUTION**

Provide interior electrical wiring, fixtures, switches, outlets, and apparatus in accordance with applicable codes and standards. The electrical system shall conform to NFPA 70. Power and lighting circuits shall be separate.

- 1. Wiring:** All wiring shall be in electrical metal conduits and shall be concealed except in the industrial spaces and at locations indicated in Part 3. No conductors shall be smaller than No. 12 AWG, copper wires. Wiring below slab or underground shall be in Schedule 40 PVC with ground wire. Exposed conduits on the exterior of the building are prohibited. Provide a ground conductor for each circuit; conduits shall not be used for grounding. Use of cable assemblies Types AC, MC, or MI and flat conductors are prohibited. Circuit breakers shall be bolt-on type. Series rated circuit breakers and fusible panelboards shall not be used.
- 2. Outlet Circuits:** Lighting and convenience outlets shall be on separate circuits. Install GFI protected receptacles at all wet or damp areas. Location of outlets shall be as required by

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

applicable codes and standards. Provide extra outlets for maintenance and service staffs in spaces such as corridors, hallways and other public spaces as identified below. All exterior outlets shall be on separate circuits, shall be GFI protected, and equipped with a cover to prevent accidental water infiltration into the devices.

In addition to the location requirements specified by NFPA 70, locate general purpose and dedicated outlets in accordance with the following:

- a. Mechanical equipment: Provide receptacle within 7.6 m (25 ft) of mechanical equipment on the interior and exterior of buildings.
- b. Office, staff support spaces, and other workstation locations: One receptacle for each workstation with a minimum of one for every 3050 mm (10 ft) of wall space. When less than 3500 mm (10 ft) of wall at the floor line, provide a minimum of two receptacles spaced appropriately to anticipate furniture relocations. Limit loads to a maximum of four workstations per 20 amp circuit. See Appendix C, Table C1 for workstation load data.
- c. Conference rooms and training rooms: One for every 3.6 m (12 ft) of wall space at the floor line. Ensure one receptacle is located next to each voice/data outlet. Provide one receptacle above the ceiling to support video projection device. Extend circuit to wall location for connection to motorized screen. When it is expected that a conference room table will be specifically dedicated to floor space in a conference room, locate a floor-mounted receptacle under the table. This receptacle may be part of combination power/communications outlet.
- d. Provide power outlets throughout the building to serve all proposed equipment, including government furnished equipment, and allow for future reconfiguration of equipment layout. Provide power connections to all ancillary office equipment such as printers, faxes, plotters, and shredders. Provide dedicated circuits where warranted.
- e. In each telecommunications room provide a dedicated 20 amp circuit with a receptacle adjacent to each rack or backboard for each of the following:
  - 1) CCTV for training systems
  - 2) CCSTV for security systems
  - 3) CATV
  - 4) Voice systems
  - 5) Data systems.
- f. Provide dedicated receptacles as required throughout the facility for television monitors. These outlets will typically be located at the ceiling level for wall mounted television monitors.
- g. Provide dedicated receptacles as required throughout the facility for tape players and disc players.
- h. Corridors: One every 15 m (50 ft) with a minimum of one per corridor.
- i. Janitor's closet and toilet rooms: One GFI receptacle per closet. Provide GFI receptacles at counter height for each counter in toilets such that there is a minimum of one outlet for each two sinks.

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

- j. Space with counter tops: One for every 1.200 m (4 ft) of countertop, with a minimum of one outlet. Provide GFI protection of outlets when located within 1.8 m (6 ft) of plumbing fixtures.
  - k. Building exterior: One for each wall, GFI protected and weatherproof.
  - l. Kitchen non-residential: One for each 3.05 m (10 ft) of wall space at the floor line. Provide GFI protection when located within 1.8 m (6 ft) of plumbing fixture.
  - m. Child occupied spaces (including toilets): One for every 3.6 m (12 ft) of wall space. Use child safety type such as those that require rotating an integral surface cover plate to access current. Removable caps and plugs are not acceptable.
  - n. All other rooms: One for every 7.6 m (25 ft) of wall space at the floor line. When 7.6 m (25 ft) or less of wall at the floor line exists in a room, provide a minimum of two receptacles spaced appropriately to anticipate furniture relocations.
  - o. Special purpose receptacles: Designer of Record must coordinate with the user to provide any special purpose outlets required. Provide outlets to allow connection of equipment in special use rooms.
3. **Service Entrance Equipment:** When a switchboard or switchgear is required, the Designer of Record shall utilize UFGS Section 26 23 00, *Switchboards and Switchgear*, for the project specification, and shall submit the edited specification section as a part of the design submittal for the project.

**D5020 LIGHTING & BRANCH WIRING**

- 1. **Lighting Fixtures:** All lighting fixtures shall be energy conservation compact fluorescent except where indicated by Part 3.
  - a. **Fluorescent Fixtures for Administrative and Commercial Spaces:** For offices, commercial and administrative spaces and facilities provide high efficiency ballast, and instant or rapid start recessed fluorescent fixtures.
  - b. **Three-Way and Four-Way Switches:** Provide three-way or four-way switching of light fixtures as necessary to facilitate movement between adjacent spaces to allow efficient energy management.
- 2. **Exterior Lighting Fixtures for Large Open Areas:** Exterior lighting fixtures for large open areas such as parking lots, streets and playgrounds shall be energy efficient High-Intensity Discharge (HID) or compact fluorescent fixtures and shall comply with local regulations regarding low lighting levels to avoid light pollution.
  - a. **Photocell Overriding Switch:** Provide photocell-overriding switch for all outdoor light fixtures.

**D5030 COMMUNICATIONS & SECURITY**

- 1. **Telecommunications Systems:** Provide a horizontal distribution system including, but not necessarily limited to, all wiring, pathway systems, connector blocks, protectors for all copper service entrance pairs, terminators for all fiber optic cables, outlet boxes, telephone jacks, and data jacks cover plates in accordance with EIA/TIA standards. Provide Category 6 UTP telephone premise wiring where telephones are required.

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

2. **Public Address Systems:** Provide a Public Address system with speakers in all locations identified in Part 3.
3. **Intercommunications Systems:** Provide an Intercommunication System to allow two-way communications between all locations identified in Part 3.
4. **Television Systems:** Provide television systems to the extent specified in Part 3. Coordinate with the local Cable Company, Local users and Local Authority at the Activity for other specific requirements. The interior cable outlets and wiring shall be complete and ready for use. Wiring shall not be run exposed on any surface of the building.
5. **Security Systems:** Provide an Intrusion Detection System (IDS) to sense all perimeter doors and windows and the interior volume in at least two locations. System shall have 90-minute battery back-up and annunciate both locally and at the Base Security Office via a telephone dialer. System shall have entry/exit timer. Provide wall mounted keypad control at two locations.

**D5090 OTHER ELECTRICAL SERVICES**

1. **Transient Voltage Surge Suppression (TVSS):** Provide TVSS in accordance with UFC 3-500-10N.
2. **Emergency Generators:** When an emergency generator is required, the Designer of Record shall utilize UFGS Section 26 32 13.00 20 for the project specification, and shall submit the edited specification section as a part of the design submittal for the project.
3. **Automatic Transfer and Bypass/Isolation Switches:** When an Automatic Transfer Switch is required, the Designer of Record shall utilize UFGS Section 26 36 23.00 20 for the project specification, and shall submit the edited specification section as a part of the design submittal for the project.
4. **Uninterruptible Power Supply (UPS) System:** When a UPS system is required, the Designer of Record shall utilize UFGS Section 26 32 33.00 20 and shall submit the edited specification section as a part of the design submittal for the project.
5. **400 Hertz Systems:** The Designer of Record shall utilize UFGS Section 26 32 26 or 26 35 43 for the project specification, and shall submit the edited specification section as a part of the design submittal for the project.

## **SECTION E. EQUIPMENT AND FURNISHINGS**

### **E10 EQUIPMENT**

**Equipment and Appliances:** Provide appliances and equipment to fulfill the work for Part 3. Whenever possible, all appliances and equipment provided for the facilities in the contract shall be by the same manufacturer and shall be the current model available at the time of proposals. Discontinued makes and models are prohibited. All appliances and equipment shall comply with applicable Energy Star efficiency rating requirements and shall be rated as high efficiency models. Appliances and equipment on California projects shall comply with California Title 24 and be rated as high efficiency. All appliances shall be of the same manufacturer and shall be the same, or similar in color. Submit catalog information for approval by the Contracting Officer prior to purchasing, delivery and installation of the appliances at the job site. Equipment and appliances such as dishwashers, ice machines with drains, garbage disposers, and ovens/ranges are not considered FF&E.

### **E20 FURNISHINGS**

#### **E2010 FIXED FURNISHINGS**

**Window Treatments:** Unless otherwise specified in Part 3 window treatments shall be as follows: Horizontal blinds shall be aluminum, washable, cleanable, installed in all windows except for bathroom, kitchen, and utility windows. Horizontal blinds shall be installed at all sliding glass doors. All blinds shall be screwed or securely anchored to wood backing and shall be inside mounted except at sliding glass door. Submit catalog information for approval by the Contracting Officer. Blinds shall have 1-inch aluminum slats, mounted within window opening. Blinds shall have separate tilt and height controls, metal truck, head channels, wand, and valance. Solar shades shall be woven polyester/resin coated fiberglass or polyester fabric with fade resistance and dimensional stability; with clutch or motorized roller operation. Roller shades shall be screwed or securely anchored to wood backing and shall be inside mounted except at sliding glass door. Submit catalog information for approval by the Contracting Officer. Blinds shall have prefinished steel or aluminum roller housing and valance. Window treatments are not considered FF&E.

#### **E2020 MOVABLE FURNISHINGS**

- 1. Furnishings, Fixtures and Equipment (FF&E):** FF&E shall include furniture, shop equipment, audiovisual equipment (excluding motorized screens), and specialty equipment. Weapon racks, drying cages, motorized projection screens and lockers are not considered FF&E. FF&E shall be fully integrated with the building system.

Design and provide FF&E for all areas as developed during client programming. Design an FF&E package and prepare supporting plans and procurement data in accordance with the General Interior Design Requirements UFC 3-120-10.

The contractor shall have an NCIDQ certified Interior designer not affiliated with any furniture dealership prepare both the SID and FF&E package and participate in design charettes to develop the building floorplan. The designer must have previous experience in project types similar to this contract. As required, the contractor shall obtain services of equipment specialists to specify the audiovisual, shop, or specialty equipment. Equipment specialists shall not have any affiliation with the product specified.

The contractor's Interior Designer shall be responsible for specifying product and installation for all FF&E for the designated facilities built under this contract, using NAVSUP Blanket Purchase

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

Agreements, GSA federal supply schedules or other government supply sources and complying with priorities found in FAR Part 8.404.

All fixed and movable furnishings selections shall be coordinated with Sections C10, "Interior Construction" and C30, "Interior Finishes." The FF&E shall be fully integrated with the building systems as well as the design and construction schedule.

As an option to the contract/task order, the contractor shall be authorized to procure all FF&E with separate funding.

- a. **FF&E Package:** Provide the FF&E loose furnishings package from Government supply sources schedules according to Federal Acquisition Regulations, to include but not limited to, systems and modular furniture, training and conference furniture, seating, tables, artwork, window covering, specialty furniture and equipment, and accessories. NAVSUP Blanket Purchase Agreements (BPA) must be used whenever possible.

The Government will provide separate funding for procurement of the FF&E package. Upon receipt of required funding, the Contractor shall be authorized by the Contracting Officer as an option to contract/task order to procure all FF&E using predominately negotiated price schedules from GSA or other Federal contracts. The amount of the modification will be the actual cost of these items from the Federal price schedules or NAVSUP BPAs, including any freight and installation charges from the furniture supplier as well as the contractor's FF&E Handling and Administration Rate (HAR). The HAR includes all of the prime contractor's effort related to storage, coordination, handling, administration of subcontractors, and all other associated costs and profit for the procurement of FF&E. The prime contractor will propose in the contract/task order solicitation the FF&E HAR. The contractor's proposed HAR may not exceed 5% of the total FF&E costs, as noted on the bid schedule. No other charges, expenses, fees, or other markups will be authorized.

When the FF&E package is complete and accepted by the Government, the procurement option will be awarded based on the specific line items in the final package. The Government's Interior Designer will approve the final FF&E submittal. The FF&E package will be presented to the Project Manager and they will expect the Contractor to procure the FF&E exactly as specified and approved by the government Interior Designer.

Two copies of all ordering documentation shall be provided to the Contracting Officer including purchase orders and warranty information. The Contractor shall take maximum advantage of all exemptions from State and Local taxation authorities whether available to it directly or available to the contractor based on an exemption afforded the Government. The responsibility for paying applicable taxes rests with the contractor. Any state and local taxes applicable to the FF&E option will be included with the FF&E Dealer quote, if applicable.. Under regulation 1521, Construction Contractors performing work for the US Government are not required to charge the Government sales tax for the purchase of furniture. Any items purchased as building materials such as carpet are taxable. FF&E items are subject to the Buy American Act. The contractor shall not be required to secure any additional bond for the award of the FF&E option item. Any performance and payments bonds required for the FF&E option will be included in the prim contractor's FF&E HAR.

- b. **Procurement and Installation:** Upon completion and Government acceptance of the design, using the Best Value Determination (BVD) method in association with the Government's Interior Design Representative, the Government will award the FF&E procurement option for the Contractor to purchase the FF&E package. The Government's Interior Designer shall provide a certification to the Contracting Officer that the process was completed. The Design-Build Contractor will receive a letter of authorization from the Contracting Officer citing the

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

name of the furniture dealer and other information to use when accessing the Government supply sources. The FF&E package includes the installation of all furniture and furnishings as specified in the FF&E package. The installation dealer specified in the FF&E package will receive, store, if required, transport to the project site, off load, inside deliver, unpack, assemble, place/install, clean, if required, and dispose of all the trash for all furniture and furnishings. The Contractor's Interior Designer will be responsible for specifying installation services and warehousing, as required, for all collateral equipment. It is the Contractor's responsibility to coordinate the building completion, occupancy, and furniture installation dates with the installation dealer specified in the FF&E package. Any costs associated with storing or delaying furniture shipments is the responsibility of the Construction Contractor. Davis Bacon wages do not apply to the FF&E installer accessed through Government supply sources. The Contractor should anticipate providing a deposit of between 30% and 50% of the furniture costs when placing their order.

All movable furnishings shall be installed in accordance with the manufacturer's instructions and warranty requirements. All movable furnishings shall be level and aligned and all doors, drawers and accessories shall be level and aligned to open, close and otherwise operate smoothly and securely. All systems furniture shall be installed by the systems furniture manufacturer's dealer of record and not by the General Contractor.

- c. **Furnishings for Special Functions:** Contractor shall coordinate shop equipment, audiovisual equipment, and specialty equipment, with the building systems.

**SECTION F. SPECIAL CONSTRUCTION AND DEMOLITION**

**F1010 SPECIAL STRUCTURES**

**1. PRE-ENGINEERED BUILDINGS**

Provide the design and installation in accordance with the UFC 3-100-10, *Architecture* and UFC 3-300-10N, *Structural Engineering*.

- a. **Design Requirements** - The metal building manufacturer shall have AISC FCD, category MB certification. The Metal Building System design shall be in accordance with the Metal Building Manufacturers Association (MBMA) *Metal Building Systems Manual*. All structural design shall comply with the provisions of Section B10, "Superstructures", above.
- b. **Additional Roof Design Requirements** - Roof Decking – In addition to any other load requirements, roof decking shall be designed to support a 91 kg (200-pound) concentrated load at mid-span on a 300 mm (12-inch) wide section of deck.
- c. **Deflection** – the maximum deflection for –
- 1) Structural Members - main framing members shall be L/240.
  - 2) Purlins and Roof Panels: The deflection due to live, snow, or wind shall not exceed L/180.
  - 3) For buildings with masonry infill, limit frame sway to L/600th of building eave height.
  - 4) Wall Panels - Maximum deflection of wall panels due to wind loads shall be L/120th of their respective spans except that when interior finishes are used the maximum allowable deflection shall be limited to L/180th of their respective spans.

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

**d. Wall and Roof materials –**

- 1) Alum/Zinc-Coated Steel Sheet: ASTM A792/ A792M, AZ 55.
- 2) Aluminum Sheet: Alloy 3004 Alclad conforming to ASTM B209.
- 3) Framing and Structural Members – Steel - ASTM A992 / A992M, ASTM A529/ A529M, ASTM A572/ A572M, or ASTM A588/ A588M.
- 4) Framing and Structural Members, Aluminum: ASTM B221 or ASTM C308

**e. Structural Tube:** ASTM A500 or ASTM B221.

**f. Fasteners** - Shall be compatible with the materials they are fastening to, be gasketed when exposed to weather to prevent leaks, and shall provide both shear and tensile strengths not less than 3,336 N (750 pounds) per fastener. The main fastening system shall use concealed fasteners, however, when exposed fasteners are needed, color fasteners shall be color coated to match wall/roof panels.

**g. Light Transmitting Roof Panels (Non-Insulated):** ASTM D3841, Type II, Grade 1.

**h. Insulation:** Blanket-type fiberglass insulation with a factory applied facing on one side and having a permeance rating of 0.05 or less in accordance with ASTM E96. Flame Spread Rating 75 or less, and a Smoke Developed Rating of 150 or less when tested in accordance with ASTM E84.

**i. Panel Finish** - Factory Color Finish - Provide factory applied baked coatings to the exterior and interior of metal wall panels and metal accessories. Provide exterior primer standard with panel manufacturer but not less than 0.8 mil dry film thickness (DFT). Provide PVDF exterior finish top coat of 70 percent inorganic pigments with 0.8 mil DFT. Provide factory-applied clear finish over the color topcoat and edge coating for projects within 91 meters of a water shoreline or industrial environments. Field apply 70 percent PVDF clear coat to unfinished panel edges or field cut panels. Interior finish exposed to sun or rain shall be the same coating and DFT as the exterior coating. Interior finish protected from sun or rain exposure shall receive 1.0 mil DFT coating of siliconized polyester (SMP) resin coating with organic or blended pigments and manufacturer's standard primer.

## **F20 SELECTIVE BUILDING DEMOLITION**

In general terms, demolition work shall include the removal and effective management and disposition of existing construction and or structures. Contractor shall take care to prevent damage to existing utilities and construction that are not scheduled for demolition. If damage occurs, the Contractor shall make repairs to the satisfaction of the Contracting Officer and at no cost to the Government. Comply with local Activity and Installation local requirements regarding demolition and removal. Unless otherwise specified in Part 3, all demolished materials and equipment must be removed from government property in accordance with applicable laws and regulations, including local Activity or Installation regulations. Selling of demolished or salvaged materials and equipment on government properties is prohibited.

**Demolition Plan and Environmental Protection Plan:** No demolition work shall take place until a Demolition Plan, Environmental Protection Plan, Safety Plan (including Activity Hazard Analysis), Asbestos Abatement Plan, and a Lead Abatement Plan have been submitted to, and approved by, the Contracting Officer. The Plans shall take into consideration, and indicate

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

method of removal, disposition, and abatement of environmentally hazardous materials. Demolition, disposition, and abatement of hazardous materials must comply with all applicable Local, State, and Federal regulations and laws. If destructive investigation is to occur, the Contracting Officer shall approve a Destructive Investigation Plan.

When hazardous materials such as asbestos, lead paint, PCB and other hazardous materials are involved in the performance of the work, the contractor shall abate, remove and manage the hazardous materials in construction and finish materials such as insulation, flooring, wall materials, ceiling materials, roofing materials, heating, plumbing, ventilation, air conditioning equipment and installations in accordance with National as well as local Environmental Protection Laws and Regulations.

**F2020 HAZARDOUS COMPONENT ABATEMENT**

1. **Asbestos in DoD Schools:** For projects that require removal or disturbance of asbestos containing materials within DoD schools, perform work in accordance with the edited UFGS 02 82 14.00 10, *Asbestos Hazard Control Activities*.
2. **Asbestos Materials:** Asbestos shall be removed, transported and managed in accordance with the following regulations: 29 CFR 1926.1101, and 40 CFR 61-Subpart M.

Category I & II Nonfriable: Demolition of Category I & II nonfriable asbestos containing materials (approved to be left in place during building demolition) shall be performed in accordance with 40 CFR 61 – Subpart M.

3. **Lead Based Paint in Child Occupied Facilities:** For projects that require removal or disturbance of painted surfaces within a child occupied facility, perform work in accordance with the edited UFGS 02 83 19.00 10, *Lead Based Paint Hazard Abatement, Target Housing and Child Occupied Facilities*.
4. **Paint Containing Lead, Cadmium and Chromium:** Work which requires the disturbance of paint that have been determined to contain all or any of the following: lead, cadmium and chromium must be performed in accordance with: 29 CFR 1926.62, 29 CFR 1926.1126 and 29 CFR 1926.1127.
5. **Mercury & LLR Components:** Work which requires removal of mercury and LLR components shall be performed in accordance with: 29 CFR 1910.1000, 10 CFR 20, and 40 CFR 273.
6. **PCBs:** Work which requires removal of PCB containing components or materials shall be performed in accordance with 29 CFR 1910.1000, 40 CFR 761, and 40 CFR 273.
7. **Hazardous Materials Reporting:**
  - a. **Daily Report:** Notify the Contracting Officer of work involving hazardous materials abatement and removal, including the quantities involved, on daily reports.
  - b. **Hazardous Material Inventory Report:** The Contractor shall provide a list of all hazardous materials used on the site.

## **SECTION G. BUILDING SITEWORK**

### **G10 SITE PREPARATIONS**

- 1. General Requirements:** Building site work includes site preparation, site improvements, site civil/mechanical utilities, site electrical utilities, exterior furnishings, landscaping, and irrigation. Provide site work in accordance with UFC 3-200-10N, *Civil Engineering*, which accommodates regional requirements (see paragraph 1-6).
- 2. Project Limitations:** Prior to the start of design, the contractor shall determine the exact limit-of-work line for the project periphery, considering items such as, but not limited to, utility work, landscape re-vegetation of disturbed areas, and lay down areas. The Civil Engineer and Landscape Architect of Record shall determine limit-of-work lines. Minimize the impact of construction activity on operations and neighboring facilities.
- 3. Geotechnical Data:** A geotechnical engineer shall conduct the subsurface exploration, investigation/evaluation, testing, and analysis that the Designer of Record deems necessary for the design and construction of the proposed facilities, including building pad, structure, pavement sections, repairs, overlays, stormwater management facilities, utility structure foundations, septic systems, and other features requiring soil support.

### **G1010 SITE CLEARING**

- 1. Existing Utilities:** When the Contractor is to work at a site that has existing utilities, the contractor is responsible for coordination with Contracting Officer and utility companies for staking out, capping, connection and relocation of any existing utility systems or traffic interruption. Notify utility locator service for area where Project is located before site clearing.
- 2. Interruption:** All interruption to the existing utilities and traffic shall be coordinated with and approved by the Contracting Officer not less than 14 calendar days in advance of such interruption.

### **G1020 SITE DEMOLITION & RELOCATIONS**

Abandon utility systems in-place conforming to applicable codes and regulations, removing their presence from the ground surface and clearly indicating that they have been abandoned. Remove utilities underneath or within 3.0 m (10 feet) of any new facilities. Fill abandoned gravity systems with flowable fill. Fill abandoned utility system piping under pavements subject to potential vehicle loading with flowable fill.

Remove existing utility structures to 900 mm (3 feet) below existing or new adjacent grade, whichever is greater. Break up bases to permit drainage. Fill with clean sand.

Comply with the requirements of the utility provider concerning utility relocation.

### **G1030 SITE EARTHWORK**

The DOR shall utilize UFGS Section 31 23 00.00 20 for the project specification and shall submit the edited section as a part of the design submittal. Perform quality assurance for earthwork in accordance with UFGS Section 31 23 00.00 20. If sheeting/shoring or dewatering is required, the Contractor shall provide a registered Professional Engineer to provide excavation, sheeting, shoring, and dewatering plans and inspection of excavations and soil/groundwater conditions throughout construction. The Engineer shall be responsible for performing pre-construction and periodic site visits throughout construction to assess site conditions. The Engineer, with the

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

concurrence of the contractor and the Contracting Officer, shall update the excavation, sheeting, shoring, and dewatering plans as construction progresses to reflect actual site conditions and shall submit the updated plan and a written report (with professional seal) at least monthly informing the Contractor and the Contracting Officer of the status of the plan and an accounting of Contractor adherence to the plan; specifically addressing any present or potential problems. The Engineer shall be available to meet with the Contracting Officer at any time throughout the contract duration.

**G20 SITE IMPROVEMENTS**

Provide site improvements as required to make a useable facility that meets functional and operational requirements, incorporates all applicable anti-terrorism, force protection and physical security requirements and blends into the existing environment.

Provide site improvements in conformance with applicable requirements of the Uniform Federal Accessibility Standards.

1. **Pavements:** For work in and adjacent to existing pavements, the Contractor is required to match the existing adjacent finish elevation, materials, paving section and texture, unless otherwise indicated in Part 3 or directed by the Contracting Officer.

Provide pavement design and pavement section materials in accordance with UFC 3-200-10N, *Civil Engineering*.

2. **Traffic Control:** If the site work involves interference with normal vehicular and or pedestrian traffic, the Contractor shall coordinate with the authority having jurisdiction, propose and obtain approval for traffic control measures that may be required in performance of the work required by the contract.

3. **Performance Verification And Acceptance Testing:**

- a. **Subgrade Preparation:** If required by the Designer of Record, perform proof rolling. Proof rolling shall be performed in the presence of the Contracting Officer. Rutting or pumping of material shall be undercut as directed by the Contracting Officer and replaced with satisfactory soil materials as defined by the Geotechnical Engineer.
- b. **Base Course Performance Verification:** At a minimum, Contractor must perform visual performance verification. Surface shall be smooth with no ruts, sloped or crowned to not pond water.
- c. **Bituminous Concrete Pavement Performance Verification:** At a minimum, Contractor must perform visual performance verification. Finished surface shall be uniform in texture and appearance, free of defects such as cracks and creases, and be sloped or crowned so as to not pond water.
- d. **Portland Cement Concrete Pavement Performance Verification:** At a minimum, Contractor must perform visual performance verification. Finished surface shall be uniform in texture and appearance, free of defects such as cracks and spalls, and be sloped or crowned so as to not pond water.
- e. **Concrete Joint Performance Verification:** Joint sealer that fails to cure properly, or fails to bond to joint walls, or reverts to uncured state or fails in cohesion, or shows excessive air voids, blisters, or has surface defects, swells, or other deficiencies, or is not recessed within indicated tolerances shall be rejected. Remove rejected sealer, re-clean and reseal joints.

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

**G2040 EXTERIOR FURNISHINGS**

All site furnishings shall be permanently attached to concrete pads. Site furnishings shall conform to the Base Exterior Architecture Plan (BEAP) or Installation Appearance Plan (IAP) for each Activity. If no product guidance is given, coordinate material, finish and color with architecture (fiberglass and aluminum are not acceptable) and provide to the greatest extent possible, materials with industrial recycled content, preferably from regionally local manufacturers. At a minimum, provide a trash and ash receptacle at each entry and gathering/smoking area.

**G2050 LANDSCAPING**

- 1. Landscaping Design:** The design of landscaped areas shall be in accordance with Presidential Executive Order 13148 of April 2000 with a goal to reduce fertilizers, pesticides, and water use. All non-paved site areas inside the project limits disturbed by construction operations, after meeting plant quantity requirements, shall be covered with plant material or mulch. All projects with planting (except for seeding, sprigging and or sodding) and or irrigation areas shall utilize the design services of a Landscape Architect licensed or certified in the State of the project.
- 2. Existing Plant Material to Remain:** Fence at plant or tree drip lines, and maintain all plant material to remain to keep plants healthy and thriving during construction operations. Should any plants die or are damaged during this period or during the Landscape Establishment Period, the Contractor, at the direction of the Contracting Officer, shall remove the existing tree and stump and replace with trees of the same genus and species equal to the total caliper of the existing tree. Minimum caliper of replacement trees shall be 100 mm (4 inch). Replace shrubs with 18.9 liter (5 gallon) size container, ground cover with flat containers planted at 200 mm (8 inches) on center, and turf with sod, all of the same genus and species.
- 3. Seeding, Sprigging, and Sodding:** Select a permanent seed mix. Apply seed at a time best suited for germination of the selected species. Seeded areas shall achieve a 95-percent coverage of the selected species and be weed free at the end of the Establishment Period. Sodded areas shall achieve 100% coverage and be weed free.
- 4. Utilities:** Trees shall not be placed within 10 feet of any above or below-grade utility line or structure.
- 5. Green Waste Recycling:** Contact the Public Works Department for potential green waste collection, management, and recycling by the Government.
- 6. Plant Quality:** All plants shall be in a healthy, disease and pest-free condition. All seed mixes, sod and sprigs shall be State Certified. Contractor shall provide native species appropriate for the locality.
- 7. Plant Quantities:** Within project limits, provide for building periphery, parking lot and perimeter site planting, not covered by buildings or paving, with a minimum of one tree and a minimum of 8 shrubs per 83.6 square meter (900 square feet) of landscape area. Provide a minimum tree size of 200 mm (24 inch) box/50mm (2 inch) caliper, or if within an anti-terrorism zone provide a minimum size of 910 mm (36 inch) box/76 mm (3 inch) caliper. For shrubs provide a minimum size of 19-liter (5 gallon), for ground cover provide a minimum size of 3.85-liter (1 gallon) containers. For trees and shrubs within concrete or other non-permeable paved area, allow a minimum non-paved area of 1.2 m by 2.4 m (4 feet by 8 feet per tree).
- 8. Edging & Mulching Materials:** Provide 3/16-inch thick by 4-inch deep galvanized metal or 6-inch by 6-inch Concrete edging dividing all turf and shrub areas and dividing all planted and non-

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

planted inorganic mulch areas. Plastic edging is not allowed. Mulch all plant areas with a minimum 3-inch layer of mulch to match local area material.

- 9. Weed Control Fabric:** Provide an ultra-violet-resistant weed barrier fabric of polypropylene or polyester fabric specifically designed for weed control purposes beneath all mulched non-planted areas with a minimum weight of 0.11 kg per square meter (5 ounces per square yard) with a minimum thickness of 0.50mm (20 mils) with a 20-year minimum guarantee.
- 10. Irrigation:** If specified in Part 3, all planting areas shall be automatically irrigated with a permanent, below-grade system.
  - a. Irrigation Design and Testing:** Provide 100 percent sprinkler head coverage. Provide pop-up heads in turf and when adjacent to turf, walks, roads, parking lots, and in sparsely planted landscape areas where pedestrians may circulate. Provide pop-up heads project-wide on high-traffic sites such as, but not limited to, dining, housing, entertainment, daycare, education and recreation facilities. Verify adequate water pressure for irrigation purposes and provide booster pumps and or pressure regulation as required. Provide minimum 12-inch cover over PVC irrigation pipe. 13 mm (1/2 inch) pipe is not allowed. The Landscape Contractor shall test the entire system in the presence of the Contracting Officer (and for projects greater than 5,000 square feet, the Landscape Architect of Record shall attend,) to ensure proper performance. All irrigation components shall be commercial or institutional quality. Provide rain shut-off device and watertight splices. Sprinkler heads, bodies and nozzles shall be of the same manufacturer.
  - b. Irrigation Operation and Control:** Assure systems will automatically operate on an "irrigation window" between 2130-0530. Provide compatible and fully functional control if a central control system exists on base. Otherwise, provide evaporo-transpiration measuring control with flow meter and master valve with controller capable of indicating visible or auditory notification, such as a blinking light or beeping sound, of system shut-off.
  - c. Irrigation Controller Charts:** Provide one chart for each new controller or existing re-sequenced controller. The chart shall be an actual plan reduced to fit inside maximum dimensions of the controller housing. Use black line print for chart and a different color to indicate each station area of coverage. After chart is completed and approved for final acceptance, seal chart between two 0.5 mm (20 mil) pieces of clear plastic. The chart shall be affixed to the inside of the controller cabinet door using approved mastic or fastening system.
  - d. Irrigation Zoning:** Provide separate control valves for differing solar exposures, for areas with differing irrigation head types or differing precipitation rates, and top and bottom of slopes. Provide a separate irrigation backflow prevention device and water meter. Turf and shrubs/groundcover are not allowed on the same valve. Provide separate concrete valve box with cast iron lid and valve ID for each valve and wire splice. Provide quick coupling valves at 30m (100 feet) on center. Provide in-head check valves for sloped areas with 150 mm (0.5 feet) or more in elevation change.
  - e. Temporary Irrigation:** Provide ultra-violet resistant pipe and fittings for above-grade, temporary irrigation. Only non-pressure pipe is allowed above grade. Irrigation systems intended to remain in place longer than one year shall be installed below grade.
  - f. Non-Potable Irrigation:** Provide lavender-colored pipe, sprinkler head and quick coupler caps, valve tags, signage, and associated filtration equipment.

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

- 11. Landscape and Irrigation Establishment Period and Guarantee:** Provide the following landscape and irrigation establishment period for landscaped areas within the limits of work and areas disturbed by construction:

365 days: Trees, Shrubs, Ground Cover, Vines, and Ornamental Grasses.

120 days: Turf Areas (Active growing season).

The Landscape Architect-of-Record shall, along with the Contracting Officer, attend, approve and document the start of the Establishment Period and document quarterly and final inspections. During this period, the Contractor shall perform tasks which shall include, but not be limited to, watering, weeding, eradicating pests, adjust irrigation and replenish mulch to assure all plant material is in a healthy and thriving condition or the Contractor shall replace plant material at his own expense. All trees, shrubs, and ground covers that die or have 20 percent or more of their crowns that die during planting operations or the guarantee period shall be replaced with healthy plants of the same species or variety. Broadcast seeded or hydro-seeded areas that do not achieve the 95-percent coverage of the selected species by the end of the Establishment Period shall be reseeded by the same method and be maintained an additional 120 days to assure coverage. Sodded turf areas should be 100% at the end of the guarantee period. Turf shall be maintained in a manner that promotes proper health, growth, rich natural green color, and a neat, uniform, manicured appearance. Mow weekly during the growing season and remove excess clippings.

### **G30 SITE CIVIL/MECHANICAL UTILITIES**

Develop the site to provide water, fire protection, sanitary sewer, storm drainage, heating, cooling and fuel distribution services that meet the requirements of each utility provider and each applicable regulatory agency that governs and issues permits for the construction and operation of these systems.

Coordinate with the local utility providers and pay any fees or charges required to connect to their utility.

Provide all required fittings, connections and accessories required for a complete and usable system. All equipment shall be installed per the criteria indicated in this RFP and the manufacturer's recommendations. Where the word "should" is used in the manufacturer's recommendations, substitute the word "shall".

### **G3010 WATER SUPPLY**

- 1. Water System Design and Construction:** Provide the new water system and connections to the existing water system in accordance with UFC 3-200-10N, *Civil Engineering (paragraph 2-3)*; the utility provider's requirements; or the state waterworks' regulations; whichever is more stringent.
- 2. Notifications:** Notify the utility provider of the additional demand generated by the proposed facility. Provide a copy of all correspondence with the utility provider to the Government's Civil/Mechanical Reviewer.
- 3. Performance Verification And Acceptance Testing:** Provide testing on water mains and service lines in accordance with the state waterworks' regulations and the following:
  - a. Ductile iron and other materials: AWWA C600.
  - b. PVC: AWWA C605.

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

whichever is more stringent. Do not begin testing on any section of a pipeline where concrete thrust blocks have been provided until at least 5 days after placing of the concrete.

**G3020 SANITARY SEWER**

- 1. Sanitary System Design and Construction:** Provide the new sanitary sewer system and connections to the existing sanitary sewer collection system in accordance with UFC 3-200-10N, *Civil Engineering (paragraphs 2-4 and 2-5)*; the utility provider's requirements; or the state sewerage regulations; whichever is more stringent.
- 2. Notifications:** Notify the utility provider of the additional wastewater flow generated by the proposed facility. Provide a copy of all correspondence with the utility provider to the Government Civil Reviewer.
- 3. Wastewater Pump Station:** Where required, provide a duplex, grinder pump station in accordance with the utility provider's requirements. Provide pump station wet well of fiberglass construction. Provide adjacent valve vault of precast concrete construction.

Provide automatic control to start and stop the pump system. Provide automatic level control by floats in accordance with the preferences of the system owner to fill and prevent overflow of the wet well. Provide an emergency pump connection.

Provide a telephone dialer in the control panel capable of accepting up to 8 telephone numbers. At the control panel provide an alarm horn and light with battery backup. Alarms shall include high liquid wet well level; loss of main power; no flow as sensed by current sensor; and pump failure via overload or motor heat sensor trip. Provide seal failure indicator lights and elapsed time meters.

Provide electrical connections for a portable emergency generator hook-up sized to start up and maintain the total rated running capacity of the station, including the pumps, controls, lighting, and other auxiliary equipment.

**4. Performance Verification And Acceptance Testing:**

- a. Sanitary Sewer Distribution System Performance Verification: Provide testing on sewer mains and laterals in accordance with the state sewerage regulations. At a minimum, perform the following:
  - 1) Visual Test: Check each straight run of pipeline for gross deficiencies by holding a light in a manhole; it shall show a full circle of light through the pipeline when viewed from the adjoining end of line.
  - 2) Leakage Tests: Test lines for leakage by either infiltration tests or exfiltration tests, or by low-pressure air tests in accordance with the following:
    - d) Exfiltration Tests: ASTM C 969M (ASTM C 969) and perform calculations in accordance with its Appendix.
    - e) Low-pressure Air Tests: Pipelines: ASTM C 924M (ASTM C 924) and perform calculations in accordance with its Appendix. PVC plastic pipelines: UBPPA UNI-B-6 and perform calculations in accordance with its Appendix.
  - 3) Cross Connection Tests: Cross connection tests shall be observed by the Contracting Officer and the utility provider's inspector.

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

- a) Perform a tracer study from the project sewer connection to the first manhole downstream on the active sewer system. Use a nontoxic, non-staining sewer tracing dye. Testing shall continue until the dye visually confirms the design connection is appropriate. During the test, the contractor shall monitor the storm drainage system (structures and outfalls) downstream from the project for any sign of cross connection.
  - b) Perform a smoke test on the project sewer to verify that project storm drainage inlets or drains have not been connected to the sanitary sewer.
- b. Sanitary Sewer Manholes Verification Testing: Provide testing on sanitary sewer manholes in accordance with the state sewerage regulations. At minimum, perform hydraulic testing in accordance with ASTM C 969M (ASTM C 969).
- c. Wastewater Pump Station Verification Testing: Test the wastewater pump station in accordance with the state sewerage regulations. Conduct testing on discharge piping and force main in accordance with tests for water distribution mains; see G30, paragraph 1.3.2. Test pumps, controls, and alarms, in operation, under design conditions to ensure proper operation of all equipment.

**G3030 STORM SEWER**

1. **Storm System Design and Construction:** Provide the new storm sewer system and connections to the existing storm sewer system in accordance with UFC 3-200-10N, *Civil Engineering (paragraph 2-2)*; the utility provider's requirements; or the state stormwater management laws and regulations; whichever is more stringent.

The Contractor shall make necessary adjustments to the drainage design in order to avoid disruption to existing utilities and to protect existing trees to remain.

Confirm that the existing receiving system has adequate capacity to receive the additional stormwater flow generated by the project.

2. **Storm Sewer System Performance Verification:** At a minimum, Contractor shall perform visual testing. Check each straight run of pipeline for deficiencies by holding a light in a manhole; it shall show a full circle of light through the pipeline when viewed from the adjoining end of line.

**G3060 FUEL DISTRIBUTION**

**Gas Distribution System:** Refer to Section D20 for requirements.

**G40 SITE ELECTRICAL UTILITIES**

**G4010 ELECTRICAL DISTRIBUTION**

1. **Electrical Utilities Design and Construction:** Site electrical utilities include all exterior electrical work, including the connection to the primary distribution system. This also includes telephone and cable television supplies.

Provide electrical overhead and underground, distribution systems in accordance with IEEE C2 (National Electrical Safety Code), NFPA 70, local utilities company requirements, and local Activity guidelines.

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

2. **Coordination With Local Utilities Company and Local Activity:** Service meters for electrical services shall be provided and installed in conformance with the local utilities company requirements and local activity guidelines.
3. **Substations:** When secondary unit substations are required, the Designer of Record shall utilize UFGS Section 26 11 13, *Secondary Unit Substation*, and UFGS Section 26 23 00, *Switchboards and Switchgear*, for the project specification, and shall submit the edited specification section as a part of the design submittal for the project.
4. **Transformers:** When transformers are required, the Designer of Record shall utilize UFGS Section 26 12 19.10, *Three-Phase Pad Mounted Transformers*, UFGS Section 26 12 19.20, *Single-Phase Pad Mounted Transformers*, or UFGS Section 33 71 01.00 20, *Overhead Transmission and Distribution*, for the project specification, and shall submit the edited specification section as a part of the design submittal for the project.
5. **Switches, Controls and Devices:** When switches or control devices are required, the Designer of Record shall utilize UFGS Section 26 13 00.00 20, *SF6 Insulated Pad Mounted Switchgear*, or UFGS Section 33 71 01.00 20, *Overhead Transmission and Distribution*, for the project specification, and shall submit the edited specification section as a part of the design submittal for the project.

**G4030 SITE COMMUNICATION & SECURITY**

1. **Telephone Distribution System:** Provide all telephone distribution systems in accordance with EIA/TIA Standards, NFPA 70, and the cognizant telephone company requirements.
2. **Cable Television System:** Provide all cable television systems in accordance with NFPA 70, and the cognizant cable television company requirements and BICSI recommendations.

\*\* End of Part 4 \*\*

**Replace Siding -Bldg 405  
Naval Support Activity, Mechanicsburg, Pennsylvania  
Work Order Number 1350926**

## **PART FIVE - PRESCRIPTIVE SPECIFICATIONS**

**Not Used.**

**Replace Siding – Bldg 405**  
**Naval Support Activity, Mechanicsburg, Pennsylvania**  
**Work Order Number 1350926**

**PART 6**  
**ATTACHMENTS**

10/14

Part 6 contains information that will help the contractor develop a suitable design and to construct without hindrance.

1. Miscellaneous Bldg Drawings - Building 405
2. Existing Exterior Insulation & Finish System (EIFS Installation Plans)
3. AutoCAD and PDF drawings of 'Replace Siding – Bldg 209'
4. Pictures (Beginning at the N.W. corner and proceeding clockwise around the Bldg)
5. NAVFAC 24 x 36 AutoCAD drawing of standard plan sheet (w/map – use map on title sheet only)
6. Standard Utility Note
7. "Safety First" notice (To be included on Title Sheet of AutoCAD drawings.)
8. NAVFAC Red Zone Check List Contractor
9. Contractor Accident Prevention Plan Checklist
10. Specification Section 07 42 63, "Fabricated Wall Panel Assemblies"
11. ALMECH INSTRUCTION 11450.1D, Weight Handling Equipment and Elevated Crane Trackage Program Management
12. Specifications, Division 01 General
  - a. Specification Section 01 14 00, "Work Restrictions"
  - b. Specification Section 01 30 00.05 20, "Administrative Requirements for Design Build"
  - c. Specification Section 01 32 16.05 20, "Design and Construction Progress Documentation"
  - d. Specification Section 01 33 10.05 20, "Design Submittal Procedures"
  - e. Specification Section 01 35 26, "Government Safety Requirements"
  - f. Specification Section 01 45 00.00 10, "Quality Control"
  - g. Specification Section 01 57 19.00 20, "Temporary Environmental Controls"
13. Sample Building ID sign information
14. Bldg 405 Roofing Plans – pdf
15. Bldg 405 Roofing Plans - CADD
16. Excavation Permit