

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>			1. CONTRACT ID CODE J	PAGE OF PAGES 1   3
2. AMENDMENT/MODIFICATION NO. 0007	3. EFFECTIVE DATE 08-Aug-2016	4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO.(If applicable)
6. ISSUED BY NAVFAC MID ATLANTIC IPT NORTH 9324 VIRGINIA AVENUE BLDG Z-144 NORFOLK VA 23511	CODE N40085	7. ADMINISTERED BY (If other than item 6) <b>See Item 6</b>		
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)		X	9A. AMENDMENT OF SOLICITATION NO. N40085-16-R-3011	
		X	9B. DATED (SEE ITEM 11) 22-Jun-2016	
			10A. MOD. OF CONTRACT/ORDER NO.	
			10B. DATED (SEE ITEM 13)	
CODE	FACILITY CODE			
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS				
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.				
12. ACCOUNTING AND APPROPRIATION DATA (If required)				
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.				
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.				
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).				
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:				
D. OTHER (Specify type of modification and authority)				
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.				
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)  This amendment is issued in order to provide responses to pre-proposal inquiries (PPI's).  john.p.bishop1@navy.mil; (757)341-1982				
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.				
15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
		TEL:	EMAIL:	
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA		16C. DATE SIGNED
_____ (Signature of person authorized to sign)		BY _____ (Signature of Contracting Officer)		08-Aug-2016

## SECTION SF 30 BLOCK 14 CONTINUATION PAGE

**SUMMARY OF CHANGES**

## SECTION SF 30 - BLOCK 14 CONTINUATION PAGE

The following have been added by full text:

AMENDMENT 0007

8 August 2016

Is issued for the following reasons:

1. Provide responses to Pre-Proposal Inquiries (PPIs)
- 

**PRE-PROPOSAL INQUIRY**

REFERENCE			QUESTION	GOVERNMENT RESPONSE	Posted on Amend No.	Response Number
Page	Section	Para.				
7	31 63 19	3.1	Plans and specifications state that rock probing will be done at the location of each king pile. The specifications also state in section 31 63 19 page 7, par. 3.1, that "Rock probing equipment shall be capable of penetrating through all materials to the top of bedrock and penetrate 10 feet into bedrock." Is it the intent that each probe actually be cored into bedrock 10 ft.? There are significant cost implications to this.	The probes are for establishing the top of competent bedrock elevation at each King Pile. The drill depth at each probe needs to be whatever is required to ensure the probe has extended through the overburden and weathered bedrock and into the competent bedrock, and also to ensure that the probe is not in a boulder. To establish the consistency and drilling rate of the bedrock, the first 5 probes should be drilled to a depth of 10 feet and logs of drilling rates should be recorded. Once the consistency, drilling rates, and elevations of competent bedrock have been established, a drilling depth of 5 to 6 feet into bedrock should be sufficient to confirm the rock competency and to establish the top of bedrock elevation, as long as the consistency, drilling rate, and elevation are similar to those that have already been	7	113

			<p>established by the other probes. Drilling rate logs of all probes should be recorded. The specification requirement for being "...capable of penetrating through all materials to the top of bedrock and penetrate 10 feet into bedrock.", shall be taken to mean that the equipment must have the capability to drill to that depth, but it is not a requirement to drill 10 feet into rock at every probe.</p>		
--	--	--	---	--	--

(End of Summary of Changes)