

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>			1. CONTRACT ID CODE J	PAGE OF PAGES 1   4
2. AMENDMENT/MODIFICATION NO. 0008	3. EFFECTIVE DATE 11-Aug-2016	4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO.(If applicable)
6. ISSUED BY NAVFAC MID ATLANTIC IPT NORTH 9324 VIRGINIA AVENUE BLDG Z-144 NORFOLK VA 23511	CODE N40085	7. ADMINISTERED BY (If other than item 6) <b>See Item 6</b>		
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)		X	9A. AMENDMENT OF SOLICITATION NO. N40085-16-R-3011	
		X	9B. DATED (SEE ITEM 11) 22-Jun-2016	
			10A. MOD. OF CONTRACT/ORDER NO.	
			10B. DATED (SEE ITEM 13)	
CODE	FACILITY CODE			
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS				
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.				
12. ACCOUNTING AND APPROPRIATION DATA (If required)				
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.				
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.				
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).				
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:				
D. OTHER (Specify type of modification and authority)				
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.				
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)  This amendment is issued in order to provide responses to pre-proposal inquiries (PPIs).  john.p.bishop1@navy.mil; (757)341-1982				
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.				
15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
		TEL:	EMAIL:	
15B. CONTRACTOR/OFFEROR  _____ (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA  BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED  11-Aug-2016

## SECTION SF 30 BLOCK 14 CONTINUATION PAGE

**SUMMARY OF CHANGES**

## SECTION SF 30 - BLOCK 14 CONTINUATION PAGE

The following have been added by full text:

AMENDMENT 0008

11 August 2016

Is issued for the following reasons:

1. Provide responses to Pre-Proposal Inquiries (PPIs)
- 

**PRE-PROPOSAL INQUIRY**

REFERENCE			QUESTION	GOVERNMENT RESPONSE	Posted on Amend No.	Response Number
Page	Section	Para.				
Plan Sheet S-608			The plan sheet S-608 "Steel sheet Pile Bulkhead Rock Anchor Schedule" references B1 – B13 = 13 Anchors Total – Below the table has an * use Type 5 anchors for Bid Option 4: A93 – 101 and **use Type 3 anchors for Bid Option 4: A102 – A103 = 11 anchors total. Please clarify if A93-103 referenced in the notes of the table corresponds to the B1-B13 Anchors in the table for Option 4.	The asterisk notes on drawing S-608 should be revised as follows: (*) Use Type 5 Anchors for Bid Option 4, Anchors B1 Thru B9. (**) Use Type 3 Anchors for Bid Option 4, Anchors B10 Thru B13. Drawing S-608 will be revised via addenda.	8	103
Plan Sheet S-503			The specs section 3.1.2 says that the casing shall be removed during grouting. The plan sheet S-503 detail A3 shows the casing to the bonded length. Can the casing remain permanently in place in the stressing length?	Specification section 3.1.3 paragraph 3.1.3 is intended for a condition if casing were installed in the bonded length (example is a soil anchor). Permanent casing is required for the entire unbonded zone .	8	104

			The specifications 2.5.6.3 says that the bond length is encapsulated with a corrugated tubing. The plan sheet S-503 detail A3 shows a bare strand in the bond length. Which one will be required?	The specificaiton is correct and the full anchor length requires corrugated sheathing. Detail A3 on drawing S-503 is drawn with a break in the corrugated sheathing for presentation purposes to show the strands and spacer arrangement. This will be clarified via addenda.	8	105
			The plan S-503 Rock Anchor Notes #8 says that the unbonded length shall be grouted after stressing. The Specifications 2.5.6.2 say that the stressing length is to have a bond-breaker. Considering that the stressing length has a bond breaker. Can the anchors be fully grouted in a single stage?	No. The grouting sequence and the bond-braker shall be provided as shown on the drawings and specifications.	8	106
7	31 68 13	2.2.1	The specification calls for special wedges for epoxy coated strand. Are the strand anchors epoxy coated	No.	8	107
6	31 63 19	2.1.3	King Pile Specification Section 31 63 19, Paragraph 2.1.3 states "slump results between 5 to 6 inches,..." for concrete. Concrete placement will require tremie methods and typical tremie concrete mix designs use 7 to 9 inch slump. Please confirm 7 to 9 inch slump concrete will be allowed.	An adjustment to the concrete slump will be considered provided the mix design meets the project requirements.	8	114

		Was a geotechnical engineering report prepared for this project? If so, please distribute for review.	We are providing Geophysical Report and Geotechnical Laboratory Test Results via addenda.	8	115
		Based on the amount of information provided in the last amendments received on July 26th and July 28th we request a 3-week time extension on the bid date so we disseminate the information to our potential subcontracted team and also process them to make the necessary changes in our proposal	No proposal extensions are currently planned for this solicitation.	8	116

(End of Summary of Changes)