

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>			1. CONTRACT ID CODE	PAGE OF PAGES 1   7
2. AMENDMENT/MODIFICATION NO. 0004	3. EFFECTIVE DATE 22-Aug-2016	4. REQUISITION/PURCHASE REQ. NO. ACQR4455590		5. PROJECT NO.(If applicable)
6. ISSUED BY NAVFAC MID ATLANTIC MARINE CORPS IPT 9324 VIRGINIA AVE NORFOLK VA 23511	CODE N40085	7. ADMINISTERED BY (If other than item 6)  <b>See Item 6</b>		
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)		X	9A. AMENDMENT OF SOLICITATION NO. N40085-16-R-5505	
		X	9B. DATED (SEE ITEM 11) 22-Jul-2016	
			10A. MOD. OF CONTRACT/ORDER NO.	
			10B. DATED (SEE ITEM 13)	
CODE	FACILITY CODE			
<b>11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS</b>				
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.				
12. ACCOUNTING AND APPROPRIATION DATA (If required)				
<b>13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.</b>				
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.				
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).				
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:				
D. OTHER (Specify type of modification and authority)				
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.				
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)  N40085-16-R-5505 P398 RANGE SAFETY IMPROVEMENTS AND MODERNIZATION, MARINE CORPS RECRUIT DEPOT (MCRD), PARRIS ISLAND, SOUTH CAROLINA  THE PURPOSE OF THIS AMENDMENT IS TO PROVIDE SITE VISIT ROSTER, BID SHEET/SCHEDULE AND RESPOND TO PRE-PROPOSAL INQUIRIES (PPIs).  RECEIPT OF PROPOSALS REMAINS THE SAME, 26 AUGUST 2016 @ 2:00 PM				
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.				
15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
		TEL:	EMAIL:	
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA		16C. DATE SIGNED
_____ (Signature of person authorized to sign)		BY _____ (Signature of Contracting Officer)		23-Aug-2016

## SECTION SF 30 BLOCK 14 CONTINUATION PAGE

## SUMMARY OF CHANGES

## SECTION SF 30 - BLOCK 14 CONTINUATION PAGE

The following have been added by full text:

SUMMARY CHANGE

**REFER TO ATTACHMENTS:**

SITE VISIT ROSTER

BID SCHEDULE

## PRE-PROPOSAL INQUIRY (PPI) RESPONSES:

CONTRACTOR PPI#	SECTION	PARAGRAPH REF	DRAWING #
001	01 35 26	1.6.1.1.1	

This section states the QC cannot be the SSHO. Does this pertain to the Superintendent as well, meaning the SSHO have no other duties?

**- The QC, SSHO and Superintendent shall have separate roles and responsibilities. They cannot be dual hatted.**

002	01 50 00	3.5.7	
-----	----------	-------	--

This section speaks to the construction of a new building for the temporary project field office. Will the MCRB consider allowing for a trailer that meets the requirements?

**- In the event the KTR selects a new building, then the requirements of 3.5.7 must be met. If not, temporary facilities requirements are indicated in 3.5.5.**

003	01 50 00	3.6	
-----	----------	-----	--

Is this paragraph suggesting a temporary safety fence be constructed around the entire project site? If so, what type of fence is required (chainlink or orange snow fence).

**- No, temporary screened-chainlink fence will be required for the contractor laydown area. All other fencing will be required as indicated in drawings.**

004	01 57 19.00 20	1.5.4	
-----	----------------	-------	--

This section states to appoint an environmental manager for the project. Is this person to be on site full time during construction or is this person to be a consultant type for periodic monitoring?

**- EM may be dual hatted with other roles provided they meet all the requirements for both positions.**

005

Will the sign in sheet be furnished in the form of an amendment?

**-Yes**

006

With respect to the Q&A responses, will NAVFAC consider postponing the bid date?

**-No**

007

00010

Solicitation Contract Form Item 2 (page 3 of 53) in the solicitation states that allowances are included for ordnance scanning of entire site and for potential ordnance removals. We have been unable to find these allowances in the bid documents. Can you please provide more information regarding these allowances?

**-See Section 02 51 43**

008

We have been told by installers that spec section 32 18 16.13 - Firing Line Protective Surfacing provides information that is contrary to the typical material and installation of the product. Can you please provide a Basis of Design for this product? Comments from one of our suppliers are included below

**- Provide firing line surfaces as specified using aliphatic binder with a 1/2" wearing surface. Surface is subject to falls. Any variations of the firing line surfaces shall be submitted as described in section 01 33 00, Paragraph 1.8 after project award.**

009

Section 01 14 00 paragraph 1.2 states that the side wall must be completed before work is permitted during regular hours or when work is done within 1 foot of the top of the side wall. This section also states that a schedule is produced every October with anticipated range operation. Is it possible to obtain a copy of the current range operating schedule and does the government anticipate similar usage for the duration of this project?

**- The Government does not anticipate similar uses for the duration of the project. Current Range schedule not to be provided.**

010

Will the installation of the water distribution and site sanitary sewer work need to be completed during off-normal working hours due to the proximity of this work to the adjacent range?

**- Work south of the safety wall must be completed outside of normal working hours. Other work must be completed as specified in 01 14 00.**

011

Will the contractor be required to coordinate, supervise and oversee installation of the site utilities work performed by BJWSA within the project limits?

**- BJWSA is not installing any utility within the project limits. All site utilities shall be installed by the KTR.**

012

Section 02 51 43, paragraph 1.1 states "area to be cleared is approximately 0.5 acres" however the map appears to indicate the entire DGM area. Can you provide coordinates of the 0.5 acres to be cleared?

**- See CD-100 for LOD coordinates**

013

A/R - Specifications

A/R

A/R

Is this a LEED project and if so what certification is required? There are several specification references to LEED in the Cx sections amongst others, but nowhere does it state that this is a LEED project?

**-NO**

014

Do we need to have utility contractors certified by the public utility?

**- No, see BJWSA Development Policy and Procedure Manual for additional requirements.**

015

CS Drawings

No detail is provided for the 20' and 50' flag poles.

**- See section 12 93 00.**

016

CS-514

Detail A4 depicts a lined swale. Please indicate the cloud like material required above the class 2 geotextile.

**- Fabric formed concrete, see 33 40 00 for technical specifications.**

017 C-001 (note 4), C-002  
(note 6), CD-100 (note 5), & CD-101 (note 9)

Target berm has lead in the dirt. Note 4 on C-001 tells us to dispose of cleared and/or grubbed material properly. It is likely that the upper layers of the target berm will have lead in it. Note 5 on CD-100 says not to haul any dirt off the site. Note 9 on CD-101 says we can use the dirt with lead in it as long as we cover it with clean dirt to a min depth of 5'.

Are we supposed to plan on hauling off the top 2' of the existing target berm and dispose of in an appropriate site or just reuse the material as fill on the site for the new work and handle it appropriately per lead in construction rules?

**- Reuse earth material from existing target berm onsite. All existing earth material must remain onsite.**

018 CS Drawings

Since there is no CS-107, please confirm that there is no requirement for a flag pole or gate at the road entrance.

**- Confirmed, there is no gate or flagpole at the driveway onto Wake Blvd.**

019 CS-504

The CG Drawings reference storm pipe sections FES#\_. Is there a storm pipe schedule that was supposed to be provided?

**- FES # are indicated on CG-101 thru CG-106.**

020 CS-102

Are bollards needed at the corners of the Butt house similar to the Target Storage shed corners?

**- Yes**

021 CG-101 & 102

Alongside the Male and Female Heads there is a symbol that appears to be stairs leading from the concrete platform (#34) to the respective Head. A detail is needed for these stairs that includes grade details, number of steps and hand rail details (if applicable).

**- See C3 on A-202.**



There are not resilient connectors for elliptical pipe. Provide an alternate connection detail/spec.

**- Resilient connectors are not required for elliptical pipe.**

030                      31 23 00.00 20 1.6 g

Where is borrow available onsite per this paragraph?

**- See SP series and CG series drawings for existing and proposed grades.**

(End of Summary of Changes)