

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>			1. CONTRACT ID CODE J	PAGE OF PAGES 1   3
2. AMENDMENT/MODIFICATION NO. 0006	3. EFFECTIVE DATE 23-Aug-2016	4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO.(If applicable)
6. ISSUED BY NAVFAC MID ATLANTIC MARINE CORPS IPT 9324 VIRGINIA AVE NORFOLK VA 23511	CODE N40085	7. ADMINISTERED BY (If other than item 6) <b>See Item 6</b>		
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)		X	9A. AMENDMENT OF SOLICITATION NO. N40085-16-R-5516	
		X	9B. DATED (SEE ITEM 11) 29-Jul-2016	
			10A. MOD. OF CONTRACT/ORDER NO.	
			10B. DATED (SEE ITEM 13)	
CODE	FACILITY CODE			
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS				
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.				
12. ACCOUNTING AND APPROPRIATION DATA (If required)				
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.				
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.				
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).				
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:				
D. OTHER (Specify type of modification and authority)				
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.				
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)  DESIGN-BUILD / DESIGN-BID-BUILD INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ) FIRM FIXED PRICE MULTIPLE AWARD CONSTRUCTION CONTRACT (MACC) FOR MARINE CORPS AIR STATION BEAUFORT, MARINE CORPS RECRUIT DEPOT, PARRIS ISLAND AND NAVAL HOSPITAL BEAUFORT, SOUTH CAROLINA.  SEE SECTION SF 30 BLOCK 14 CONTINUATION PAGE				
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.				
15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
		TEL:	EMAIL:	
15B. CONTRACTOR/OFFEROR  _____ (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA  BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED  23-Aug-2016

## SECTION SF 30 BLOCK 14 CONTINUATION PAGE

## SUMMARY OF CHANGES

## SECTION SF 30 - BLOCK 14 CONTINUATION PAGE

The following have been added by full text:

AMENDMENT 0006

This amendment is issued to provide responses to PPIs. All PPIs have been addressed via Amendment.

Contractor PPI#	Section of RFP or Page Number	Paragraph Reference	Drawing Number	Question	Response
8	08 51-13	1.4.2 and 1.8.1		<p>Requesting additional information for the Sections 08 51 13 Paragraph 1.4.2 Design Data Requirements and the paragraph 1.8.1 Minimum Antiterrorist Performance Criteria. Have reviewed the Drawings &amp; Specifications data for this required information and was not found.</p> <p><b>Data needed is as following:</b></p> <ol style="list-style-type: none"> <li>1. Glass make up: <ol style="list-style-type: none"> <li>a) Overall glass thickness &amp; Airspace</li> <li>b) Inboard glass thickness, Type &amp; PVB thickness</li> <li>c) Outboard glass thickness &amp; Type</li> </ol> </li> <li>2. Building Location is considered as: <ol style="list-style-type: none"> <li>a) Controlled perimeter or parking &amp; roadways without controlled perimeter</li> <li>b) Parking and roadways within controlled perimeter</li> <li>c) Trash containers</li> </ol> </li> <li>3. Building Category: <ol style="list-style-type: none"> <li>a) Billeting and High</li> </ol> </li> </ol>	<p>Modify the Door Schedule on Drawing A6.0: Change door type from type 1 to type 2 for doors 104, 106, 118A, 118B, and 205.</p> <p>The blast pressures for windows in these rooms 103, 118, 202 blast pressure 133 psf 101, 203 blast pressure 100 psf</p> <p>All other windows and doors have a standoff exceeding 100 feet and shall meet the specifications 08 51 13 and 08 81 00.</p>

				<p>Occupancy Family Housing</p> <p>b) Primary Gathering</p> <p>c) Inhabited Building</p> <p>4. Standoff Distance: a) 148Ft b) 82ft c) 33ft</p> <p>5. Explosive Weight: a) Explosive Weight 1 b) Explosive Weight 2 c) Explosive Weight 1 and 2</p> <p>6. Frame Load _____ psf</p> <p>7. Frame attachment load to Building _____psf</p> <p>8. Peak Blast Pressure=_____psi</p> <p>9. Impulse=_____psi*msec-psi</p> <p>10. Level of protection a) very low, b) low c) Medium and d)High</p>	
--	--	--	--	---	--

(End of Summary of Changes)