

		1. CONTRACT ID CODE J		PAGE 1	OF PAGES 5
2. AMENDMENT/MODIFICATION NO. 0004		3. EFFECTIVE DATE 07 JANUARY 2016		4. REQUISITION/PURCHASE REQ. NO.	
6. ISSUED BY NAVFAC MID ATLANTIC HAMPTON ROADS IPT 9324 VIRGINIA AVENUE NORFOLK, VA 23511		Code OPHA		7. ADMINISTERED BY (If other than item 6.)	
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)		<input checked="" type="checkbox"/>		9A. AMENDMENT OF SOLICITATION NO. N40085-16-R-6116	
		<input checked="" type="checkbox"/>		9B. DATED (SEE ITEM 11) 7-Dec-2015	
		<input type="checkbox"/>		10A. MODIFICATION OF CONTRACT/ORDER NO.	
				10B. DATED (SEE ITEM 13)	
CODE		FACILITY CODE			
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS					
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in item 14. The hour and date specified for receipt of Offers <input checked="" type="checkbox"/> is extended <input type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning <u>2</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.					
12. ACCOUNTING AND APPROPRIATION DATA (if required)					
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.					
<input type="checkbox"/> A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14. ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.					
<input type="checkbox"/> B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATION CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103 (b).					
<input type="checkbox"/> C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:					
<input type="checkbox"/> D. OTHER: (specify type of modification and authority)					
E. IMPORTANT: Contractor <input checked="" type="checkbox"/> is not <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.					
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)					
<b>N40085-16-R-6116, Design-Build P-554, Industrial Controls, Naval Station Norfolk, Va. (Work Order #1363440)</b>					
<b>This Amendment is being issued to provide the following:</b>					
<ul style="list-style-type: none"> <li>- The proposal due date for this project is being extended from Tuesday, 12 January 2016 to 20 January 2016. Proposals are due at 2:00 PM Eastern Standard time at the designated location identified in the solicitation.</li> <li>- Responses to PPI's 1-27</li> </ul>					
Please acknowledge amendment 0004.					
Contract POC: andrew.dorsey@navy.mil, Phone: (757) 341-1653 or melinda.crawley@navy.mil, Phone (757) 341-0150					
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.					
15A. NAME AND TITLE OF SIGNER (Type or print)			16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
15B. CONTRACTOR/OFFEROR (Same as Item 8)		15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY		16C. DATE SIGNED
_____ (Signature of person authorized to sign)			_____ (Signature of Contracting Officer)		

## Continuation Sheet

Responses to PPIs 1 – 27

PPI #	Reference			Question	Government Response
	Page	Section	Paragraph		
1				We have been reviewing the proposal submission requirements and we are a bit confused. Normally on a design-build, we are required to submit some type of drawings to demonstrate our proposed scope of work. This drawing is also accompanied by a narrative which provides additional details about the project requirements. This RFP does not ask for that. Is this not required or are you planning to issue an amendment revising the submission requirements to include this? If it is required, please also indicate whether it should be included in the Price Factor or the Non-Price Factor.	Bid Per RFP Documents
2	1	part 3, chapter 6	C30	The RFP is calling for the painting subcontractor to be SSPC QP-1 certified. While there is significant painting required of the steel work, there is more painting on the project that besides the steel. By holding the painting subcontractors to the SSPC QP-1 certification, this will limit the number of painting subcontractors that can bid the project and drive the cost upward on this item. Can the SSPC QP-1 certification requirement be removed from the RFP?	See Amendment Continuation Sheet
3		Part 3, chapter 4	127 Mens Restroom	The RFP for the Women's Restroom 125 calls for teak wood benches (uniformat Section E201003). This requirement is not shown in the description of work in the Men's Restroom 127. With the floor plan shown in Part 3, Chapter 4, Page 2, PP 4.2, the restrooms both look to have benches shown. Are the teak benches to be included in the Men's Restroom 127?	See Amendment Continuation Sheet
4	2	Part 3, chapter 4		In the Part Three Room Requirement Sheets for the Vestibule (101) it states that the projects two storefronts (B2030) with 3'X7' doors but a pair of doors are shown on the floor plan on Part 3, Chapter 4, Page 2, for the inner Vestibule doors. Is it the intent to have two entrance storefronts with a single outer door and a pair of doors for the inner?	Bid Per RFP Documents
5				In the Part Three Room Requirement Sheets for the Corridor (104) it states that the corridor is 4'-0" wide. The project requires handicap accessibility. 4'-0" is not wide enough for an in-swinging door approach for these corridors. Please clarify intent.	See Amendment Continuation Sheet
6	2	Part 3, chapter 4		In the Part Three Room Requirement Sheets and the floor plan on Part 3, Chapter 4, Page 2 for the CIO Storage (#105) what is counter and what is free standing shelving as stated in the Data Sheets. Please clarify.	Bid Per RFP Documents.

7	2	Part 3, chapter 4		In the Part Three Room Requirement Sheets for the Women's Restroom (#125) it states to have two showers but only one shower is indicated on the floor plan on Part 3, Chapter 4, Page 2. Please confirm shower count.	See Amendment Continuation Sheet
8	2	Part 3, chapter 4		In the Part Three Room Requirement Sheets for the Women's Restroom (#125) it states to have eight double tier lockers but only two lockers are shown on the floor plan on Part 3, Chapter 4, Page 2. The note on the plan says four double stacked. Please confirm locker count and types.	See Amendment Continuation Sheet
9	2	Part 3, chapter 4		In the Part Three Room Requirement Sheets for the Men's Restroom (#127) it states to have two showers but only one shower is indicated on the floor plan on Part 3, Chapter 4, Page 2. Please confirm shower count.	See Amendment Continuation Sheet
10	2	Part 3, chapter 4		In the Part Three Room Requirement Sheets for the Men's Restroom (#127) it states to have eight double tier lockers but only two lockers are shown on the floor plan on Part 3, Chapter 4, Page 2. The note on the plan says four double stacked. Please confirm locker count and types.	See Amendment Continuation Sheet
11		Photos	A-902	In the reference photos (A-902) it states to remove all contents of the pits/trenches and fill. Are these contents classed as "hazardous" or "combustible" by code?	See Amendment Continuation Sheet
12		Part 3, chapter 6	ESR B-20	Part 3 – Chapter 6 / ESR B20 states: "Confirm air barrier compliance with Air Barrier Performance Test in RFP Part 4". Is this the intent for this renovation project? If so, will the testing be only within the limits of the renovation work?	See Amendment Continuation Sheet
13		Part 3, Chapter 6	ESR B-30	It appears from the Part 3 – Chapter 6 / ESR B30 that we are to provide a new EPDM roof. Please confirm if the entire existing building receives the new roof of just within the limits of the renovation work? There is nothing indicated in the project description about a new roof.	See Amendment Continuation Sheet
14				Part 3 – Chapter 6 / ESR F2020 1.3 ASBESTOS states" Remove and dispose of the following asbestos-containing materials." The paragraph does not describe specific asbestos-containing materials. The cost of hazardous material abatement is a function of the findings of the Hazardous Materials Survey described in F2020. How would the Government like the Contractor to quantify the hazardous materials abatement costs, for purposes of responding to the RFP prior to the preparation of the Hazardous Materials Survey?	See Amendment Continuation Sheet
15				There are several ADA and egress violations on the given floor plan. Is the intent of the RFP to utilize this floor plan layout or will the design-build team be required to correct any violations shown?	See Amendment Continuation Sheet

16				There is an existing riser that serves OTHER areas of the building. It would be best to provide a new riser for the buildout so the existing riser is not shared, or would need to be shutdown during construction. Can new riser be made a requirement so all bidders are equal on this matter?	See Amendment Continuation Sheet
17				The new floor plan provided in the RFP under 4.2 SPACE Relationships shows a 2 hour wall required at corridor. If occupancy of new space is business, and the automotive portion will be Storage. This will require at a minimum a 1 hour rated wall and sprinklering on both sides, OR possibly a 2 hour wall pending actual floor areas. Please provide record drawings or state the separation wall requirements.	Bid Per RFP Documents
18		Part 3	Chapter 6	Part 3 – Chapter 6 Section D4020 The existing sprinkler riser serves areas outside the scope of work area (i.e. beyond the bays affected by P554). Adding a backflow preventer to the existing riser will increase required pressures for the existing sprinkler system - are there shop drawings for the existing system? There was no data plate on the riser. Without a full layout of the existing system it cannot be checked hydraulically for adequacy. Please advise what information is available so we can determine what is required to complete the design.	See Amendment Continuation Sheet
19		Part 3	Chapter 6	Part 3 – Chapter 6 Section D4020: Can it be assumed that beyond the work items stated in the RFP there will be no additional sprinkler system modifications required outside the P554 work area. If the Government does not quantify any sprinkler work required outside the P554 work area it will be assumed that none is required.	See Amendment Continuation Sheet
20		Part 3	Chapter 6	Part 3 – Chapter 6 Section D4020: Has the Government considered leaving the existing sprinkler system in place with no alterations and providing a new riser with BFP for the build out area. This appears to be a more defined scope of work.	See Amendment Continuation Sheet
21		01 35 26.05 20	1.6.1.1	Section 01 35 26.05 20 states that the CQC person cannot be the SSHO for the project. Section 01 45 00.05 20 alludes that the CQC cannot be the project superintendent either. Can the Project Superintendent be the SSHO or do all 3 administrative jobs have to be performed by separate individuals?	See Amendment Continuation Sheet
22				The RFP requests FINAL framed renderings, typical of a larger new design project. Are these renderings definitely required?	Bid Per RFP Documents
23		01 45 00.05 20	1.4.3.2	Does the project require a MECHANICAL QC specialist as requested by the RFP? If so, can the Mechanical DOR handle this responsibility?	See Amendment Continuation Sheet
24		01 45 00.05 20	1.4.3.4	Does the project require a ROOF QC specialist as requested by the RFP? If so, can the roofing subcontractor handle this responsibility?	Bid Per RFP Documents

25		01 45 00.05 20	1.4.3.3	Does the project require a Structural QC specialist as requested by the RFP? If so, can the Structural DOR handle this responsibility?	See Amendment Continuation Sheet
26		01 45 00.05 20	1.4.3.1	Does the project require a Fire Protection QC specialist as requested by the RFP?	Bid Per RFP Documents
27	215	Part 3 Chapter 2	2.3.6	Referenced UFC 4-010-01 Standard 18 (B-4.3.4) states the following: Where air handling equipment in heating, ventilating, and air conditioning systems is being replaced or when they are being upgraded, all provisions of Standard 18 will be applied to the building in which the new HVAC system is being installed. <u>Questions:</u> How many existing HVAC systems throughout LP-20 will require emergency shutdown? How many existing Outside Air Intakes, Relief Air, and Exhaust Openings need to be replaced with low leakage dampers? Provide damper sizing information.	See Amendment Continuation Sheet