

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE	OF PAGES
			J	1	2
2. AMENDMENT/MODIFICATION 0002	3. EFFECTIVE DATE 05/20/2016	4. REQUISITION/PURCHASE REQ.	PROJECT NO. (If applicable)		
6. ISSUED BY NAVFAC MID ATLANTIC HAMPTON ROADS IPT 9742 MARYLAND AVENUE NORFOLK, VA 23511		Code N40085 Code	7. ADMINISTERED BY (If other than item 6.)		Code
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)			<input checked="" type="checkbox"/>	9A. AMENDMENT OF SOLICITATION NO. N40085-16-R-6144	
			<input checked="" type="checkbox"/>	9B. DATED (SEE ITEM 11) 26-Apr -2015	
			<input type="checkbox"/>	10A. MODIFICATION OF CONTRACT/ORDER NO.	
				10B. DATED (SEE ITEM 13)	
CODE	FACILITY CODE				
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS					
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in item 14. The hour and date specified for receipt of Offers <input type="checkbox"/> is extended <input checked="" type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning <u>2</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already					
12. ACCOUNTING AND APPROPRIATION DATA (if required)					
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.					
<input type="checkbox"/>	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14. ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.				
<input type="checkbox"/>	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATION CHANGES (such as changes in Office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103 (b).				
<input type="checkbox"/>	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:				
<input type="checkbox"/>	D. OTHER: (specify type of modification and authority)				
E. IMPORTANT: Contractor <input type="checkbox"/> is not <input checked="" type="checkbox"/> is required to sign this document and return 1 copy to the issuing office.					
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)					
TOTAL SMALL BUSINESS DESIGN-BUILD/DESIGN-BID-BUILD MULTIPLE AWARD CONSTRUCTION CONTRACT FOR NEW CONSTRUCTION, RENOVATION, ALTERATION AND REPAIRS IN THE HAMPTON ROADS AREA OF VIRGINIA					
RM15-0619, Design-Bid-Build Repair and Renovate Bldg. 351 at Northwest Annex of Chesapeake, Va. (Work Order #1293116)					
Please see continuation page.					
Contract POC: RONALD.SMILEY2@NAVY.MIL, Phone: 757-341-0836					
15A. NAME AND TITLE OF SIGNER (Type or print)			16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
15B. CONTRACTOR/OFFEROR (Same as Item 8)		15C. DATE SIGNED	16B. UNITED STATES OF AMERICA		16C. DATE SIGNED
_____ (Signature of person authorized to sign)			BY _____ (Signature of Contracting Officer)		

This amendment is being issued to provide the following:

- Revisions to Plans and Specs
 - Attachment: 16R6144_AMEND0002_DWGS 10F1.pdf

REVISED PLANS AND SPECS

SPECIFICATIONS

SECTION 00102 LIST OF DRAWINGS

1.2 CONTRACT DRAWINGS

Sketches SKA-001, SKM-1, SKM-2, SKM-3, SKM-4, SKM-5, SKM-6, SKM-7, SKM-8, SKM-9, SKE-1 and SKE-2 are added to the list of drawings. These sketches accompany this amendment.

SECTION 01 14 00 WORK RESTRICTIONS

1.3 Occupied and Existing Buildings:

ADD the following paragraph:

“c. room 219 has existing telecom equipment that serves Northwest Buildings 351 & 366. Room 220 has existing telephone equipment that provides service to Northwest Buildings 144, 342, & 66. Rooms 219 and 220 shall remain in operation during the course of the project.”

SECTION 01 35 26 GOVERNMENTAL SAFETY REQUIREMENTS

1.7.1.2 Contractor Quality Control (QC) Manager:

DELETE this Paragraph in its entirety and REPLACE with the following:

“1.7.1.2 Contractor Quality Control (QC) Manager:

The Quality Control Manager cannot be the Site Safety and Health Officer.”

SECTION 01 45 00.00 20 QUALITY CONTROL

1.5.1.2 Qualifications

At the end of this paragraph ADD the following: “The Quality Control Manager cannot be the Site Safety and Health Officer.”

SECTION 08 51 13 ALUMINUM WINDOWS

1.11.5 Thermal Performance:

DELETE this Paragraph in its entirety and REPLACE with the following:

“1.11.5 Thermal Performance:

Non-residential aluminum windows (including frames and glass) must be certified by the National Fenestration Rating Council with a whole-window Solar Heat Gain Coefficient (SHGC) maximum of .173 determined according to NFRC 200 procedures and a U-factor maximum of .381 Btu/hr-ft²-F per NFRC-100 & .37 at user size.”

SECTION 08 51 13 ALUMINUM WINDOWS (CONTINUED)

2.1 Windows

In the last sentence of the paragraph after the text (minimum Condensation Resistance Factor (CRF) of), delete “35” and replace with “55”.