

1. CONTRACT ID CODE		PAGE	OF PAGES
J		1	2
2. AMENDMENT/MODIFICATION NO. 0003	3. EFFECTIVE DATE 26-Jul-2016	4. REQUISITION/PURCHASE REQ. NO.	PROJECT NO. (If applicable) RM13-1361
6. ISSUED BY Code OPHA NAVFAC MID ATLANTIC HAMPTON ROADS IPT 9324 VIRGINIA AVENUE NORFOLK, VA 23511-3095		7. ADMINISTERED BY (If other than item 6.) Code	
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)		<input checked="" type="checkbox"/>	9A. AMENDMENT OF SOLICITATION NO. N40085-16-R-6155
		<input checked="" type="checkbox"/>	9B. DATED (SEE ITEM 11) 28-Jun -2016
		<input type="checkbox"/>	10A. MODIFICATION OF CONTRACT/ORDER NO.
			10B. DATED (SEE ITEM 13)
CODE	FACILITY CODE		
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS			
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in item 14. The hour and date specified for receipt of Offers <input type="checkbox"/> is extended <input checked="" type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning ___ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.			
12. ACCOUNTING AND APPROPRIATION DATA (if required)			
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.			
<input type="checkbox"/>	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14. ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.		
<input type="checkbox"/>	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATION CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103 (b).		
<input type="checkbox"/>	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:		
<input type="checkbox"/>	D. OTHER: (specify type of modification and authority)		
E. IMPORTANT: Contractor <input checked="" type="checkbox"/> is not <input type="checkbox"/> is required to sign this document and return ___ copies to the issuing office.			
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)			
TOTAL SMALL BUSINESS DESIGN-BUILD/DESIGN-BID-BUILD MULTIPLE AWARD CONSTRUCTION CONTRACT FOR NEW CONSTRUCTION, RENOVATION, ALTERATION AND REPAIRS IN THE HAMPTON ROADS AREA OF VIRGINIA  <b>RM13-1361, Design-Build HVAC and DDC Facility Optimization at Naval Station Norfolk, Va. (Work Order #1333285)</b>  The purpose of this amendment is to provide PPI responses and a revised Price Proposal Form dated 7/26/2016 (attached) IAW PPI #52.  The proposal due date is Wednesday, July 28, 2016 at 2pm local time.  You are required to acknowledge ALL amendments in the revised Price Proposal Form.			
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.			
15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR (Same as Item 8)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA  BY _____	16C. DATE SIGNED
_____ (Signature of person authorized to sign)		_____ (Signature of Contracting Officer)	

Inquiry #	Reference			Inquiry	Government Response
	Page/Dwg	Section	Paragraph		
51	5	Part 3	4.1	RFP Part 3, 4.1 DDC Modifications states "Where VFD installation is required, only install VFDs for motors 10 HP and larger". The requirement for removal of inlet or discharge vanes for AHUs with fan motors larger than 10 HP and replacing with a VFD is not referenced on any of the building sheets. Please clarify if VFDs are to be added to any building systems.	Bid per RFP
52		PPF		Currently ITEM 0004- OPTION 3 is requesting pricing for a "FULL DDC UPGRADE" for buildings Z-133, C-9, LF-59, and SP-108. Please confirm the Government is requesting a FULL building upgrade of ALL DDC's and not and DDC points expansion as detailed in Part 3- Chapter 4- Page 2 of the RFP.	See attached revised PPF