



DEPARTMENT OF THE NAVY  
NAVAL FACILITIES ENGINEERING COMMAND MARIANAS  
PSC 455, BOX 195  
FPO AP 96540-2937

IN REPLY REFER TO:  
N40192-15-R-2900  
13 January 2015

**NOTICE 3**  
REQUESTS FOR INFORMATION AND RESPONSES  
SOLICITATION N40192-15-R-2900  
PAINTING INDEFINITE-DELIVERY / INDEFINITE/QUANTITY (IDIQ),  
VARIOUS LOCATIONS, GUAM

**CORRECTION:**

**QUESTION (Q)11:** As noted on the incumbent IDIQ practices, barricades and fall protection were not used. Will these safety measures be required on this IDIQ?

*Answer (A)11: Safety measures are required in the performance of the contract. Refer to Section 01 35 26 Governmental Safety Requirements of the solicitation for detailed information. Offerors are advised that the rates set forth in the Schedule of Indefinite Quantity Work Items (Exhibit Line Item Numbers) include all labor, safety controls, transportation, materials, equipment, and supervision necessary to perform the painting work. Pricing of the Indefinite Quantity Work Items is inclusive of all safety measures.*

**Q15:** We request the documents provided for Exhibit A Price Schedule: Base Period through Exhibit E Price Schedule: Fourth Option Period be re-issued in the source formatting, which we believe is Excel, in order to reduce the likelihood of error. When using .pdf converters, we find the results are not useful.

*A15: In order to minimize corruption of data, an Excel file of the exhibits will not be provided.*

**Q16:** We understand the requirements in terms of procedures in this section, delineating the steps to be taken in the event of the finding of lead, asbestos, and so forth. How do we determine that the work is required? Are we, for example required to institute a full lead and asbestos test by an industrial hygienist for each Task Order, or may we count on the Government to advise us of sites with these issues?

*A16: The requirements for lead or asbestos work will be identified in the project by the Government on a task order basis. Inadvertent discovery of non-disclosed lead or asbestos work requires a change in scope. Refer to Section 01 57 19.00 20 Temporary Environmental Controls of the solicitation for detailed information.*