



DEPARTMENT OF THE NAVY
NAVAL FACILITIES ENGINEERING COMMAND MARIANAS
PSC 455, BOX 195 FPO AP 96540-2937

IN REPLY REFER TO:
4330
PRU22SC/SFH
10 SEP 2016

SUBJ: SOLICITATION NUMBER N40192-16-Q-7061, Supply and Replace HVAC Parts, Guam Air National Guard, AAFB, Guam

Amendment 0001- This is in regard to the solicitation notice posted to the Navy Electronic Commerce Online (NECO) Website on 07 September 2016 for solicitation no. N40192-16-Q-7061, Supply and Replace HVAC Parts, Guam Air National Guard, AAFB, Guam

1. This Amendment 0001 is issued to accomplish the following:
 - a. Provide answers to any requests for information as shown below. Both inquiries and answers therein are hereby incorporated as solicitation provisions.

No.	Date	Questions	Answers
1	9/10/16	SOW indicate to replace only Compressor A-1. Are we not replacing the 3 compressors? To make the unit more efficient.	As stated in the specifications, the requirement is to replace Compressor A-1 only at this time.
2	9/10/16	Please specify how many circuits does this unit have.	The unit has one (1) circuit.
3	9/10/16	During site visit yesterday, the unit interior flooring was already corroded & since we're going to replace compressors and condensing coils, is it not more practical if we'll replace the whole condensing unit?	The requirement is to replace the compressor (A-1), condensing coils, and other items as stated in the specifications at this time.

- b. The quote due date is remains the same at no later than 10:00 A.M. on Wednesday, 14 September 2016 (Guam Standard Date and Time).
2. All other provisions and terms remain the same.

3. Quoters shall acknowledge all solicitation amendments (signature line provided below).

Sincerely,



Sheena Hess
Contract Specialist

Contractor Acknowledgment:

Signature

Date

Name & Title