

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE J	PAGE OF PAGES 1 3
2. AMENDMENT/MODIFICATION NO. 0003		3. EFFECTIVE DATE 26-Aug-2015	4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO.(If applicable)
6. ISSUED BY NAVAC SOUTHWEST POINT LOMA FEAD/CODE ROPML NAVAL BASE POINT LOMA 4635 PACIFIC HWY SAN DIEGO CA 92110-2756		CODE N62473	7. ADMINISTERED BY (If other than item 6) See Item 6		
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)				X	9A. AMENDMENT OF SOLICITATION NO. N62473-15-R-1012
				X	9B. DATED (SEE ITEM 11) 17-Aug-2015
					10A. MOD. OF CONTRACT/ORDER NO.
					10B. DATED (SEE ITEM 13)
CODE		FACILITY CODE			
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS					
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.					
12. ACCOUNTING AND APPROPRIATION DATA (If required)					
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.					
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.					
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).					
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:					
D. OTHER (Specify type of modification and authority)					
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.					
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) Update/Revise Scope of Work as of 08/26/2015.					
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.					
15A. NAME AND TITLE OF SIGNER (Type or print)			16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
			TEL: _____ EMAIL: _____		
15B. CONTRACTOR/OFFEROR _____ (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED 26-Aug-2015	

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

SECTION A - SOLICITATION/CONTRACT FORM

The following have been added by full text:

AMENDMENT 03PROJECT PROGRAMRevised Scope of Work

A Pre-proposal conference/ Site visit was conducted on August 26, 2015. The following changes have been incorporated into the Scope of Work for the seed project (please refer to amendment 0002):

Division 02: Demolition

- a) Contractor shall reuse the existing 8 penetrations for supply and return ducting, but shall demo the roofing needed to install A/C into the (2) server rooms.
- b) Contractor shall demo CW piping from the existing units back to the main tie in shut off valve.
- c) Contractor shall demo existing flex ducting, allowing only 5' of flex per register.
- d) Contractor shall demo the existing light switches and relocate switch/sensor of zone 4 and zone 5.

Division 09: Finishes

- a) Contractor shall reseal roof after (new penetrations and new roof curbs) have been installed.
- b) Contractor shall install drywall and paint as needed to provide a completed and finished product after demo of (lighting and ducting) has occurred.
- c) Contractor shall provide and install permanent fall protection railing around the entire roof of this building.
- d) Contractor shall provide a full height internal wall for server room B: This does not allow a drop ceiling for this space.

Division 22 Plumbing:

- a) Contractor shall provide a second fire sprinkler head located in server room for proper coverage.

Division 23: HVAC

- a) Contractor shall install lockable thermostat covers over the new programmable thermostats
 - a. The thermostat shall be Viconics VT7600 or equivalent to be reviewed by POC.
 - b. Thermostat for 2 ton unit shall be in server room A.
- b) Contractor shall paint all ceiling ducting black to match existing ceiling color, and contractor shall only use a max length 5ft whip of flex ducting for landing each register.
- c) Contractor shall have 5000+ hr salt spray coating on the heating and cooling coils on each unit.

Division 26 Electrical

- a) Contractor shall install CREE 2x4 troffer capable and pendant mounted units: or equivalent product to be reviewed by POC.
- b) Contractor shall install 2 stage lighting with (dual dimmer switches) on zones 1-3.
- c) Contractor shall install single lighting control with motion sensor in zone 4-5.
- d) Contractor shall install a dimming system for the conference room allowing switching and secondary dimming control of each row of lights moving from the front to back:
 - a. Contractor shall replace lamp for lamp in this conference room with the drop ceiling

All other terms and conditions of this solicitation remain unchanged.

SECTION J - LIST OF DOCUMENTS, EXHIBITS AND OTHER ATTACHMENTS

The Table of Contents has changed from:

Exhibit/Attachment Table of Contents

DOCUMENT TYPE	DESCRIPTION	PAGES	DATE
Attachment 2	FORMS		25-AUG-2015
Attachment 3	Replace Air Handling Units (UHA) at SOC		21-AUG-2015

to:

Exhibit/Attachment Table of Contents

DOCUMENT TYPE	DESCRIPTION	PAGES	DATE
Attachment 2	FORMS		25-AUG-2015
Attachment 3	Replace Air Handling Units (UHA) at SOC		21-AUG-2015
Attachment 4	Pictures Seed Project		26-AUG-2015

(End of Summary of Changes)



SERIAL NO. K96F47281

DATE: 06/96

TAG: AHU-1

MODULE 07 OF 07

SERVICE MODEL NO. MODULE

-----+-----1-----+-----2-----+-----3-----+-----4-----
MCCA008FBC0A0000A0



ORDER NO. W3C220A B/M A

THE TRANE COMPANY, A DIVISION OF AMERICAN STANDARD INC. MADE IN U.S.A.

X1950287-01

FIELD LIFTING INSTRUCTIONS
(MODULAR CLIMATE CHANGER ON BASERAIL)



A Participating Corporation
in the ARI 430
Certification Program

FAN SECTION MODULE
HORIZONTAL

SERIAL NO. K96F47195

DATE: 06/96

MODULE 06 OF 07

TAG: AHU-4


SERVICE MODEL NO. MODULE

MCCA00SGAM0ABA000E0EAAA0AAA0000AA000C000000

MOTOR
VOLTAGE
460/50/3

MOTOR
HORSEPOWER
5

EXTERNAL OVERLOAD DEVICE IN ACCORDANCE WITH THE NATIONAL
ELECTRICAL CODE (OR NEC) IS REQUIRED WHEN NOT PROVIDED
BY TRANE.



ORDER NO. W3C220A B/M D

THE TRANE COMPANY, A DIVISION OF AMERICAN STANDARD INC. MADE IN U.S.A. X390018-00

IMPORTANT
DO NOT INSTALL
BEFORE READING INSTALLATION
AND MAINTENANCE MANUAL
LOCATED INSIDE UNIT.

WARNING
PRODUCT CONTAINS FIBERGLASS WOL
REFER TO OWNER'S INFORMATION MANUAL
PROVIDED WITH THIS UNIT FOR PROPER
INSTALLATION, OPERATION AND MAINTENANCE
INSTRUCTIONS



WARNING
HAZARDOUS VOLTAGE!
DISCONNECT ALL ELECTRIC POWER
INCLUDING REMOTE DISCONNECTS
BEFORE SERVICING.



MEDIUM COIL MODULE SECTION
HORIZONTAL

SERIAL NO. K96F47194

DATE: 06/96

TAG: AHU-4

MODULE 05 OF 07


SERVICE MODEL NO. MODULE

-----1-----+-----2-----+-----3-----+-----4
MCCA008BBE0AAC00000

SERVICE MODEL NO. COIL

-----1-----+-----2-----+-----3-----+-----4
DUWB28040A0EB127CAAD00A00000

ORDER NO. W3C220A B/M D



X39060018-00

THE TRANE COMPANY, A DIVISION OF AMERICAN STANDARD INC. MADE IN U.S.A.

X39500287-01

WATER INLET



ACCESS SECTION MODULE
SMALL


SERIAL NO. K96F47193

DATE: 06/96

TAG: AHU-4

MODULE 04 OF 07

SERVICE MODEL NO. MODULE



MCCA008AADOA0A000000

ORDER NO. W3C22QA B/M D





MIXING BOX MODULE
W/ FILTER FRAME

SERIAL NO. K96F47192

DATE: 06/96

TAG: AHU-4

MODULE 03 OF 07

SERVICE MODEL NO. MODULE

-----+-----1-----+-----2-----+-----3-----+-----4-----
MCCA008MAE0AAA0DD0AA000000





MIXING BOX MODULE

SERIAL NO. K96F47191

DATE: 06/96

MODULE 02 OF 07

TAG: AHU-4

SERVICE MODEL NO. MODULE

-----1-----+-----2-----+-----3-----+-----4-----
MCGA008MAE0AA000DD000000000

ORDER NO. W96220A B/M D



THE TRANE COMPANY, A DIVISION OF AMERICAN STANDARD INC. MADE IN U.S.A.

12/93/0000EX