

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE J	PAGE OF PAGES 1 2
2. AMENDMENT/MODIFICATION NO. 0001	3. EFFECTIVE DATE 19-Aug-2015	4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO.(If applicable)
6. ISSUED BY NAVFAC HAWAII CONSTRUCTION ACQUISITION DIV (OPHA2) 400 MARSHALL ROAD JBP HH HI 96860-3139	CODE N62478	7. ADMINISTERED BY (If other than item 6) See Item 6		
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)		X	9A. AMENDMENT OF SOLICITATION NO. N62478-15-B-1502	
		X	9B. DATED (SEE ITEM 11) 28-Jul-2015	
			10A. MOD. OF CONTRACT/ORDER NO.	
			10B. DATED (SEE ITEM 13)	
CODE	FACILITY CODE			
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS				
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.				
12. ACCOUNTING AND APPROPRIATION DATA (If required)				
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.				
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.				
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).				
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:				
D. OTHER (Specify type of modification and authority)				
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.				
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) Invitation for Bid No. N62478-15-B-1502, Construct Exterior Stairway, Bauer Road, Camp Smith, Hawaii				
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.				
15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
		TEL:	EMAIL:	
15B. CONTRACTOR/OFFEROR _____ (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED 19-Aug-2015

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

The following items are applicable to this modification:

REVISED SUMMARY OF CHANGES

Add Document 00900, Responses to Questions.

DOCUMENT 00900
RESPONSES TO QUESTIONS SUBMITTED FOR
RFP NO. NO. N62478-15-B-1502

CONSTRUCT EXTERIOR STAIRWAY, BAUER ROAD, CAMP SMITH, HAWAII

- Q1. Sheet E101. Would it be possible to run the underground electrical utilities along the same side as the parking lot? There is some saw cutting of the existing parking lot but the work will be much less than having to remove the fence and bring equipment over to clear all the shrub and trees to trench for the electrical utilities.
- A1. Yes, sawcutting through existing slab is okay provided that the pavement is repaired to existing or better condition. The existing concrete parking lot has a thickened edge that is 12 wide by 12" thick. Repair to the concrete pavement shall match existing dimensions and be tied back to the existing concrete pavement using #4 rebar at 24" o.c. with minimum 6" embedment with epoxy and a #4 continuous longitudinal rebar. Maintain 3" clearance on sides and 2" clear on top and bottom of concrete surfaces from rebar. Toneable warning tape shall be installed 6" below the new concrete slab. The contractor shall assume that tree roots will be encountered and shall be cut and removed prior to installation of new work. Provide chemical root barrier on the tree side edge of the trench to reach the full depth of the conduit.
- Q2. On sheet E-101 the location of the new electrical buried conduit is located on the outside of the fence. Due to the amount of trees growing on the outside of the fence would it be possible to saw cut the existing concrete, trench and install the electrical conduit and install new concrete where the concrete was removed.
- A2. See response to Q1.