

2. AMENDMENT NO. 0007	3. EFFECTIVE DATE 02 June 2015	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. <i>(If applicable)</i>
---------------------------------	--	----------------------------------	---------------------------------------

6. ISSUED BY CODE	7. ADMINISTERED BY <i>(If other than Item 6)</i> CODE
Naval Facilities Engineering Command Pacific (ACQ31) Building 62 4262 Radford Drive Honolulu HI 96818-3296	

8. NAME AND ADDRESS OF CONTRACTOR <i>(No., street, county, State and ZIP Code)</i>	9A. AMENDMENT OF SOLICITATION NO. <input checked="" type="checkbox"/> N62742-15-R-1305
	9B. DATED <i>(SEE ITEM 11)</i> 09 April 2015
	10A. MODIFICATION OF CONTRACT NO. <input type="checkbox"/>
	10B. DATED <i>(SEE ITEM 13)</i>
CODE	FACILITY CODE

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in item 14. The hour and date specified for receipt of offers is extended, is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:
(a) By completing Items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or © By separate letter or telegram which includes a reference to the solicitation and amendment numbers. **FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER.** If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA *(If required)*

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS, IT MODIFIES THE CONTRACT NO. AS DESCRIBED IN ITEM 14.

<input type="checkbox"/>	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: <i>(Specify authority)</i> THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT NO. IN ITEM 10A.
<input type="checkbox"/>	B. THE ABOVE NUMBERED CONTRACT IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES <i>(such as changes in paying office, appropriation date, etc.)</i> SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
<input type="checkbox"/>	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
<input type="checkbox"/>	D. OTHER <i>(Specify type of modification and authority)</i>

E. IMPORTANT: Contractor is not, is required to sign this document and return ___ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT *(Organized by UCF section headings, including solicitation/contract subject matter where feasible.)*
WON 1312011, FY15 MCON P861, FACILITY MODIFICATIONS FOR VMU, MWSD AND CH53E, MARINE CORPS BASE HAWAII, KANEOHE, HAWAII

The date and time for submission of proposals remains:
June 09, 2015 at 2:00 p.m. HST

See next page

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER <i>(Type or print)</i>	16A. NAME OF TITLE OF CONTRACTING OFFICER <i>(Type or print)</i>		
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA	16C. DATE SIGNED
_____ <i>(Signature of person authorized to sign)</i>		BY _____ <i>(Signature of Contracting Officer)</i>	

This modification is issued as follows:

FRONT END REVISIONS NARRATIVELY:

1. Amendment 0005 issued 29 May 2015 is revised as follows:

Amend Block 2, Amendment No. from "0005" to "0006"

2. Document 00700, paragraph 1.25 FAR 52.211-10, COMMENCEMENT, PROSECUTION, AND COMPLETION OF WORK (APR 1984), 1ST paragraph, 3rd line, "940 calendar days" is revised to "1,045 calendar days"

SPECIFICATION SECTIONS REVISED NARRATIVELY:

3 Section 01 11 00, Summary of Work, paragraph 1.10, is amended to add "unless designated otherwise" between "salvageable materials" and "shall become"

4. Section 01 14 00, Work Restrictions, paragraphs 1.2.d. and 1.2.e. are deleted in their entirety and replaced with the following:

"d. A Historic American Buildings Survey (HABS), currently in process, is required prior to commencing work on HANGAR 102. Construction on Hangar 102 cannot commence until after February 15, 2016, which is the anticipated completion date of the HABS, unless the final HABS is completed earlier.

e. The NPDES permit is being processed by the Government. Ground disturbing activities, including mobilization to the site, cannot commence until after February 15, 2016, which is the date the Government anticipates receiving the NPDES NOI, unless the NPDES NOI is completed earlier."

DRAWING REVISIONS NARRATIVELY:

5. Amendment 0006, issued 29 May 2015, Item No. 13, Sketch SKC-B005, is deleted in its entirety.

6. DWG CB-102, Note 2, is amended to include the following after the last sentence:

"Restore all disturbed areas with 6" base course to match existing grade."

NO.	SHEET NO.	DESCRIPTION
<u>7.</u>	A-511	Revise Detail A3 title from "Not Used" to "Window Sill Detail".
<u>8.</u>	AB-601	Add Remark 1 for doors B123B and B124B under remarks column.
<u>9.</u>	AD-101	C1 / AD-101 FIRST FLOOR EXISTING REFLECTED CEILING DEMOLITION PLAN: Remove all existing suspended acoustic panel ceiling system between gridlines A through N and between gridlines 0.1 and 2. Mechanical, Fire Protection, Electrical and Telecom removal work described elsewhere.
<u>10.</u>	AD-102	AD-102 SECOND FLOOR EXISTING REFLECTED CEILING DEMOLITION PLAN: Remove all existing suspended acoustic panel ceiling system between gridlines A through N and between gridlines 0.1 and 2. Mechanical, Fire Protection, Electrical and Telecom removal work described elsewhere.
<u>11.</u>	AD-121	C1 / AD-121 PARTIAL FIRST FLOOR REFLECTED CEILING PLAN: Provide all new 2X2 suspended acoustic panel ceiling system between gridlines A through G and between gridlines 0.1 and 2 except where noted to be gypsum wallboard ceiling. Mechanical, Fire Protection, Electrical and Telecom work described elsewhere.

<u>12.</u>	AD-121	A1 / AD-121 PARTIAL FIRST FLOOR REFLECTED CEILING PLAN: Provide all new 2X2 suspended acoustic panel ceiling system between gridlines G through N and between gridlines 0.1 and 2 except where noted to be gypsum wallboard ceiling. Mechanical, Fire Protection, Electrical and Telecom work described elsewhere.
<u>13.</u>	AD-122	C1 / AD-122 PARTIAL SECOND FLOOR REFLECTED CEILING PLAN: Provide all new 2X2 suspended acoustic panel ceiling system between gridlines A through G and between gridlines 0.1 and 2 except where noted to be gypsum wallboard ceiling. Mechanical, Fire Protection, Electrical and Telecom work described elsewhere.
<u>14.</u>	AD-122	A1 / AD-1221 PARTIAL SECOND FLOOR REFLECTED CEILING PLAN: Provide all new 2X2 suspended acoustic panel ceiling system between gridlines G through N and between gridlines 0.1 and 2 except where noted to be gypsum wallboard ceiling. Mechanical, Fire Protection, Electrical and Telecom work described elsewhere.
<u>15.</u>	ED-103	All existing luminaires currently shown to remain in existing grid ceilings shall be removed and saved for re-installation to accommodate removal of existing ceiling.
<u>16.</u>	ED-105	All existing luminaires currently shown to remain in existing grid ceilings shall be removed and saved for re-installation to accommodate removal of existing ceiling.
<u>17.</u>	ED-107	All luminaires shown as existing shall be re-installed in new grid ceiling. All other notes on drawings still apply.
<u>18.</u>	ED-109	All luminaires shown as existing shall be re-installed in new grid ceiling. All other notes on drawings still apply.
<u>19.</u>	ED-103, ED-105, ED-107 and ED-109	Add General Note – Contractor shall refer to Architectural Reflected Ceiling Plan for new ceiling work.

DRAWING REVISIONS BY SKETCH:

NO.	SKETCH NO.	SHEET NO.	DESCRIPTION
<u>20.</u>	SKC-002	C-506	Revised detail C2. Provide shallow manhole per sketch for the manhole that the lift station force main outlets to near B4078.
<u>21.</u>	SKC-003	C-507	Revised detail B1. Revised 6" thick bottom wall of trench drain.
<u>22.</u>	SKC-A003	CA-109	DEDUCTIVE ITEM 1 - B373 PAVEMENT, SALVAGE EXISTING AC PAVEMENT AREA. Revised grading plan to match existing AC pavement elevations.
<u>23.</u>	SKC-A004	CA-109	DEDUCTIVE ITEM 1 - B373 PAVEMENT, SALVAGE EXISTING AC PAVEMENT AREA. Revised grading plan to match existing AC pavement elevations.
<u>24.</u>	SKC-A005	CA-111	DEDUCTIVE ITEM 1 - B373 PAVEMENT, SALVAGE EXISTING AC PAVEMENT AREA. Revised storm drainage pipes and subsurface storage to salvage AC pavement area.
<u>25.</u>	SKC-A006	CA-111	DEDUCTIVE ITEM 1 - B373 PAVEMENT, SALVAGE EXISTING AC PAVEMENT AREA. Revised storm drainage pipes and subsurface storage to salvage AC pavement area.
<u>26.</u>	SKC-A007	CA-201	DEDUCTIVE ITEM 1 - B373 PAVEMENT, SALVAGE EXISTING AC PAVEMENT AREA. Revised storm drainage pipes and subsurface storage to salvage AC pavement area.
<u>27.</u>	SKC-A008	CA-201	DEDUCTIVE ITEM 1 - B373 PAVEMENT, SALVAGE EXISTING

			AC PAVEMENT AREA. Revised storm drainage pipes and subsurface storage to salvage AC pavement area.
<u>28.</u>	SKC-A009	CA-201	DEDUCTIVE ITEM 1 - B373 PAVEMENT, SALVAGE EXISTING AC PAVEMENT AREA. Revised storm drainage pipes and subsurface storage to salvage AC pavement area.
<u>29.</u>	SKC-A010	CA-201	DEDUCTIVE ITEM 1 - B373 PAVEMENT, SALVAGE EXISTING AC PAVEMENT AREA. Revised storm drainage pipes and subsurface storage to salvage AC pavement area.

30. All other terms and conditions remain unchanged.