

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>			1. CONTRACT ID CODE	PAGE OF PAGES <b>1</b>   <b>5</b>
2. AMENDMENT NO. <b>0003</b>		3. EFFECTIVE DATE <b>08 DEC 2015</b>	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable)
6. ISSUED BY CODE		7. ADMINISTERED BY (If other than Item 6) CODE		
<b>Naval Facilities Engineering Command Pacific (ACQ31)</b> <b>Building 62</b> <b>4262 Radford Drive</b> <b>Honolulu HI 96818-3296</b>				
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)			<input checked="" type="checkbox"/> 9A. AMENDMENT OF SOLICITATION NO. <b>N62742-16-R-1312</b>	<input checked="" type="checkbox"/> 9B. DATED (SEE ITEM 11) <b>05 NOVEMBER 2015</b>
			<input type="checkbox"/> 10A. MODIFICATION OF CONTRACT NO.	<input type="checkbox"/> 10B. DATED (SEE ITEM 13)
CODE	FACILITY CODE			
<b>11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS</b>				
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in item 14. The hour and date specified for receipt of offers <input checked="" type="checkbox"/> is extended, <input type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or © By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.				
12. ACCOUNTING AND APPROPRIATION DATA (If required)				

<b>13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS, IT MODIFIES THE CONTRACT NO. AS DESCRIBED IN ITEM 14.</b>	
<input type="checkbox"/>	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT NO. IN ITEM 10A.
<input type="checkbox"/>	B. THE ABOVE NUMBERED CONTRACT IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
<input type="checkbox"/>	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
<input type="checkbox"/>	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor  is not,  is required to sign this document and return \_\_\_ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)  
**RFP: N62742-16-R-1312, FY16 DEF (DHA), PROJECT 78150, MEDICAL/DENTAL CLINIC REPLACEMENT, MARINE CORPS BASE HAWAII, KANEOHE BAY, HAWAII**

**The date and time for submission of proposals is revised to:**  
**January 06, 2016 at 2:00 p.m. HST**

See next page

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME OF TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA	16C. DATE SIGNED
_____ (Signature of person authorized to sign)		BY _____ (Signature of Contracting Officer)	

This amendment is issued for the following:

**FRONT END REVISIONS - NARRATIVE**

**1.** Document 00100, paragraph 1.1 Number of Copies/Time of Receipt, subparagraph a., b., and c. are revised follows:

- a. Subparagraph a. Replace **09 December 2015, 2:00 p.m. HST** with **06 January 2016, 2:00 p.m. HST**.
- b. Subparagraph b. Replace **09 December 2015, 2:00 p.m. HST** with **06 January 2016, 2:00 p.m. HST**.
- c. Subparagraph c. Replace **10 December 2015, 2:00 p.m. HST** with **07 January 2016, 2:00 p.m. HST**.

**2.** Document 00600, is deleted in its entirety and replaced with the attached Document 00600, Rev 1.

**3.** Document 00700, paragraph 1.25, FAR 52.211-10, Commencement, Prosecution and Completion of Work, 1<sup>st</sup> paragraph, "**780** calendar days" is revised to "**835** calendar days"

**SPECIFICATION REVISIONS**

**PROJECT TABLE OF CONTENTS**

- Add Section 07 05 23, PRESSURE TESTING AN AIR BARRIER SYSTEM FOR AIR TIGHTNESS to the Project Table of Contents. This section accompanies this Amendment. See Attachment (1).

**DOCUMENT 00 01 15 – LIST OF DRAWINGS**

- PARA 1.2 CONTRACT DRAWINGS: The following drawings, bearing revision date of 11-24-2015, supersede previously issued drawings bearing the same number and title. The revised drawings accompany this Amendment. See Attachment (2).

NAVFAC DWG NO.	SHEET NO.	REVISION NO.	TITLE
19055937	A-310	1	EXTERIOR WALL SECTIONS
19055938	A-311	1	EXTERIOR WALL SECTIONS,
19055939	A-312	1	EXTERIOR WALL SECTIONS
19055940	A-313	1	EXTERIOR WALL SECTIONS
19055941	A-314	1	CANOPY SECTION
19055942	A-315	1	EXTERIOR WALL SECTIONS
19055943	A-316	1	CANOPY SECTION
19055944	A-317	1	EXTERIOR WALL SECTIONS
19055945	A-318	1	EXTERIOR WALL SECTIONS

- PARA 1.2 CONTRACT DRAWINGS: Changes as directed below shall be made to the respective drawings. Drawings incorporating the directed changes are not issued with this Amendment.

NAVFAC DWG NO.	CHANGE NO.	SHEET NO./TITLE/DIRECTED CHANGES
19055805	(1)	S-001 GENERAL NOTES At III. GENERAL REQUIREMENTS, Note #7, replace Note #7 with the following "7. ALL PIPE PENETRATIONS THROUGH CONCRETE WALLS, FLOOR SLABS AND BEAMS SHALL BE FORMED WITH CAST-IN GALVANIZED STEEL PIPE SLEEVES."
19056025		A-607 SIGNAGE TYPES

N62742-16-R-1312, FY16 DEF (DHA), PROJECT 78150,  
MEDICAL/DENTAL CLINIC REPLACEMENT, MARINE  
CORPS BASE HAWAII, KANEOHE BAY, HAWAII

- (1) At DEPARTMENTAL SIGNAGE TYPES, "Notes for Departmental Signs", Note #1, change "150 mm" to "229 mm".
  - (2) At DEPARTMENTAL SIGNAGE TYPES, change the dimension "150" to "229".
- 19055923                    A-172 ROOF DETAILS
- (1) At Detail A1 ROOF DRAIN & OVERFLOS DRAIN DETAIL – SC4, delete "(See Plumbing)" at callout for "Roof Drain Pipe" and "Overflow Drain Pipe" at the bottom of the detail.
- 19055927                    A-176 ROOF DETAILS
- (1) At Details A1 and C1, delete "Aluminum Gutters" and replace with "Stainless Steel". All gutters are painted stainless steel.

**SECTION 01 45 00.00 20 – QUALITY CONTROL**

- PARA. 1.5.5 QC Specialists Duties and Qualifications: After the text of this paragraph, delete the table in its entirety and replace it with the attached table of QC Specialists Duties and Qualifications. See Attachment (3).
- PARA. 1.5.8 Submittal Reviewers Duties and Qualifications: After the text of this paragraph, delete the table in its entirety and replace it with the attached table of Submittal Reviewers Duties and Qualifications. See Attachment (4).
- Test/Requirements List: Insert Test/Requirements List for Divisions 02-33 after Test/Requirements List for Division 01 at the end of this section. This List for Divisions 02-33 accompanies this Amendment. See Attachment (5).

**SECTION 07 27 27 – FLUID-APPLIED MEMBRANE VAPOR/MOISTURE BARRIERS**

- PARA. 1.3 SUBMITTALS: At SD-07 Certificates, before "Vapor/Moisture Barrier Assemblies", inset a new submittal requirement for Government approval: "Qualification of Installer"
- PARA. 1.5.1 Installer Qualifications, At the 2<sup>nd</sup> un-numbered paragraph, delete "Installer shall be licensed by ABAA according to ABAA's Quality Assurance Program and shall employ ABAA-certified installers and supervisors on Project." and replace with "Submit documentation demonstrating that the Installer has been trained by the manufacturer, has experience satisfactory to the manufacturer, and is authorized by the manufacturer to install the products specified."

**SECTION 07 05 23 – PRESSURE TESTING AN AIR BARRIER SYSTEM FOR AIR TIGHTNESS**

- Insert Section 07 05 23, PRESSURE TESTING AN AIR BARRIER SYSTEM FOR AIR TIGHTNESS. This section accompanies this Amendment. See Attachment (1).

**SECTION 08 22 20 – FIBERGLASS REINFORCED PLASTIC (FRP) DOORS AND FRAMES**

- PARA. 1.2.1 Pre-Installation Meeting: In the first sentence, change "30 days" to "90 days".

**SECTION 08 56 54 – BLAST RESISTANT FAÇADE SYSTEMS**

- Delete Section 08 56 54 BLAST RESISTANT FAÇADE SYSTEMS in its entirety and replace with Section 08 56 54 BLAST RESISTANT FAÇADE SYSTEMS (Revised 11-25-15). The revised Section accompanies this Amendment. See Attachment (6).

**SECTION 10 14 01 – EXTERIOR SIGNAGE**

- PARA. 2.2.5 Mounting: After this paragraph, insert new paragraph as follows:

“2.2.6 Location

Building Identification Number will be assigned by the Government during construction. Building Identification Numbers will be up to 6 digits/letters, mounted at the corners of the building facing all points of the compass, and spaced a maximum of 60 meters (200 feet) apart.”

**SECTION 14 24 00 – HYDRAULIC ELEVATORS**

---

- PARA. 1.1 REFERENCES: At the bottom of the list, and after the last reference, insert:  
“OTHER APPLICABLE DOCUMENTS, NAVFAC(2013) Interim Technical Guidance (ITG 2013-01) Elevator Design, including Enclosure (1) ITG 2013-01 NAVFAC ELEVATOR DESIGN dated 1 August 2013”

**SECTION 22 00 70 – PLUMBING, HEALTHCARE FACILITIES**

---

- PARA. 3.6.1 Sleeve Requirements, Lines 26-29: Delete “Sleeves in bearing walls and concrete slab on grade floors shall be steel pipe or cast-iron pipe. Sleeves in nonbearing walls or ceilings may be steel pipe, cast-iron pipe, galvanized sheet metal with lock-type longitudinal seam, or plastic.” and replace with “Sleeves in concrete walls shall be cast-in galvanized steel pipe.”

**SECTION 23 11 25 – FACILITY GAS PIPING**

---

- PARA. 1.5.3 Shop Drawings: In the first sentence, change "30 days" to "90 days".

**SECTION 23 00 00 – AIR SUPPLY DISTRIBUTION, VENTILATION, AND EXHAUST SYSTEMS**

---

- PARA. 2.9.13 Radon Exhaust Ductwork: Delete this paragraph and replace with “2.9.13 Not Used.”
- PARA. 2.9.13 Radon Exhaust Ductwork: After paragraph 2.9.13, insert new paragraph 2.9.14 as follows:

- “2.9.14 Heat Removal Hood

The lab heat removal hood shall be fabricated of Type 430 stainless steel with #3 or #4 polish on all exposed surfaces. The hood shall be manufactured to overhang the covered equipment by a minimum of 125 mm in each direction. The hood shall have liquid tight seams, shall have a minimum depth of 500 mm and a maximum depth of 600 mm. The bottom of the hood will be a maximum of 2000 mm above the finished floor. There shall be no sharp edges or corners. All edges and corners will be bent or rounded to eliminate bodily injury. A single 350 x 350 mm exhaust collar with a 20 mm duct connection flange will be provided near the center of the hood. The hood will be supported at the four corners by utilizing threaded connectors or L-brackets and a minimum of 10 mm stainless steel all thread rods connected to the structure above. The hood shall be braced to the rear wall to provide stability. The hood shall be manufactured by the contractor or purchased pre-made to meet these specifications.”

- PARA. 3.2.5.1 Radon Exhaust Ductwork: Delete this paragraph and replace with “3.2.5.1 Not Used.”
- PARA. 3.9 DUCTWORK LEAK TEST: Delete this paragraph and replace with “3.9 NOT USED.”

**SECTION 31 62 13.20 – PRECAST/PRESTRESSED CONCRETE PILES**

---

Delete Section 31 62 13.20 PRECAST/PRESTRESSED CONCRETE PILES in its entirety and replace with Section 31 62 13.20 PRECAST/PRESTRESSED CONCRETE PILES (Revised 11-25-15). The revised Section accompanies this Amendment. See Attachment (7).

N62742-16-R-1312, FY16 DEF (DHA), PROJECT 78150,  
MEDICAL/DENTAL CLINIC REPLACEMENT, MARINE  
CORPS BASE HAWAII, KANEOHE BAY, HAWAII

4. All other terms and conditions remain unchanged.

-- End of Amendment --