

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE J	PAGE OF PAGES 1 3
2. AMENDMENT/MODIFICATION NO. 0007	3. EFFECTIVE DATE 22-Dec-2015	4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO.(If applicable)
6. ISSUED BY NAVFAAC SOUTHEAST IPT GULFCOAST BLDG 903, PO BOX 30 NAS JACKSONVILLE JACKSONVILLE FL 32212-0030		CODE N69450	7. ADMINISTERED BY (If other than item 6) See Item 6	
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)			<input checked="" type="checkbox"/>	9A. AMENDMENT OF SOLICITATION NO. N69450-15-R-0606
			<input checked="" type="checkbox"/>	9B. DATED (SEE ITEM 11) 30-Mar-2015
			<input type="checkbox"/>	10A. MOD. OF CONTRACT/ORDER NO.
			<input type="checkbox"/>	10B. DATED (SEE ITEM 13)
CODE		FACILITY CODE		
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS				
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.				
12. ACCOUNTING AND APPROPRIATION DATA (If required)				
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.				
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.				
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).				
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:				
D. OTHER (Specify type of modification and authority)				
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.				
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) N69450-15-R-0606 TENNESSEE, MISSISSIPPI AND FLORIDA PANHANDLE AREA INDEFINITE DELIVERY INDEFINITE QUANTITY (IDIQ) MULTIPLE AWARD CONSTRUCTION CONTRACT (MAAC). SEE PAGE 2 CONTINUATION				
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.				
15A. NAME AND TITLE OF SIGNER (Type or print)			16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
			TEL: _____ EMAIL: _____	
15B. CONTRACTOR/OFFEROR _____ (Signature of person authorized to sign)		15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer)	16C. DATE SIGNED 22-Dec-2015

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

SECTION 00800 - SPECIAL CONTRACT REQUIREMENTS

The following have been added by full text:

AMENDMENT 0007

1. The purpose of this amendment is to provide responses to Pre-Proposal Information requests, Provide the Site Visit Attendance Sign-in Sheet and revise technical specifications.

a. The answer to Pre-Proposal Information request number 20 has been revised. Please see the updated Pre-Proposal Information log dated 2015-12-22. The Pre-Proposal Information log is being provided as an attachment to this amendment.

The Pre-Proposal Information log with attachment name 2015-12-22_PPI_Log can be located at <https://www.neco.navy.mil/> under this solicitation number under Additional Documents.

b. A copy of the Site Visit Sign-in Sheet and Site Visit Presentation are provided as an attachment to this amendment.

c. The following changes to the technical specifications are provided below;

Technical Changes:

In the RFP PART 3 - CHAPTER 5 - Page 38 of the Room Requirements for BREAK ROOM TOILET ROOMS:

DELETE "Tank type water closet"

ADD: "Provide floor mounted flush valve water closets"

In the RFP PART 3 - CHAPTER 5 - Page 35 of the Room Requirements for PUBLIC RESTROOM:

DELETE "Tank type water closet"

ADD "Provide floor mounted flush valve water closets"

RFP Part 3, Chapter 5, page 31, Corridor D5020

Delete: 2x4 troffer

Replace with: 2X2 troffer

In Part 3 Chapter 5 page 32:

DELETE: "Freight elevator"

Replace with "Passenger elevator"

RFP Part 3, Chapter 6:

DELETE: B201011 SUN CONTROL DEVICES (EXTERIOR)

RFP Part 3, Chapter 6

Delete: C103015 Ornamental Metal Work

In RFP Part 3, Chapter 6 the First ESR A10 Foundations section is the applicable section.

Delete the second A10 Foundations section.

RFP Part 3, D303002

Delete the 2nd paragraph "Provide vertical water source heat pumps...."

Replace with the following: "Provide horizontal water source heat pump units (WSHPs) in the overhead with a means for removal and maintenance of the system through lockable access panels. Install flexible stainless steel piping connections (hose kits) between water source heat pumps and piping. Install vibration isolators on heat pumps. If ceiling space does not allow for adequate access for the horizontal WSHPs, alternative types of water source heat pumps (such as vertical or console types) may be considered for the Sleeping Unit Modules as long as RFP requirements, including but not limited to, minimum space square footages and energy performance, are not compromised."

RFP Part 3, D30, last sentence

Delete the word "outdoor" where it proceeds "HVAC equipment" so that it reads: "All outdoor air coils for HVAC equipment shall...".

2. The proposal due date remains Thursday January 14, 2016 at 3:00 p.m. Eastern Time.
3. All other terms and conditions of this RFP remain unchanged.
4. Offeror's must acknowledge this amendment in writing with their proposal submission.

(End of Summary of Changes)