

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>			1. CONTRACT ID CODE J	PAGE OF PAGES 1   2	
2. AMENDMENT/MODIFICATION NO. 0005	3. EFFECTIVE DATE 21-Apr-2015	4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO.(If applicable)	
6. ISSUED BY NAVFAC SOUTHEAST IPT SOUTH ATLANTIC BLDG 135, PO BOX 30 NAS JACKSONVILLE JACKSONVILLE FL 32212-0030	CODE N69450	7. ADMINISTERED BY (If other than item 6) NAVFAC SOUTHEAST PWD KEY WEST BLDG A-629, PO BOX 9018 KEY WEST FL 33040-9018		CODE	N69450
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)			X	9A. AMENDMENT OF SOLICITATION NO. N69450-15-R-1106	
			X	9B. DATED (SEE ITEM 11) 03-Mar-2015	
				10A. MOD. OF CONTRACT/ORDER NO.	
				10B. DATED (SEE ITEM 13)	
CODE	FACILITY CODE				
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS					
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input checked="" type="checkbox"/> is extended, <input type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.					
12. ACCOUNTING AND APPROPRIATION DATA (If required)					
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.					
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.					
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).					
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:					
D. OTHER (Specify type of modification and authority)					
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.					
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)  N69450-15-R-1106 REPAIR AUTEC PIER 1902 AT ANDROS ISLAND, BAHAMAS  The purpose of this amendment is to clarify questions received on the Schedule of ELINs issued in Amendment 0004 and Extend the proposal due date to 01 May 2015.  Continued on page 2					
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.					
15A. NAME AND TITLE OF SIGNER (Type or print)			16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
			TEL:	EMAIL:	
15B. CONTRACTOR/OFFEROR  _____ (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA  BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED  21-Apr-2015	

## SECTION SF 30 BLOCK 14 CONTINUATION PAGE

**SUMMARY OF CHANGES**

## SECTION SF 30 - BLOCK 14 CONTINUATION PAGE

The following have been added by full text:

AMENDMENT 0005

The following questions were received and being disseminated to clarify the ELINs schedule issued in Amendment 0004

Q. Please confirm that the defect quantities listed in the table all have units of Each, e.g. ELIN 101 is for a defect size of 0' 3" x 2' 0" x 2' 0" and has a quantity of 25. As a result, we need to price repairing 25 areas with a defect size of 4 square feet each x 3" deep.

A. Correct. Based on the example, the contractor shall price an area of defect with having an average repair size of 4 square feet by 3" deep, use this as the unit price and multiply it by 25 to come to a total price for ELIN 101

Q. ELIN 106 has a description which reads, "Impact Damage to Piles" with a defect size of 5' 0". We are unclear what repair would be required in this instance. Please confirm that you would like us to price encasement of a 5' length of Steel H Pile for this item and there are no additional repairs needed. In reviewing Halcrow's inspection report of 2010, we note that there are several pictures showing impact damage to Steel H Piles, photos 013 and 014 for example. If the intent of this item is to restore the pile's structural integrity, that is a significantly costlier repair which we have no details for. Please clarify what is intended.

A. There is no repair provided in the design documents for the impact damage to the piles since that type of defect was not quantified in the Halcrow inspection report. This information will need to be gathered during the winning bidders pre-construction design level inspection. For bidding purposes assume the damaged piles will require steel reinforcing via underwater welding for an approximate 5'-0" length of pile. The intent of the steel reinforcing is to repair the pile to its original design capacity. The steel repair shall be encased in concrete to provide cover similar to the typical pile encasement.

*Proposal due date has been extended from 27 April 2015 to 01 May 2015 at 2:30pm local time.*

*All other terms and conditions remain unchanged.*

*ACKNOWLEDGEMENT OF THIS AMENDMENT IS REQUIRED WITH YOUR PROPOSAL.*

## SECTION 00010 - SOLICITATION CONTRACT FORM

The required response date/time has changed from 27-Apr-2015 02:30 PM to 01-May-2015 02:30 PM.

(End of Summary of Changes)