

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE J	PAGE OF PAGES 1 3
2. AMENDMENT/MODIFICATION NO. 0001	3. EFFECTIVE DATE 16-Jun-2015	4. REQUISITION/PURCHASE REQ. NO. ACQR3905952		5. PROJECT NO.(If applicable)
6. ISSUED BY NAVFAC SOUTHEAST PWD KEY WEST BLDG A-629, PO BOX 9018 KEY WEST FL 33040-9018	CODE N69450	7. ADMINISTERED BY (If other than item 6) See Item 6		
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)		X	9A. AMENDMENT OF SOLICITATION NO. N69450-15-R-4715	
		X	9B. DATED (SEE ITEM 11) 27-May-2015	
			10A. MOD. OF CONTRACT/ORDER NO.	
			10B. DATED (SEE ITEM 13)	
CODE	FACILITY CODE			
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS				
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input checked="" type="checkbox"/> is extended, <input type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.				
12. ACCOUNTING AND APPROPRIATION DATA (If required)				
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.				
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.				
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).				
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:				
D. OTHER (Specify type of modification and authority)				
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.				
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) The purpose of this amendment is to answer questions submitted in response to the solicitation, incorporate an updated inventory via Attachment J-1502000-03, and extend the proposal due date.				
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.				
15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
		TEL:	EMAIL:	
15B. CONTRACTOR/OFFEROR _____ (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED 16-Jun-2015

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

SECTION SF 30 - BLOCK 14 CONTINUATION PAGE

The following have been added by full text:

Q&A

	QUESTION	GOVERNMENT RESPONSE
1	Who owns the existing chemical feed and control equipment? NAS or contractor?	The Government.
2	Will there be a scheduled site walk thru or are contractors at liberty to visit the site as needed?	There is no formal site visit scheduled. See Section L, Information for Offerors on page 97 of the solicitation.
3	Can we receive a copy of the current water treatment providers Field Service Reports from their last visit?	It is not available.
4	We need more information on the following for each system identified in the solicitation: system volume (gallons), recirculation rate (gallons/ min), tower cycles, make-up water source/ analysis.	Available additional information on the equipment (manufacturer, model#/serial#, and unit size) is provided in the revised inventory, Attachment J-1502000-03.

SECTION A - SOLICITATION/CONTRACT FORM

The required response date/time has changed from 18-Jun-2015 12:00 PM to 25-Jun-2015 12:00 PM.

SECTION J - LIST OF DOCUMENTS, EXHIBITS AND OTHER ATTACHMENTS

The following have been added by full text:

REVISED J-1502000-03

ATTACHMENT J-1502000-03
FACILITY PROPERTY INVENTORY
INVENTORY OF CHILL WATER LOOPS, COOLING TOWERS AND BOILERS

Facility No.	Location	Type and Quantity of Equipment/System	Manufacturer	Model #/Serial #	Unit Size
Bldg. 1278/290	Truman Annex	Cooling Tower #1	BAC	3412C	325 Ton
Bldg. 1278/290	Truman Annex	Cooling Tower #2	BAC	3412C	325 Ton
Bldg. 1278/1279	Truman Annex	Chill Water Loop #1, includes air cool condenser (back-up system for chill water)	Carrier	Not available	100 Ton
Bldg. 1278/1279	Truman Annex	Chill Water Loop #2, includes air cool condenser (back-up system for chill water)	Carrier	Not available	100 Ton
Bldg. 1352	Truman Annex	Cooling Tower #1	EVAPCO	USS19-914	355 Ton
Bldg. 1352	Truman Annex	Cooling Tower #2	EVAPCO	USS19-914	355 Ton
Bldg. 1352	Truman Annex	Chill Water Loop	TRANE	RTHD	300 Ton
Bldg. A-324	Boca Chica	Chill Water Loop	YORK	YCAL 0043 EE 17EXB	300 Ton
Bldg. A-727	Boca Chica	Chill Water Loop	YORK	YCAL 0056EE	34 Ton
Bldg. A-936	Boca Chica	Cooling Tower #1	EVAPCO	SST 8-624B	520 Ton
Bldg. A-936	Boca Chica	Cooling Tower #2	EVAPCO	SST 8-624B	520 Ton
Bldg. A-936	Boca Chica	Chill Water Loop	YORK	HYP490XH30B-46	300 Ton
Bldg. A-1125	Boca Chica	Chill Water Loop	YORK	YCAL 60034	34 Ton
Bldg. A-4165	Boca Chica	Chill Water Loop	YORK	YCAL 0060 EB	60 Ton
Bldg. A-4202	Boca Chica	Chill Water Loop	TRANE	CGA180B3	15 Ton
Bldg. A-4203	Boca Chica	Chill Water Loop	TRANE	CGAFC60EAH	60 Ton
Bldg. V-4187	Sigsbee Park	Chill Water Loop	TRANE	CGAFC60YTA	60 Ton
Bldg. C-1	Trumbo Point	Chill Water Loop	YORK	YCAL 0051	51 Ton
Bldg. C-2076	Trumbo Point	Cooling Tower	EVAPCO	AT 112-618	270 Ton
Bldg. C-2076	Trumbo Point	Boiler (HVAC System)	DONLEE	SP 0-30-LP 95909	1.255 MBTU/Hr
Bldg. C-4084	Trumbo Point	Chill Water Loop (for C-2076)	YORK / TRANE	RTHB	300 Ton / 300 Ton

(End of Summary of Changes)