



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

South District Office
P.O. Box 2549
Fort Myers, FL 33902-2549

RICK SCOTT
GOVERNOR

CARLOS LOPEZ-CANTERA
LT. GOVERNOR

HERSCHEL T. VINYARD JR.
SECRETARY

In the Matter of an
Application for Permit by:

Naval Air Station Key West
Steven McAlearney, Commanding Officer
P.O. Box 9001
Key West, Florida 33040

Monroe County - DW
Boca Chica Naval Air Station WWTP
File Number: FLA147117-005-DW2P
UIC Well Numbers 63430-025-UO through 63430-030-UO
Florida Keys Basin

NOTICE OF PERMIT ISSUANCE

Enclosed is Permit Number FLA147117-005 to operate the Boca Chica Naval Air Station WWTP and its six underground injection control wells 63430-025-UO through 63430-030-UO, issued under Chapter 403, Florida Statutes.

Monitoring requirements under this permit are effective on April 1, 2014. Until such time, the permittee shall continue to monitor and report in accordance with previously effective permit requirements, if any.

Please note: Beginning on January 1, 2016, the facility shall either cease all discharge to the injection wells or meet revised annual average effluent limits for certain parameters as shown in the Condition I.A.5 of the attached permit.

The Department's proposed agency action shall become final unless a timely petition for an administrative hearing is filed under Sections 120.569 and 120.57, Florida Statutes, within fourteen days of receipt of notice. The procedures for petitioning for a hearing are set forth below.

A person whose substantial interests are affected by the Department's proposed permitting decision may petition for an administrative proceeding (hearing) under Sections 120.569 and 120.57, Florida Statutes. The petition must contain the information set forth below and must be filed (received by the Clerk) in the Office of General Counsel of the Department at 3900 Commonwealth Boulevard, Mail Station 35, Tallahassee, Florida 32399-3000.

Under Rule 62-110.106(4), Florida Administrative Code, a person may request an extension of the time for filing a petition for an administrative hearing. The request must be filed (received by the Clerk) in the Office of General Counsel before the end of the time period for filing a petition for an administrative hearing.

Petitions by the applicant or any of the persons listed below must be filed within fourteen days of receipt of this written notice. Petitions filed by any persons other than those entitled to written notice under Section 120.60(3), Florida Statutes, must be filed within fourteen days of publication of the notice or within fourteen days of receipt of the written notice, whichever occurs first. Section 120.60(3), Florida Statutes, however, also allows that any person who has asked the Department in writing for notice of agency action may file a petition within fourteen days of receipt of such notice, regardless of the date of publication.

The petitioner shall mail a copy of the petition to the applicant at the address indicated above at the time of filing. The failure of any person to file a petition or request for an extension of time within fourteen days of receipt of notice shall constitute a waiver of that person's right to request an administrative determination (hearing) under Sections 120.569 and 120.57, Florida Statutes. Any subsequent intervention (in a proceeding initiated by another

party) will be only at the discretion of the presiding officer upon the filing of a motion in compliance with Rule 28-106.205, Florida Administrative Code.

A petition that disputes the material facts on which the Department's action is based must contain the following information, as indicated in Rule 28-106.201, Florida Administrative Code:

- (a) The name and address of each agency affected and each agency's file or identification number, if known;
- (b) The name, address, any e-mail address, any facsimile number, and telephone number of the petitioner, if the petitioner is not represented by an attorney or a qualified representative; the name, address, and telephone number of the petitioner's representative, if any, which shall be the address for service purposes during the course of the proceeding; and an explanation of how the petitioner's substantial interests will be affected by the determination;
- (c) A statement of when and how the petitioner received notice of the Department's decision;
- (d) A statement of all disputed issues of material fact. If there are none, the petition must so indicate;
- (e) A concise statement of the ultimate facts alleged, including the specific facts the petitioner contends warrant reversal or modification of the Department's proposed action;
- (f) A statement of the specific rules or statutes the petitioner contends require reversal or modification of the Department's proposed action, including an explanation of how the alleged facts relate to the specific rules or statutes; and
- (g) A statement of the relief sought by the petitioner, stating precisely the action petitioner wishes the Department to take with respect to the Department's proposed action.

Mediation under Section 120.573, Florida Statutes, is not available for this proceeding.

This permit action is final and effective on the date filed with the Clerk of the Department unless a petition (or request for an extension of time) is filed in accordance with the above. Upon the timely filing of a petition (or request for an extension of time), this permit will not be effective until further order of the Department.

Any party to the permit has the right to seek judicial review of the permit action under Section 120.68, Florida Statutes, by the filing of a notice of appeal under Rules 9.110 and 9.190, Florida Rules of Appellate Procedure, with the Clerk of the Department in the Office of General Counsel, 3900 Commonwealth Boulevard, Mail Station 35, Tallahassee, Florida, 32399-3000, and by filing a copy of the notice of appeal accompanied by the applicable filing fees with the appropriate district court of appeal. The notice of appeal must be filed within 30 days from the date when this permit action is filed with the Clerk of the Department.

Executed in Ft. Myers, Florida.

STATE OF FLORIDA DEPARTMENT
OF ENVIRONMENTAL PROTECTION



For

Jon M. Iglehart
Director of
District Management

PERMITTEE NAME: Naval Air Sta. Key West
FACILITY NAME: Boca Chica Naval Air Sta. WWTP
NOTICE OF PERMIT ISSUANCE

P.A. FILE NO.: FLA147117-005-DW2P

FILING AND ACKNOWLEDGMENT

FILED, on this date, under Section 120.52, Florida Statutes, with the designated Deputy Clerk, receipt of which is hereby acknowledged.

CERTIFICATE OF SERVICE

The undersigned hereby certifies that this NOTICE OF PERMIT ISSUANCE and all copies were mailed before the close of business on **February 26, 2014**, to the listed persons.

Irene S. Collins

2-26-2014

Name

Date

JMI/RW/isc

Enclosures

Copies furnished to:

- Jens Sapin P.E., via email (jens.sapin@navy.mil)
- Guillermo Wallace; via email (guillermo.wallace@navy.mil)
- Ed Barham; via email (Edward.barham@navy.mil)
- Gus Rios, DEP—Marathon; via email.
- Ron Walters, DEP—Fort Myers; via email.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION
South District Office
P.O. Box 2549
Fort Myers, FL 33902-2549

RICK SCOTT GOVERNOR
CARLOS LOPEZ-CANTERA LT. GOVERNOR
HERSCHEL T. VINYARD JR. SECRETARY

STATE OF FLORIDA
DOMESTIC WASTEWATER FACILITY PERMIT

PERMITTEE:
Naval Air Station, Key West

PERMIT NUMBER: FLA147117-005
FILE NUMBER: FLA147117-005-DW2P
EFFECTIVE DATE: February 26, 2014
EXPIRATION DATE: February 25, 2019

RESPONSIBLE OFFICIAL:
Steven McAlearney, Commanding Officer
P.O. Box 9001
Key West, Florida 33040
(305) 293-2866

FACILITY:
Boca Chica Naval Air Station WWTP
Naval Air Station, Boca Chica
MM 7.7
Key West, FL 33040
Monroe County
Latitude: 24°35' 15" N Longitude: 81°41' 46" W

This permit is issued under the provisions of Chapter 403, Florida Statutes (F.S.), and applicable rules of the Florida Administrative Code (F.A.C.). This permit does not constitute authorization to discharge wastewater other than as expressly stated in this permit. The above named permittee is hereby authorized to operate the facilities in accordance with the documents attached hereto and specifically described as follows:

WASTEWATER TREATMENT:

An existing 0.400 MGD annual average daily flow (AADF) permitted capacity complete mix activated sludge (CMAS) process domestic wastewater treatment plant consisting of: one manually cleaned bar screen, one mechanically cleaned bar screen, grit removal, two surge tanks (one 85,272 gallons; one 39,793 gallons), one 46,000-gallon CMAS tank, one 70,437-gallon secondary clarifier, one 880-gallon clarifier junction box, one 11,200-gallon chlorine contact tank, one 35,954-gallon polishing tank, one approximately 112,000-gallon aerobic digester, and total 900 sq. ft. sludge drying beds.

REUSE OR DISPOSAL:

Underground Injection U-001: An existing 0.400 MGD AADF permitted capacity underground injection well system consisting of six Class V underground injection control wells permitted under Department permit number(s) 63430-025, 026, 027, 028, 029 and 030 discharging to Class G-III ground water. Underground Injection Well System U-001 is located approximately at latitude 24°35' 15" N, longitude 81°41' 46" W.

IN ACCORDANCE WITH: The limitations, monitoring requirements, and other conditions set forth in this cover sheet and Part I through Part X on pages 1 through 18 of this permit.

PERMITTEE: Naval Air Station Key West
 FACILITY: Boca Chica Naval Air Station WWTP

PERMIT NUMBER: FLA147117-005
 P.A. FILE NUMBER:: FLA147117-005-DW2P

I. RECLAIMED WATER AND EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

A. Underground Injection Control Systems

1. During the period beginning on the effective date and lasting through December 31, 2015, the permittee is authorized to discharge effluent to Underground Injection Well System U-001. Such discharge shall be limited and monitored by the permittee as specified below and reported in accordance with Permit Condition I.B.7.:

Parameter	Units	Max/Min	Reclaimed Water Limitations		Monitoring Requirements			Notes
			Limit	Statistical Basis	Frequency of Analysis	Sample Type	Monitoring Site Number	
BOD, Carbonaceous 5 day, 20C	mg/L	Max Max Max Max	20.0 30.0 45.0 60.0	Annual Average Monthly Average Weekly Average Single Sample	Every 2 weeks	8-hr FPC	EFA-01	
Solids, Total Suspended	mg/L	Max Max Max Max	20.0 30.0 45.0 60.0	Annual Average Monthly Average Weekly Average Single Sample	Every 2 weeks	8-hr FPC	EFA-01	
pH	s.u.	Min Max	6.0 8.5	Single Sample Single Sample	5 Days/Week	Grab	EFA-01	See I.A.6
Coliform, Fecal	#/100mL	Max Max Max	200 200 800	Annual Average Monthly Geometric Mean Single Sample	Every 2 weeks	Grab	EFA-01	See I.A.3, 6
Chlorine, Total Residual (For Disinfection)	mg/L	Min	0.5	Single Sample	5 Days/Week	Grab	EFA-01	See I.A.4, 6
Nitrogen, Total	mg/L	Max	Report	Single Sample	Every 2 weeks	8-hr FPC	EFA-01	
Phosphorus, Total (as P)	mg/L	Max	Report	Single Sample	Every 2 weeks	8-hr FPC	EFA-01	

PERMITTEE: Naval Air Station Key West
FACILITY: Boca Chica Naval Air Station WWTP

PERMIT NUMBER: FLA147117-005
P.A. FILE NUMBER:: FLA147117-005-DW2P

2. Effluent samples shall be taken at the monitoring site locations listed in Permit Condition I.A.1. and as described below:

Monitoring Site Number	Description of Monitoring Site
EFA-01	Relocated to after chlorine contact chamber before discharge to the polishing tank.

3. The effluent limitation for the monthly geometric mean for fecal coliform is only applicable if 10 or more values are reported. If fewer than 10 values are reported, the monthly geometric mean shall be calculated and reported on the Discharge Monitoring Report. *[62-600.440(4)(c)]*
4. Total residual chlorine must be maintained for a minimum contact time of 15 minutes based on peak hourly flow. *[62-600.440(4)(b) and (5)(b)]*
5. **Beginning on January 1, 2016**, the facility shall either cease all discharge to the injection wells or meet revised annual average effluent limits for certain parameters as shown below. The limits for all other parameters listed in I. A.1 will remain the same.
- a. Carbonaceous biochemical oxygen demand (CBOD₅) of 5.0 mg/L;
 - b. Total suspended solids (TSS) of 5.0 mg/L;
 - c. Total nitrogen (as N) of 3.0 mg/L;
 - d. Total phosphorus (as P) of 1.0 mg/L.
- [Chapter 403.086(10), Florida Statutes][Chapter 99-395, Laws of Florida, Section 6, Subsection (4) and (6)]*
6. Grab samples shall be collected during periods of minimal treatment plant pollutant removal efficiencies or maximum organic loading in the reclaimed water or effluent. *[62-600.740(1)(a)2]*

PERMITTEE: Naval Air Station Key West
 FACILITY: Boca Chica Naval Air Station WWTP

PERMIT NUMBER: FLA147117-005
 P.A. FILE NUMBER:: FLA147117-005-DW2P

B. Other Limitations and Monitoring and Reporting Requirements

1. During the period beginning on the effective date and lasting through the expiration date of this permit, the treatment facility shall be limited and monitored by the permittee as specified below and reported in accordance with condition I.B.7.:

Parameter	Units	Max/Min	Limitations		Monitoring Requirements			Notes
			Limit	Statistical Basis	Frequency of Analysis	Sample Type	Monitoring Site Number	
Flow	MGD	Max	Report	Monthly Average	Continuous	Recording Flow Meter with Totalizer	FLW-01	See I.B.4
Flow	MGD	Max	Report	3-Month Rolling Average	Continuous	Recording Flow Meter with Totalizer	FLW-01	See I.B.4
Percent Capacity, (TMADF/Permitted Capacity) x 100	percent	Max	Report	3-Month Rolling Average	Monthly	Calculated	CAL-01	
Flow	MGD	Max	0.400	Annual Average	Continuous	Recording Flow Meter with Totalizer	FLW-01	See I.B.4
BOD, Carbonaceous 5 day, 20C (Influent)	mg/L	Max	Report	Monthly Average	Every 2 weeks	8-hr FPC	INF-01	See I.B.3 and I.B.11
Solids, Total Suspended (Influent)	mg/L	Max	Report	Monthly Average	Every 2 weeks	8-hr FPC	INF-01	See I.B.3 and I.B.11

PERMITTEE: Naval Air Station Key West
FACILITY: Boca Chica Naval Air Station WWTP

PERMIT NUMBER: FLA147117-005
P.A. FILE NUMBER:: FLA147117-005-DW2P

2. Samples shall be taken at the monitoring site locations listed in Permit Condition I.B.1. and as described below:

Monitoring Site Number	Description of Monitoring Site
FLW-01	Flow meter at V-notch weir located in the effluent wall of the chlorine contact chamber.
CAL-01	Calculated from the FLW-01 measurements.
INF-01	Sampler at the plant headworks before discharge to influent bar screen.

3. Influent samples shall be collected so that they do not contain digester supernatant or return activated sludge, or any other plant process recycled waters. [62-601.500(4)]
4. A recording flow meter with totalizer shall be utilized to measure flow and calibrated at least once every 12 months. [62-601.200(17) and .500(6)]
5. The sample collection, analytical test methods and method detection limits (MDLs) applicable to this permit shall be conducted using a sufficiently sensitive method to ensure compliance with applicable water quality standards and effluent limitations and shall be in accordance with Rule 62-4.246, Chapters 62-160 and 62-601, F.A.C., and 40 CFR 136, as appropriate. The list of Department established analytical methods, and corresponding MDLs (method detection limits) and PQLs (practical quantitation limits), which is titled "FAC 62-4 MDL/PQL Table (April 26, 2006)" is available at <http://www.dep.state.fl.us/labs/library/index.htm>. The MDLs and PQLs as described in this list shall constitute the minimum acceptable MDL/PQL values and the Department shall not accept results for which the laboratory's MDLs or PQLs are greater than those described above unless alternate MDLs and/or PQLs have been specifically approved by the Department for this permit. Any method included in the list may be used for reporting as long as it meets the following requirements:
- The laboratory's reported MDL and PQL values for the particular method must be equal or less than the corresponding method values specified in the Department's approved MDL and PQL list;
 - The laboratory reported MDL for the specific parameter is less than or equal to the permit limit or the applicable water quality criteria, if any, stated in Chapter 62-302, F.A.C. Parameters that are listed as "report only" in the permit shall use methods that provide an MDL, which is equal to or less than the applicable water quality criteria stated in 62-302, F.A.C.; and
 - If the MDLs for all methods available in the approved list are above the stated permit limit or applicable water quality criteria for that parameter, then the method with the lowest stated MDL shall be used.

When the analytical results are below method detection or practical quantitation limits, the permittee shall report the actual laboratory MDL and/or PQL values for the analyses that were performed following the instructions on the applicable discharge monitoring report.

Where necessary, the permittee may request approval of alternate methods or for alternative MDLs or PQLs for any approved analytical method. Approval of alternate laboratory MDLs or PQLs are not necessary if the laboratory reported MDLs and PQLs are less than or equal to the permit limit or the applicable water quality criteria, if any, stated in Chapter 62-302, F.A.C. Approval of an analytical method not included in the above-referenced list is not necessary if the analytical method is approved in accordance with 40 CFR 136 or deemed acceptable by the Department. [62-4.246, 62-160]

6. The permittee shall provide safe access points for obtaining representative influent, reclaimed water, and effluent samples which are required by this permit. [62-601.500(5)]
7. Monitoring requirements under this permit are effective on the first day of the second month following the effective date of the permit. Until such time, the permittee shall continue to monitor and report in accordance with previously effective permit requirements, if any. During the period of operation authorized by this permit, the permittee shall complete and submit to the Department Discharge Monitoring Reports (DMRs) in accordance with the frequencies specified by the REPORT type (i.e. monthly, quarterly, semiannual, annual, etc.) indicated on the DMR forms attached to this permit. Unless specified otherwise in this permit, monitoring

PERMITTEE: Naval Air Station Key West
 FACILITY: Boca Chica Naval Air Station WWTP

PERMIT NUMBER: FLA147117-005
 P.A. FILE NUMBER:: FLA147117-005-DW2P

results for each monitoring period shall be submitted in accordance with the associated DMR due dates below. DMRs shall be submitted for each required monitoring period including periods of no discharge.

REPORT Type on DMR	Monitoring Period	Mail or Electronically Submit by
Monthly	First day of month - last day of month	28 th day of following month
Quarterly	January 1 - March 31 April 1 - June 30 July 1 - September 30 October 1 - December 31	April 28 July 28 October 28 January 28
Semiannual	January 1 - June 30 July 1 - December 31	July 28 January 28
Annual	January 1 - December 31	January 28

The permittee may submit either paper or electronic DMR forms. If submitting paper DMR forms, the permittee shall make copies of the attached DMR forms, without altering the original format or content unless approved by the Department, and shall mail the completed DMR forms to the Department's South District Office at the address specified in Permit Condition I.B.9. by the twenty-eighth (28th) of the month following the month of operation.

If submitting electronic DMR forms, the permittee shall use the electronic DMR system(s) approved in writing by the Department and shall electronically submit the completed DMR forms to the Department by the twenty-eighth (28th) of the month following the month of operation. Data submitted in electronic format is equivalent to data submitted on signed and certified paper DMR forms.

[62-620.610(18)][62-601.300(1),(2), and (3)]

8. During the period of operation authorized by this permit, reclaimed water or effluent shall be monitored annually for the primary and secondary drinking water standards contained in Chapter 62-550, F.A.C., (except for asbestos, color, odor, and corrosivity). These monitoring results shall be reported to the Department annually on the DMR. During years when a permit is not renewed, a certification stating that no new non-domestic wastewater dischargers have been added to the collection system since the last reclaimed water or effluent analysis was conducted may be submitted in lieu of the report. The annual reclaimed water or effluent analysis report or the certification shall be completed and submitted in a timely manner so as to be received by the Department at the address identified on the DMR by June 28 of each year. Approved analytical methods identified in Rule 62-620.100(3)(j), F.A.C., shall be used for the analysis. If no method is included for a parameter, methods specified in Chapter 62-550, F.A.C., shall be used. *[62-601.300(4)][62-601.500(3)][62-610.300(4)]*
9. Unless specified otherwise in this permit, all reports and other information required by this permit, including 24-hour notifications, shall be submitted to or reported to, as appropriate, the Department's South District Office at the address specified below:

Florida Department of Environmental Protection
 Marathon Branch Office
 2796 Overseas Hwy., Suite 221
 Marathon, Florida 33050

Phone Number - (305) 289-7070
 FAX Number - (850) 412-0590
 (All FAX copies and e-mails shall be followed by original copies.)

[62-620.305]

10. All reports and other information shall be signed in accordance with the requirements of Rule 62-620.305, F.A.C. *[62-620.305]*

PERMITTEE: Naval Air Station Key West
 FACILITY: Boca Chica Naval Air Station WWTP

PERMIT NUMBER: FLA147117-005
 P.A. FILE NUMBER:: FLA147117-005-DW2P

- Influent flow proportioned composite samples for CBOD₅, total suspended solids, total nitrogen and total phosphorous shall be taken on the same day and composite periods shall be at the same time of day that the corresponding effluent samples are taken. [62-601.300(6)]

II. BIOSOLIDS MANAGEMENT REQUIREMENTS

- Biosolids generated by this facility may be transferred to sludge tanks at the City of Key West WWTP, or disposed of in a Class I solid waste landfill. Transferring biosolids to an alternative biosolids treatment facility does not require a permit modification. However, use of an alternative biosolids treatment facility requires submittal of a copy of the agreement pursuant to Rule 62-640.880(1)(c), F.A.C., along with a written notification to the Department at least 30 days before transport of the biosolids. [62-620.320(6), 62-640.880(1)]
- The permittee shall monitor and keep records of the quantities of biosolids generated, received from source facilities, treated, distributed and marketed, land applied, used as a biofuel or for bioenergy, transferred to another facility, or landfilled. These records shall be kept for a minimum of five years. [62-640.650(4)(a)]
- Biosolids quantities shall be monitored by the permittee as specified below. Results shall be reported on the permittee's Discharge Monitoring Report in accordance with Condition I.B.7.

Parameter	Units	Max/ Min	Biosolids Limitations		Monitoring Requirements		
			Limit	Statistical Basis	Frequency of Analysis	Sample Type	Monitoring Site Number
Biosolids Quantity (Landfilled)	Dry tons	Max	Report	Monthly Total	Monthly	Calculated	RMP-1
Biosolids Quantity (Transferred) *	Dry tons	Max	Report	Monthly Total	Monthly	Calculated	RMP-1

* See Condition II.12 of this permit. [62-640.650(5)(a)]

- Biosolids quantities shall be calculated as listed in Permit Condition II.3 and as described below:

Monitoring Site Number	Description of Monitoring Site Calculations
RMP-1	Monthly Total of Biosolids Landfilled or Transferred.

- The treatment, management, transportation, use, land application, or disposal of biosolids shall not cause a violation of the odor prohibition in subsection 62-296.320(2), F.A.C. [62-640.400(6)]
- Storage of biosolids or other solids at this facility shall be in accordance with the Facility Biosolids Storage Plan. [62-640.300(4)]
- Biosolids shall not be spilled from or tracked off the treatment facility site by the hauling vehicle. [62-640.400(9)]
- Disposal of biosolids, septage, and "other solids" in a solid waste disposal facility, or disposal by placement on land for purposes other than soil conditioning or fertilization, such as at a monofill, surface impoundment, waste pile, or dedicated site, shall be in accordance with Chapter 62-701, F.A.C. [62-640.100(6)(b) & (c)]
- The permittee shall not be held responsible for treatment and management violations that occur after its biosolids have been accepted by a permitted biosolids treatment facility with which the source facility has an agreement in accordance with subsection 62-640.880(1)(c), F.A.C., for further treatment, management, or disposal. [62-640.880(1)(b)]

PERMITTEE: Naval Air Station Key West
FACILITY: Boca Chica Naval Air Station WWTP

PERMIT NUMBER: FLA147117-005
P.A. FILE NUMBER:: FLA147117-005-DW2P

10. The permittee shall keep hauling records to track the transport of biosolids between the facilities. The hauling records shall contain the following information:

Source Facility	Biosolids Treatment Facility or Treatment Facility
1. Date and time shipped	1. Date and time received
2. Amount of biosolids shipped	2. Amount of biosolids received
3. Degree of treatment (if applicable)	3. Name and ID number of source facility
4. Name and ID Number of treatment facility	4. Signature of hauler
5. Signature of responsible party at source facility	5. Signature of responsible party at treatment facility
6. Signature of hauler and name of hauling firm	

A copy of the source facility hauling records for each shipment shall be provided upon delivery of the biosolids to the biosolids treatment facility or treatment facility. The treatment facility permittee shall report to the Department within 24 hours of discovery any discrepancy in the quantity of biosolids leaving the source facility and arriving at the biosolids treatment facility or treatment facility.

[62-640.880(4)]

11. If the permittee intends to accept biosolids from other facilities, a permit revision is required pursuant to paragraph 62-640.880(2)(d), F.A.C. *[62-640.880(2)(d)]*
12. Prior to transferring biosolids to the treatment facility (the City of Key West WWTP), the permittee shall execute a hauling agreement between the source facility and the treatment facility (the City of Key West WWTP). *[62-640, FAC]*

III. GROUND WATER REQUIREMENTS

1. Section III is not applicable to this facility.

IV. ADDITIONAL REUSE AND LAND APPLICATION REQUIREMENTS

1. Section IV is not applicable to this facility.

V. OPERATION AND MAINTENANCE REQUIREMENTS

A. Staffing Requirements

1. During the period of operation authorized by this permit, the wastewater facilities shall be operated under the supervision of a(n) operator(s) certified in accordance with Chapter 62-602, F.A.C. In accordance with Chapter 62-699, F.A.C., this facility is a Category II, Class C facility and, at a minimum, operators with appropriate certification must be on the site as follows:

A Class C or higher operator 6 hours/day for 5 days/week and one visit on each weekend day. The lead/chief operator must be a Class C operator, or higher.

2. An operator meeting the lead/chief operator class for the plant shall be available during all periods of plant operation. "Available" means able to be contacted as needed to initiate the appropriate action in a timely manner. *[62-699.311(1)]*

B. Capacity Analysis Report and Operation and Maintenance Performance Report Requirements

1. The application to renew this permit shall include an updated capacity analysis report prepared in accordance with Rule 62-600.405, F.A.C. *[62-600.405(5)]*

PERMITTEE: Naval Air Station Key West
FACILITY: Boca Chica Naval Air Station WWTP

PERMIT NUMBER: FLA147117-005
P.A. FILE NUMBER:: FLA147117-005-DW2P

2. The application to renew this permit shall include a detailed operation and maintenance performance report prepared in accordance with Rule 62-600.735, F.A.C. *[62-600.735(1)]*

C. Recordkeeping Requirements

1. The permittee shall maintain the following records and make them available for inspection at the following address: Operations office of the WWTP, Naval Air Station, Boca Chica, FL, 33040.
 - a. Records of all compliance monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, including, if applicable, a copy of the laboratory certification showing the certification number of the laboratory, for at least three years from the date the sample or measurement was taken;
 - b. Copies of all reports required by the permit for at least three years from the date the report was prepared;
 - c. Records of all data, including reports and documents, used to complete the application for the permit for at least three years from the date the application was filed;
 - d. Monitoring information, including a copy of the laboratory certification showing the laboratory certification number, related to the residuals use and disposal activities for the time period set forth in Chapter 62-640, F.A.C., for at least three years from the date of sampling or measurement;
 - e. A copy of the current permit;
 - f. A copy of the current operation and maintenance manual as required by Chapter 62-600, F.A.C.;
 - g. A copy of any required record drawings;
 - h. Copies of the licenses of the current certified operators;
 - i. Copies of the logs and schedules showing plant operations and equipment maintenance for three years from the date of the logs or schedules. The logs shall, at a minimum, include identification of the plant; the signature and license number of the operator(s) and the signature of the person(s) making any entries; date and time in and out; specific operation and maintenance activities, including any preventive maintenance or repairs made or requested; results of tests performed and samples taken, unless documented on a laboratory sheet; and notation of any notification or reporting completed in accordance with Rule 62-602.650(3), F.A.C. The logs shall be maintained on-site in a location accessible to 24-hour inspection, protected from weather damage, and current to the last operation and maintenance performed; and
 - j. Records of biosolids quantities, treatment, monitoring, and hauling for at least five years.

[62-620.350, 62-602.650, 62-640.650(4)]

VI. SCHEDULES

1. The permittee is not authorized to discharge to waters of the state after the expiration date of this permit, unless:
 - a. The permittee has applied for renewal of this permit at least 180 days before the expiration date of this permit using the appropriate forms listed in Rule 62-620.910, F.A.C., and in the manner established in the Department of Environmental Protection Guide to Permitting Wastewater Facilities or Activities Under Chapter 62-620, F.A.C., including submittal of the appropriate processing fee set forth in Rule 62-4.050, F.A.C.; or
 - b. The permittee has made complete the application for renewal of this permit before the permit expiration date.
2. See the Condition I.A.5 of this permit for the schedule to comply with future effluent limitations.

[62-620.335(1) - (4)]

VII. INDUSTRIAL PRETREATMENT PROGRAM REQUIREMENTS

PERMITTEE: Naval Air Station Key West
FACILITY: Boca Chica Naval Air Station WWTP

PERMIT NUMBER: FLA147117-005
P.A. FILE NUMBER:: FLA147117-005-DW2P

1. This facility is not required to have a pretreatment program at this time. *[62-625.500]*

VIII. OTHER SPECIFIC CONDITIONS

1. In the event that the treatment facilities or equipment no longer function as intended, are no longer safe in terms of public health and safety, or odor, noise, aerosol drift, or lighting adversely affects neighboring developed areas at the levels prohibited by Rule 62-600.400(2)(a), F.A.C., corrective action (which may include additional maintenance or modifications of the permitted facilities) shall be taken by the permittee. Other corrective action may be required to ensure compliance with rules of the Department. Additionally, the treatment, management, use or land application of residuals shall not cause a violation of the odor prohibition in Rule 62-296.320(2), F.A.C. *[62-600.410(8) and 62-640.400(6)]*
2. The deliberate introduction of stormwater in any amount into collection/transmission systems designed solely for the introduction (and conveyance) of domestic/industrial wastewater; or the deliberate introduction of stormwater into collection/transmission systems designed for the introduction or conveyance of combinations of storm and domestic/industrial wastewater in amounts which may reduce the efficiency of pollutant removal by the treatment plant is prohibited, except as provided by Rule 62-610.472, F.A.C. *[62-604.130(3)]*
3. Collection/transmission system overflows shall be reported to the Department in accordance with Permit Condition IX. 20. *[62-604.550] [62-620.610(20)]*
4. The operating authority of a collection/transmission system and the permittee of a treatment plant are prohibited from accepting connections of wastewater discharges which have not received necessary pretreatment or which contain materials or pollutants (other than normal domestic wastewater constituents):
 - a. Which may cause fire or explosion hazards; or
 - b. Which may cause excessive corrosion or other deterioration of wastewater facilities due to chemical action or pH levels; or
 - c. Which are solid or viscous and obstruct flow or otherwise interfere with wastewater facility operations or treatment; or
 - d. Which result in the wastewater temperature at the introduction of the treatment plant exceeding 40°C or otherwise inhibiting treatment; or
 - e. Which result in the presence of toxic gases, vapors, or fumes that may cause worker health and safety problems.*[62-604.130(5)]*
5. The treatment facility, storage ponds for Part II systems, rapid infiltration basins, and/or infiltration trenches shall be enclosed with a fence or otherwise provided with features to discourage the entry of animals and unauthorized persons. *[62-600.400(2)(b)]*
6. Screenings and grit removed from the wastewater facilities shall be collected in suitable containers and hauled to a Department approved Class I landfill or to a landfill approved by the Department for receipt/disposal of screenings and grit. *[62-701.300(1)(a)]*
7. Where required by Chapter 471 or Chapter 492, F.S., applicable portions of reports that must be submitted under this permit shall be signed and sealed by a professional engineer or a professional geologist, as appropriate. *[62-620.310(4)]*
8. The permittee shall provide verbal notice to the Department's South District Office as soon as practical after discovery of a sinkhole or other karst feature within an area for the management or application of wastewater, wastewater residuals (sludges), or reclaimed water. The permittee shall immediately implement measures appropriate to control the entry of contaminants, and shall detail these measures to the Department's South District Office in a written report within 7 days of the sinkhole discovery. *[62-620.320(6)]*

PERMITTEE: Naval Air Station Key West
FACILITY: Boca Chica Naval Air Station WWTP

PERMIT NUMBER: FLA147117-005
P.A. FILE NUMBER:: FLA147117-005-DW2P

9. The permittee shall provide adequate notice to the Department of the following:
 - a. Any new introduction of pollutants into the facility from an industrial discharger which would be subject to Chapter 403, F.S., and the requirements of Chapter 62-620, F.A.C., if it were directly discharging those pollutants; and
 - b. Any substantial change in the volume or character of pollutants being introduced into that facility by a source which was identified in the permit application and known to be discharging at the time the permit was issued.

Adequate notice shall include information on the quality and quantity of effluent introduced into the facility and any anticipated impact of the change on the quantity or quality of effluent or reclaimed water to be discharged from the facility.

[62-620.625(2)]

IX. GENERAL CONDITIONS

1. The terms, conditions, requirements, limitations, and restrictions set forth in this permit are binding and enforceable pursuant to Chapter 403, Florida Statutes. Any permit noncompliance constitutes a violation of Chapter 403, Florida Statutes, and is grounds for enforcement action, permit termination, permit revocation and reissuance, or permit revision. *[62-620.610(1)]*
2. This permit is valid only for the specific processes and operations applied for and indicated in the approved drawings or exhibits. Any unauthorized deviations from the approved drawings, exhibits, specifications, or conditions of this permit constitutes grounds for revocation and enforcement action by the Department. *[62-620.610(2)]*
3. As provided in subsection 403.087(7), F.S., the issuance of this permit does not convey any vested rights or any exclusive privileges. Neither does it authorize any injury to public or private property or any invasion of personal rights, nor authorize any infringement of federal, state, or local laws or regulations. This permit is not a waiver of or approval of any other Department permit or authorization that may be required for other aspects of the total project which are not addressed in this permit. *[62-620.610(3)]*
4. This permit conveys no title to land or water, does not constitute state recognition or acknowledgment of title, and does not constitute authority for the use of submerged lands unless herein provided and the necessary title or leasehold interests have been obtained from the State. Only the Trustees of the Internal Improvement Trust Fund may express State opinion as to title. *[62-620.610(4)]*
5. This permit does not relieve the permittee from liability and penalties for harm or injury to human health or welfare, animal or plant life, or property caused by the construction or operation of this permitted source; nor does it allow the permittee to cause pollution in contravention of Florida Statutes and Department rules, unless specifically authorized by an order from the Department. The permittee shall take all reasonable steps to minimize or prevent any discharge, reuse of reclaimed water, or residuals use or disposal in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit. *[62-620.610(5)]*
6. If the permittee wishes to continue an activity regulated by this permit after its expiration date, the permittee shall apply for and obtain a new permit. *[62-620.610(6)]*
7. The permittee shall at all times properly operate and maintain the facility and systems of treatment and control, and related appurtenances, that are installed and used by the permittee to achieve compliance with the conditions of this permit. This provision includes the operation of backup or auxiliary facilities or similar systems when necessary to maintain or achieve compliance with the conditions of the permit. *[62-620.610(7)]*
8. This permit may be modified, revoked and reissued, or terminated for cause. The filing of a request by the permittee for a permit revision, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. *[62-620.610(8)]*

PERMITTEE: Naval Air Station Key West
FACILITY: Boca Chica Naval Air Station WWTP

PERMIT NUMBER: FLA147117-005
P.A. FILE NUMBER:: FLA147117-005-DW2P

9. The permittee, by accepting this permit, specifically agrees to allow authorized Department personnel, including an authorized representative of the Department and authorized EPA personnel, when applicable, upon presentation of credentials or other documents as may be required by law, and at reasonable times, depending upon the nature of the concern being investigated, to:
- Enter upon the permittee's premises where a regulated facility, system, or activity is located or conducted, or where records shall be kept under the conditions of this permit;
 - Have access to and copy any records that shall be kept under the conditions of this permit;
 - Inspect the facilities, equipment, practices, or operations regulated or required under this permit; and
 - Sample or monitor any substances or parameters at any location necessary to assure compliance with this permit or Department rules.

[62-620.610(9)]

10. In accepting this permit, the permittee understands and agrees that all records, notes, monitoring data, and other information relating to the construction or operation of this permitted source which are submitted to the Department may be used by the Department as evidence in any enforcement case involving the permitted source arising under the Florida Statutes or Department rules, except as such use is proscribed by Section 403.111, F.S., or Rule 62-620.302, F.A.C. Such evidence shall only be used to the extent that it is consistent with the Florida Rules of Civil Procedure and applicable evidentiary rules. *[62-620.610(10)]*
11. When requested by the Department, the permittee shall within a reasonable time provide any information required by law which is needed to determine whether there is cause for revising, revoking and reissuing, or terminating this permit, or to determine compliance with the permit. The permittee shall also provide to the Department upon request copies of records required by this permit to be kept. If the permittee becomes aware of relevant facts that were not submitted or were incorrect in the permit application or in any report to the Department, such facts or information shall be promptly submitted or corrections promptly reported to the Department. *[62-620.610(11)]*
12. Unless specifically stated otherwise in Department rules, the permittee, in accepting this permit, agrees to comply with changes in Department rules and Florida Statutes after a reasonable time for compliance; provided, however, the permittee does not waive any other rights granted by Florida Statutes or Department rules. A reasonable time for compliance with a new or amended surface water quality standard, other than those standards addressed in Rule 62-302.500, F.A.C., shall include a reasonable time to obtain or be denied a mixing zone for the new or amended standard. *[62-620.610(12)]*
13. The permittee, in accepting this permit, agrees to pay the applicable regulatory program and surveillance fee in accordance with Rule 62-4.052, F.A.C. *[62-620.610(13)]*
14. This permit is transferable only upon Department approval in accordance with Rule 62-620.340, F.A.C. The permittee shall be liable for any noncompliance of the permitted activity until the transfer is approved by the Department. *[62-620.610(14)]*
15. The permittee shall give the Department written notice at least 60 days before inactivation or abandonment of a wastewater facility or activity and shall specify what steps will be taken to safeguard public health and safety during and following inactivation or abandonment. *[62-620.610(15)]*
16. The permittee shall apply for a revision to the Department permit in accordance with Rules 62-620.300, F.A.C., and the Department of Environmental Protection Guide to Permitting Wastewater Facilities or Activities Under Chapter 62-620, F.A.C., at least 90 days before construction of any planned substantial modifications to the permitted facility is to commence or with Rule 62-620.325(2), F.A.C., for minor modifications to the permitted facility. A revised permit shall be obtained before construction begins except as provided in Rule 62-620.300, F.A.C. *[62-620.610(16)]*
17. The permittee shall give advance notice to the Department of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements. The permittee shall be responsible for

PERMITTEE: Naval Air Station Key West
FACILITY: Boca Chica Naval Air Station WWTP

PERMIT NUMBER: FLA147117-005
P.A. FILE NUMBER:: FLA147117-005-DW2P

any and all damages which may result from the changes and may be subject to enforcement action by the Department for penalties or revocation of this permit. The notice shall include the following information:

- a. A description of the anticipated noncompliance;
- b. The period of the anticipated noncompliance, including dates and times; and
- c. Steps being taken to prevent future occurrence of the noncompliance.

[62-620.610(17)]

18. Sampling and monitoring data shall be collected and analyzed in accordance with Rule 62-4.246 and Chapters 62-160, 62-601, and 62-610, F.A.C., and 40 CFR 136, as appropriate.
 - a. Monitoring results shall be reported at the intervals specified elsewhere in this permit and shall be reported on a Discharge Monitoring Report (DMR), DEP Form 62-620.910(10), or as specified elsewhere in the permit.
 - b. If the permittee monitors any contaminant more frequently than required by the permit, using Department approved test procedures, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the DMR.
 - c. Calculations for all limitations which require averaging of measurements shall use an arithmetic mean unless otherwise specified in this permit.
 - d. Except as specifically provided in Rule 62-160.300, F.A.C., any laboratory test required by this permit shall be performed by a laboratory that has been certified by the Department of Health Environmental Laboratory Certification Program (DOH ELCP). Such certification shall be for the matrix, test method and analyte(s) being measured to comply with this permit. For domestic wastewater facilities, testing for parameters listed in Rule 62-160.300(4), F.A.C., shall be conducted under the direction of a certified operator.
 - e. Field activities including on-site tests and sample collection shall follow the applicable standard operating procedures described in DEP-SOP-001/01 adopted by reference in Chapter 62-160, F.A.C.
 - f. Alternate field procedures and laboratory methods may be used where they have been approved in accordance with Rules 62-160.220, and 62-160.330, F.A.C.

[62-620.610(18)]

19. Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule detailed elsewhere in this permit shall be submitted no later than 14 days following each schedule date. *[62-620.610(19)]*
20. The permittee shall report to the Department's South District Office any noncompliance which may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the permittee becomes aware of the circumstances. A written submission shall also be provided within five days of the time the permittee becomes aware of the circumstances. The written submission shall contain: a description of the noncompliance and its cause; the period of noncompliance including exact dates and time, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent recurrence of the noncompliance.
 - a. The following shall be included as information which must be reported within 24 hours under this condition:
 - (1) Any unanticipated bypass which causes any reclaimed water or effluent to exceed any permit limitation or results in an unpermitted discharge,
 - (2) Any upset which causes any reclaimed water or the effluent to exceed any limitation in the permit,
 - (3) Violation of a maximum daily discharge limitation for any of the pollutants specifically listed in the permit for such notice, and
 - (4) Any unauthorized discharge to surface or ground waters.
 - b. Oral reports as required by this subsection shall be provided as follows:

PERMITTEE: Naval Air Station Key West
FACILITY: Boca Chica Naval Air Station WWTP

PERMIT NUMBER: FLA147117-005
P.A. FILE NUMBER:: FLA147117-005-DW2P

- (1) For unauthorized releases or spills of treated or untreated wastewater reported pursuant to subparagraph (a)4. that are in excess of 1,000 gallons per incident, or where information indicates that public health or the environment will be endangered, oral reports shall be provided to the STATE WARNING POINT TOLL FREE NUMBER (800) 320-0519, as soon as practical, but no later than 24 hours from the time the permittee becomes aware of the discharge. The permittee, to the extent known, shall provide the following information to the State Warning Point:
 - (a) Name, address, and telephone number of person reporting;
 - (b) Name, address, and telephone number of permittee or responsible person for the discharge;
 - (c) Date and time of the discharge and status of discharge (ongoing or ceased);
 - (d) Characteristics of the wastewater spilled or released (untreated or treated, industrial or domestic wastewater);
 - (e) Estimated amount of the discharge;
 - (f) Location or address of the discharge;
 - (g) Source and cause of the discharge;
 - (h) Whether the discharge was contained on-site, and cleanup actions taken to date;
 - (i) Description of area affected by the discharge, including name of water body affected, if any; and
 - (j) Other persons or agencies contacted.
 - (2) Oral reports, not otherwise required to be provided pursuant to subparagraph b.1 above, shall be provided to the Department's South District Office within 24 hours from the time the permittee becomes aware of the circumstances.
- c. If the oral report has been received within 24 hours, the noncompliance has been corrected, and the noncompliance did not endanger health or the environment, the Department's South District Office shall waive the written report.

[62-620.610(20)]

21. The permittee shall report all instances of noncompliance not reported under Permit Conditions IX.17., IX.18., or IX.19. of this permit at the time monitoring reports are submitted. This report shall contain the same information required by Permit Condition IX.20. of this permit. *[62-620.610(21)]*

22. Bypass Provisions.

- a. "Bypass" means the intentional diversion of waste streams from any portion of a treatment works.
- b. Bypass is prohibited, and the Department may take enforcement action against a permittee for bypass, unless the permittee affirmatively demonstrates that:
 - (1) Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage; and
 - (2) There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and
 - (3) The permittee submitted notices as required under Permit Condition IX.22.c. of this permit.
- c. If the permittee knows in advance of the need for a bypass, it shall submit prior notice to the Department, if possible at least 10 days before the date of the bypass. The permittee shall submit notice of an unanticipated bypass within 24 hours of learning about the bypass as required in Permit Condition IX.20. of this permit. A notice shall include a description of the bypass and its cause; the period of the bypass, including exact dates and times; if the bypass has not been corrected, the anticipated time it is expected to continue; and the steps taken or planned to reduce, eliminate, and prevent recurrence of the bypass.
- d. The Department shall approve an anticipated bypass, after considering its adverse effect, if the permittee demonstrates that it will meet the three conditions listed in Permit Condition IX.22.b.(1) through (3) of this permit.
- e. A permittee may allow any bypass to occur which does not cause reclaimed water or effluent limitations to be exceeded if it is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of Permit Condition IX.22.b. through d. of this permit.

PERMITTEE: Naval Air Station Key West
FACILITY: Boca Chica Naval Air Station WWTP

PERMIT NUMBER: FLA147117-005
P.A. FILE NUMBER:: FLA147117-005-DW2P

[62-620.610(22)]

23. Upset Provisions.

- a. "Upset" means an exceptional incident in which there is unintentional and temporary noncompliance with technology-based effluent limitations because of factors beyond the reasonable control of the permittee.
 - (1) An upset does not include noncompliance caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, careless or improper operation.
 - (2) An upset constitutes an affirmative defense to an action brought for noncompliance with technology based permit effluent limitations if the requirements of upset provisions of Rule 62-620.610, F.A.C., are met.
- b. A permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed contemporaneous operating logs, or other relevant evidence that:
 - (1) An upset occurred and that the permittee can identify the cause(s) of the upset;
 - (2) The permitted facility was at the time being properly operated;
 - (3) The permittee submitted notice of the upset as required in Permit Condition IX.20. of this permit; and
 - (4) The permittee complied with any remedial measures required under Permit Condition IX.5. of this permit.
- c. In any enforcement proceeding, the burden of proof for establishing the occurrence of an upset rests with the permittee.
- d. Before an enforcement proceeding is instituted, no representation made during the Department review of a claim that noncompliance was caused by an upset is final agency action subject to judicial review.

[62-620.610(23)]

X. INJECTION WELLS

1. GENERAL CRITERIA

- a. The permittee shall be aware of and operate under the General Conditions of Florida Administrative Code, (F.A.C.), Rule 62-528.307(1), (a) through (x), and 62-528.307(3)(a) through (e). These General Conditions are binding upon the permittee and enforceable pursuant to Chapter 403 of the Florida Statutes.
- b. Any permit noncompliance constitutes a violation of the Safe Drinking Water Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.
- c. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.
- d. The permittee shall take all reasonable steps to minimize or correct any adverse impact on the environment resulting from noncompliance with this permit.
- e. Proper operation and maintenance includes effective performance, adequate funding, adequate operator staffing and training, and adequate laboratory and process controls, including appropriate quality assurance procedures.
- f. This permit may be modified, revoked and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation or reissuance, or termination, or a notification of planned changes or anticipated noncompliance, does not stay any permit condition.
- g. When requested by the Department, the permittee shall furnish, within the time specified, any information needed to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit.

PERMITTEE: Naval Air Station Key West
FACILITY: Boca Chica Naval Air Station WWTP

PERMIT NUMBER: FLA147117-005
P.A. FILE NUMBER:: FLA147117-005-DW2P

h. Signatories and Certification Requirements

1. All reports and other submittals required to comply with this permit shall be signed by a person authorized under Rules 62-528.340(1) or (2), F.A.C.
2. In accordance with Rule 62-528.340(4), F.A.C., all reports shall contain the following certification:

“I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based upon my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.”

- i. The permittee shall notify the Department and obtain approval prior to any work within the well, physical alterations or additions to the injection or monitor well, including removal of the wellhead (includes well clean out or other well rehabilitation type work).
- j. The permittee shall give advance notice to the Department of any planned changes in the permitted facility or injection activity that may result in noncompliance with permit requirements.
 1. The permittee shall report any noncompliance that may endanger health or the environment, to include:
 2. Any monitoring or other information which indicates that any contaminant may cause an endangerment to an underground source of drinking water; or to adjacent surface waters, or
 3. Any noncompliance with a permit condition or malfunction of the injection system that may cause fluid migration into or between underground sources of drinking water or adjacent surface waters.
- k. Any information shall be provided orally within 24 hours from the time the permittee becomes aware of the circumstances. A written submission shall also be provided within 5 days of the time the permittee becomes aware of the circumstances. The written submission shall contain a description of the noncompliance and its cause, the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and the steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.
- l. No underground injection is allowed that causes or allows movement of fluid into an underground source of drinking water.
- m. The permittee shall retain all records of all monitoring information concerning the nature and composition of injected fluid until five years after completion of any plugging and abandonment procedures specified under Rule 62-528.435, F.A.C. The permittee shall deliver the records to the Department office that issued the permit at the conclusion of the retention period unless the permittee elects to continue retention of the records.

2. OPERATING REQUIREMENTS

- a. Injection of any fluids or materials, other than those permitted, into the disposal wells(s) will constitute a violation of this permit and shall constitute cause for permit revocation and possible enforcement action for water quality violations.
- b. Injection into the well shall not exceed a peak hourly flow rate of 300 gallons per minute (0.432) MGD Peak Daily Flow). Flow to the wellhead shall be measured with a properly calibrated flow meter(s) or such other devices as provided for in this facility’s wastewater treatment permit.
- c. In the event the permittee is temporarily unable to comply with any of the conditions of a permit due to breakdown of equipment, power outages, destruction by hazard of fire, wind, or by other cause, the permittee of the facility shall notify the Department.

PERMITTEE: Naval Air Station Key West
 FACILITY: Boca Chica Naval Air Station WWTP

PERMIT NUMBER: FLA147117-005
 P.A. FILE NUMBER:: FLA147117-005-DW2P

- d. Notification shall be made in person, by telephone, or by electronic mail within 24 hours of breakdown or malfunction to the Department's South District office.
- e. A written report of any noncompliance referenced in Specific Condition 2.c above shall be submitted to the Department's South District and Tallahassee offices within five days after its occurrence. The report shall describe the nature and cause of the breakdown or malfunction, the steps being taken or planned to be taken to correct the problem and prevent its reoccurrence, emergency procedures in use pending correction of the problem, and the time when the facility will again be operating in accordance with permit conditions.
- f. The permittee shall calibrate all pressure gauges, flow meters, chart recorders, and other related equipment associated with the injection well system on the same basis as is required by the facility wastewater permit. The permittee shall maintain all monitoring equipment and shall ensure that the monitoring equipment is calibrated and in proper operating condition at all times. Laboratory equipment, methods, and quality control will follow EPA guidelines as expressed in Standard Methods for the Examination of Water and Wastewater. The pressure gauges, flow meters, and chart recorders, as applicable to this facility, shall be calibrated using standard engineering methods. Calibration records shall be kept by the permittee at the permitted facility and be available for inspection by Department personnel upon request.
- g. In the event a well must be plugged or abandoned, the permittee shall obtain a permit from the Department as required by Chapter 62-528, Florida Administrative Code. Within 180 days of well abandonment, the permittee shall submit to the Department and the TAC the proposed plugging method, pursuant to Rule 62-528.460, F.A.C. When no longer used for their intended purpose, these wells shall be properly plugged and abandoned.

3. TESTING AND REPORTING REQUIREMENTS

- a. The injection system shall be monitored in accordance with Rule 62-528.615(2), F.A.C. The following injection well performance data shall be recorded and reported in a Monthly Operating Report as indicated below. Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity.

INJECTION WELLS

The specifications for the injection well are as follows:

<i>Casing Diameter and Type</i>	<i>Depth Cased (feet bls)</i>	<i>Open Hole Interval (feet bls)</i>
8" Schedule 40 PVC	60'	Extending from 60' to 90'

bls = below land surface.

The injection wells shall be monitored in accordance with the parameters and frequencies listed below. The flow rate shall be recorded continuously or as required by the facility wastewater permit in accordance with Rule 62-528.615(2), F.A.C. All samples shall be collected and analyzed in accordance with the quality assurance requirements of Chapter 62-160, F.A.C. The report shall include the following data:

<i>Parameters</i>	<i>Reporting Frequency</i>
Daily Flow Rate (GPM)	Daily/Monthly
Maximum Peak Hourly Flow Rate (For non-continuous recorders please substitute Average Hourly Flow for the Peak Hourly Flow Rate. Average Hourly Flow = Daily Flow Rate ÷ 24)	Daily/Monthly
Minimum Total Residual Chlorine (mg/L)	Daily/Monthly
Total Volume WWTP Effluent Injected (gallons)	Daily/Monthly

WWTP Effluent Water Quality

<i>Parameters</i>	<i>Reporting Frequency</i>
pH (Standard Units)	Monthly
Total Nitrogen (TN) (mg/L)	Monthly
Total Phosphorus (TP) (mg/L)	Monthly

PERMITTEE: Naval Air Station Key West
FACILITY: Boca Chica Naval Air Station WWTP

PERMIT NUMBER: FLA147117-005
P.A. FILE NUMBER:: FLA147117-005-DW2P

CBOD ₅ (mg/L)	Monthly
Solids, Total Suspended (mg/L)	Monthly
Fecal Coliform (#/100 mL)	Monthly

- b. In accordance with Rule 62-528.615(2), F.A.C., the permittee shall submit to the Department the results of all monitoring data collected no later than the last day of the month immediately following the end of the month of record. The results shall be sent to the Department of Environmental Protection, Marathon Branch Office, 2796 Overseas Hwy., Suite 221, Marathon, Florida 33050. The results shall be submitted in the same manner and on the same forms as required by the facility wastewater permit.
4. UIC PROGRAM DISPOSAL WELL PERMIT RENEWAL
- a. In accordance with Rules 62-4.090(1) and 62-528.455(3)(a), F.A.C., the permittee shall submit an application for renewal of the existing injection well system operating permit (a minimum of 5 copies) with the applicable fee at least 60 days prior to the expiration of this operation permit. The application for renewal shall include the items listed in Rule 62-528.455(3)(b), F.A.C.
5. EMERGENCY DISPOSAL
- a. All applicable federal, state and local permits must be in place to allow for any alternate discharges due to emergency or planned outage conditions.
 - b. Any changes in emergency disposal methods must be submitted for Technical Advisory Committee (TAC) review and Department approval.
 - c. The permittee shall notify the local office of the Department within 24 hours in the event the emergency discharge has been used. The notification should include the reason for using the emergency discharge, the duration of the discharge, and the volume discharged. Written notification shall be provided within 5 days after its occurrence.
6. The permittee is reminded of the necessity to comply with the pertinent regulations of any other regulatory agency, as well as any county, municipal, and federal regulations applicable to the project. These regulations may include, but are not limited to, those of the Federal Emergency Management Agency in implementing flood control measures. This permit should not be construed to imply compliance with the rules and regulations of other regulatory agencies.

Note: In the event of an emergency the permittee shall contact the Department by calling (800) 320-0519. The permittee shall call (239) 344-5600 during regular business hours.

Executed in Ft. Myers, Florida.

STATE OF FLORIDA DEPARTMENT OF
ENVIRONMENTAL PROTECTION



For

Jon M. Iglehart
Director of
District Management

PERMIT ISSUANCE: February 26, 2014

Attachment(s):
Discharge Monitoring Report
Statement of Basis

**STATEMENT OF BASIS
FOR
STATE OF FLORIDA DOMESTIC WASTEWATER FACILITY PERMIT**

PERMIT NUMBER: FLA147117-005

P.A. FILE NUMBER: FLA147117-005-DW2P

FACILITY NAME: Boca Chica Naval Air Station WWTP

FACILITY LOCATION: Naval Air Station, Boca Chica, MM 7.7, Key West, FL 33040
Monroe County

NAME OF PERMITTEE: Naval Air Station, Key West

PERMIT WRITER: R. Walters

1. SUMMARY OF APPLICATION

a. Chronology of Application

Application Number: FLA147117-005-DW2P

Application Submittal Date: 28 October 2013

b. Type of Facility

Domestic Wastewater Treatment Plant

Ownership Type: Federal

SIC Code: 4952

c. Facility Capacity

Existing Permitted Capacity: 0.400 MGD Annual Average Daily Flow

Proposed Increase in Permitted Capacity: 0.000 MGD Annual Average Daily Flow

Proposed Total Permitted Capacity: 0.400 MGD Annual Average Daily Flow

d. Description of Wastewater Treatment

An existing 0.400 MGD annual average daily flow (AADF) permitted capacity complete mix activated sludge (CMAS) process domestic wastewater treatment plant consisting of: one manually cleaned bar screen, one mechanically cleaned bar screen, grit removal, two surge tanks (one 85,272 gallons; one 39,793 gallons), one 46,000-gallon CMAS tank, one 70,437-gallon secondary clarifier, one 880-gallon clarifier junction box, one 11,200-gallon chlorine contact tank, one 35,954-gallon polishing tank, one approximately 112,000-gallon aerobic digester, and total 900 sq. ft. sludge drying beds.

e. Description of Effluent Disposal and Land Application Sites (as reported by applicant)

Secondary treated effluent discharged to existing underground injection control wells.

2. SUMMARY OF SURFACE WATER DISCHARGE

This facility does not discharge to surface waters.

3. BASIS FOR PERMIT LIMITATIONS AND MONITORING REQUIREMENTS

This facility is authorized to discharge reclaimed water to Underground Injection Well System U-001 which consists of six Class V injection wells based on the following:

Parameter	Units	Max/Min	Limit	Statistical Basis	Rationale
BOD, Carbonaceous 5 day, 20C	mg/L	Max	20.0	Annual Average	403.085(2) & .086(1)(b) FS & 62-600.740(1)(b)1.a. FAC
		Max	30.0	Monthly Average	62-600.740(1)(b)1.b. FAC
		Max	45.0	Weekly Average	62-600.740(1)(b)1.c. FAC
		Max	60.0	Single Sample	62-600.740(1)(b)1.d. FAC
Solids, Total Suspended	mg/L	Max	20.0	Annual Average	403.085(2) & .086(1)(b) FS & 62-600.740(1)(b)1.a. FAC
		Max	30.0	Monthly Average	62-600.740(1)(b)1.b. FAC
		Max	45.0	Weekly Average	62-600.740(1)(b)1.c. FAC
		Max	60.0	Single Sample	62-600.740(1)(b)1.d. FAC
pH	s.u.	Min	6.0	Single Sample	62-600.445 FAC
		Max	8.5	Single Sample	62-600.445 FAC
Coliform, Fecal	#/100mL	Max	200	Annual Average	Chapter 99-395, Laws of Florida, Section 6, & 62-600.440(4)(c)1. FAC
		Max	200	Monthly Geometric Mean	62-600.440(4)(c)2. FAC
		Max	800	Single Sample	62-600.440(4)(c)4. FAC
Chlorine, Total Residual (For Disinfection)	mg/L	Min	0.5	Single Sample	62-600.440(4)(b) FAC
Nitrogen, Total	mg/L	Max	Report	Single Sample	Chapter 99-395, Laws of Florida, Section 6
Phosphorus, Total (as P)	mg/L	Max	Report	Single Sample	Chapter 99-395, Laws of Florida, Section 6

Other Limitations and Monitoring Requirements:

Parameter	Units	Max/Min	Limit	Statistical Basis	Rationale
Flow	MGD	Max	Report	Monthly Average	62-600.440(4)(b) FAC
Flow	MGD	Max	Report	3-Month Rolling Average	62-600.440(4)(b) FAC
Flow	MGD	Max	0.400	Annual Average	62-600.440(4)(b) FAC
Percent Capacity, (TMADF/Permitted Capacity) x 100	percent	Max	Report	3-Month Rolling Average	62-600.440(4)(b) FAC

Parameter	Units	Max/Min	Limit	Statistical Basis	Rationale
BOD, Carbonaceous 5 day, 20C (Influent)	mg/L	Max	Report	Monthly Avg.	62-601.300(1) FAC
Solids, Total Suspended (Influent)	mg/L	Max	Report	Monthly Avg.	62-601.300(1) FAC
Monitoring Frequencies and Sample Types	-	-	-	All Parameters	62-601 FAC & 62-699 FAC and/or BPJ of permit writer
Sampling Locations	-	-	-	All Parameters	62-601, 62-610.412, 62-610.463(1), 62-610.568, 62-610.613 FAC and/or BPJ of permit writer

4. DISCUSSION OF CHANGES TO PERMIT LIMITATIONS

The maximum annual average, effluent limitations are scheduled to become effective on January 1, 2016: CBOD₅, 5 mg/L, TSS, 5 mg/L, TN, 3 mg/L, TP, 1 mg/L.

Basis: Chapter 403.086(10), Florida Statutes; Chapter 99-395, Laws of Florida, Section 6, Subsection (4) and (6).

5. BIOSOLIDS MANAGEMENT REQUIREMENTS

Biosolids generated by this facility may be transferred to sludge tanks at the City of Key West WWTP, or disposed of in a Class I solid waste landfill.

See the table below for the rationale for the biosolids quantities monitoring requirements.

Parameter	Units	Max/Min	Limit	Statistical Basis	Rationale
Biosolids Quantity (Landfilled)	dry tons	Max	Report	Monthly Total	62-640.650(5)(a)1. FAC
Biosolids Quantity (Transferred)	dry tons	Max	Report	Monthly Total	62-640.650(5)(a)1. FAC
Monitoring Frequency	All Parameters				62-640.650(5)(a) FAC

6. GROUND WATER MONITORING REQUIREMENTS

This section is not applicable to this facility.

7. PERMIT SCHEDULES

A schedule of improvement actions is not included in the wastewater permit.

8. INDUSTRIAL PRETREATMENT REQUIREMENTS

At this time, the facility is not required to develop an approved industrial pretreatment program. However, the Department reserves the right to require an approved program if future conditions warrant.

9. ADMINISTRATIVE ORDERS (AO) AND CONSENT ORDERS (CO)

This permit is not accompanied by an AO and has not entered into a CO with the Department.

10. REQUESTED VARIANCES OR ALTERNATIVES TO REQUIRED STANDARDS

No variances were requested for this facility.

11. THE ADMINISTRATIVE RECORD

The administrative record including application, and additional information is available for public inspection during normal business hours at the location specified in item 12. Copies will be provided at a minimal charge per page.

12. DEP CONTACT

Additional information concerning the permit and proposed schedule for permit issuance may be obtained during normal business hours from:

R. Walters
Engineering Specialist
South District Office
2295 Victoria Ave., Suite 364
Ft. Myers, FL 33901

Telephone No.: (239) 344-5703

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

When Completed mail this report to: Department of Environmental Protection, Marathon Branch Office, 2796 Overseas Hwy., Suite 221, Marathon, FL 33050

PERMITTEE NAME: Naval Air Station Key West
 MAILING ADDRESS: P.O. Box 9001
 Key West, Florida 33040

PERMIT NUMBER: FLA147117-005

LIMIT: Final
 CLASS SIZE: N/A
 MONITORING GROUP NUMBER: U-001
 MONITORING GROUP DESCRIPTION: Six Class V injection wells, with Influent

REPORT FREQUENCY: Monthly
 PROGRAM: Domestic

FACILITY: Boca Chica Naval Air Station WWTP
 LOCATION: Naval Air Station, Boca Chica
 MM 7.7
 Key West, FL 33040

RE-SUBMITTED DMR:
 NO DISCHARGE FROM SITE:
 MONITORING PERIOD From: _____ To: _____

COUNTY: Monroe
 OFFICE: South District

**THIS REPORT FORM IS NOT VALID
 AFTER DECEMBER 31, 2015.**

Parameter		Quantity or Loading	Units	Quality or Concentration	Units	No. Ex.	Frequency of Analysis	Sample Type
BOD, Carbonaceous 5 day, 20C	Sample Measurement							
PARM Code 80082 Y Mon. Site No. EFA-01	Permit Requirement			20.0 (An.Avg.)	mg/L		Every 2 weeks	8-hr FPC
BOD, Carbonaceous 5 day, 20C	Sample Measurement							
PARM Code 80082 A Mon. Site No. EFA-01	Permit Requirement			60.0 (Max.) 45.0 (Wk.Avg.) 30.0 (Mo.Avg.)	mg/L		Every 2 weeks	8-hr FPC
Solids, Total Suspended	Sample Measurement							
PARM Code 00530 Y Mon. Site No. EFA-01	Permit Requirement			20.0 (An.Avg.)	mg/L		Every 2 weeks	8-hr FPC
Solids, Total Suspended	Sample Measurement							
PARM Code 00530 A Mon. Site No. EFA-01	Permit Requirement			60.0 (Max.) 45.0 (Wk.Avg.) 30.0 (Mo.Avg.)	mg/L		Every 2 weeks	8-hr FPC
pH	Sample Measurement							
PARM Code 00400 A Mon. Site No. EFA-01	Permit Requirement			6.0 (Min.) 8.5 (Max.)	s.u.		5 Days/Week	Grab
Coliform, Fecal	Sample Measurement							
PARM Code 74055 Y Mon. Site No. EFA-01	Permit Requirement			200 (An.Avg.)	#/100mL		Every 2 weeks	Grab

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (mm/dd/yyyy)

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here):

DISCHARGE MONITORING REPORT - PART A (Continued)

FACILITY: Boca Chica Naval Air Station WWTP

MONITORING GROUP U-001

PERMIT NUMBER: FLA147117-005

NUMBER:

MONITORING PERIOD

From: _____

To: _____

THIS REPORT FORM IS NOT VALID AFTER DECEMBER 31, 2015.

Parameter		Quantity or Loading	Units	Quality or Concentration	Units	No. Ex.	Frequency of Analysis	Sample Type
Coliform, Fecal	Sample Measurement							
PARM Code 74055 A Mon. Site No. EFA-01	Permit Requirement			200 (Mo.Geo.Mn.)	800 (Max.)	#/100mL	Every 2 weeks	Grab
Chlorine, Total Residual (For Disinfection)	Sample Measurement							
PARM Code 50060 A Mon. Site No. EFA-01	Permit Requirement			0.5 (Min.)		mg/L	5 Days/Week	Grab
Nitrogen, Total	Sample Measurement							
PARM Code 00600 A Mon. Site No. EFA-01	Permit Requirement				Report (Max.)	mg/L	Every 2 weeks	8-hr FPC
Phosphorus, Total (as P)	Sample Measurement							
PARM Code 00665 A Mon. Site No. EFA-01	Permit Requirement				Report (Max.)	mg/L	Every 2 weeks	8-hr FPC
Flow	Sample Measurement							
PARM Code 50050 1 Mon. Site No. FLW-01	Permit Requirement	Report (Mo.Avg.)	MGD				Continuous	Flow Totalizer
Flow	Sample Measurement							
PARM Code 50050 Q Mon. Site No. FLW-01	Permit Requirement	Report (3-Mo.Avg.)	MGD				Monthly	Flow Totalizer
Flow	Sample Measurement							
PARM Code 50050 Y Mon. Site No. FLW-01	Permit Requirement	0.400 (An.Avg.)	MGD				Continuous	Flow Totalizer
Percent Capacity, (TMADF/Permitted Capacity) x 100	Sample Measurement							
PARM Code 00180 P Mon. Site No. CAL-01	Permit Requirement				Report (3Mo.Avg.)	percent	Continuous	Calculated
BOD, Carbonaceous 5 day, 20C (Influent)	Sample Measurement							
PARM Code 80082 Q Mon. Site No. INF-01	Permit Requirement				Report (Mo.Avg.)	mg/L	Every 2 weeks	8-hr FPC
Solids, Total Suspended (Influent)	Sample Measurement							
PARM Code 00530 Q Mon. Site No. INF-01	Permit Requirement				Report (Mo.Avg.)	mg/L	Every 2 weeks	8-hr FPC

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

When Completed mail this report to: Department of Environmental Protection, Marathon Branch Office, 2796 Overseas Hwy., Suite 221, Marathon, FL 33050

PERMITTEE NAME: Naval Air Station, Key West
 MAILING ADDRESS: P.O. Box 9001
 Key West, Florida 33040

PERMIT NUMBER: FLA147117-005

LIMIT: Final
 CLASS SIZE: N/A
 MONITORING GROUP NUMBER: RMP-Q
 MONITORING GROUP DESCRIPTION: Biosolids Quantity

REPORT FREQUENCY: Monthly
 PROGRAM: Domestic

FACILITY: Boca Chica Naval Air Station WWTP
 LOCATION: Naval Air Station, Boca Chica
 MM 7.7
 Key West, FL 33040

RE-SUBMITTED DMR:
 NO DISCHARGE FROM SITE:
 MONITORING PERIOD From: _____ To: _____

COUNTY: Monroe
 OFFICE: South District

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Biosolids Quantity (Landfilled)	Sample Measurement										
PARM Code B0008 + Mon. Site No. RMP-1	Permit Requirement		Report (Mo.Total)	dry tons						Monthly	Calculated
Biosolids Quantity (Transferred)	Sample Measurement										
PARM Code B0007 + Mon. Site No. RMP-1	Permit Requirement		Report (Mo.Total)	dry tons						Monthly	Calculated

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (mm/dd/yyyy)

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here):

DAILY SAMPLE RESULTS - PART B

Permit Number: FLA147117-005
 Monitoring Period From: _____ To: _____

Facility: Boca Chica Naval Air Station WWTP

	BOD, Carbonaceous 5 day, 20C mg/L	Chlorine, Total Residual (For Disinfection) mg/L	Coliform, Fecal #/100mL	Nitrogen, Total mg/L	Phosphorus, Total (as P) mg/L	Solids, Total Suspended mg/L	pH s.u.	Flow MGD	BOD, Carbonaceous 5 day, 20C (Influent) mg/L	Solids, Total Suspended (Influent) mg/L	
Code	80082	50060	74055	00600	00665	00530	00400	50050	80082	00530	
Mon. Site	EFA-01	EFA-01	EFA-01	EFA-01	EFA-01	EFA-01	EFA-01	FLW-01	INF-01	INF-01	
1											
2											
3											
4											
5											
6											
7											
8											
9											
10											
11											
12											
13											
14											
15											
16											
17											
18											
19											
20											
21											
22											
23											
24											
25											
26											
27											
28											
29											
30											
31											
Total											
Mo. Avg.											

PLANT STAFFING:

Day Shift Operator Class: _____ Certificate No: _____ Name: _____

Evening Shift Operator Class: _____ Certificate No: _____ Name: _____

Night Shift Operator Class: _____ Certificate No: _____ Name: _____

Lead Operator Class: _____ Certificate No: _____ Name: _____

INSTRUCTIONS FOR COMPLETING THE WASTEWATER DISCHARGE MONITORING REPORT

Read these instructions before completing the DMR. Hard copies and/or electronic copies of the required parts of the DMR were provided with the permit. All required information shall be completed in full and typed or printed in ink. A signed, original DMR shall be mailed to the address printed on the DMR by the 28th of the month following the monitoring period. The DMR shall not be submitted before the end of the monitoring period.

The DMR consists of three parts--A, B, and D--all of which may or may not be applicable to every facility. Facilities may have one or more Part A's for reporting effluent or reclaimed water data. All domestic wastewater facilities will have a Part B for reporting daily sample results. Part D is used for reporting ground water monitoring well data.

When results are not available, the following codes should be used on parts A and D of the DMR and an explanation provided where appropriate. Note: Codes used on Part B for raw data are different.

CODE	DESCRIPTION/INSTRUCTIONS
ANC	Analysis not conducted.
DRY	Dry Well
FLD	Flood disaster.
IFS	Insufficient flow for sampling.
LS	Lost sample.
MNR	Monitoring not required this period.

CODE	DESCRIPTION/INSTRUCTIONS
NOD	No discharge from/to site.
OPS	Operations were shutdown so no sample could be taken.
OTH	Other. Please enter an explanation of why monitoring data were not available.
SEF	Sampling equipment failure.

When reporting analytical results that fall below a laboratory's reported method detection limits or practical quantification limits, the following instructions should be used:

1. Results greater than or equal to the PQL shall be reported as the measured quantity.
2. Results less than the PQL and greater than or equal to the MDL shall be reported as the laboratory's MDL value. These values shall be deemed equal to the MDL when necessary to calculate an average for that parameter and when determining compliance with permit limits.
3. Results less than the MDL shall be reported by entering a less than sign (" $<$ ") followed by the laboratory's MDL value, e.g. < 0.001 . A value of one-half the MDL or one-half the effluent limit, whichever is lower, shall be used for that sample when necessary to calculate an average for that parameter. Values less than the MDL are considered to demonstrate compliance with an effluent limitation.

PART A -DISCHARGE MONITORING REPORT (DMR)

Part A of the DMR is comprised of one or more sections, each having its own header information. Facility information is preprinted in the header as well as the monitoring group number, whether the limits and monitoring requirements are interim or final, and the required submittal frequency (e.g. monthly, annually, quarterly, etc.). Submit Part A based on the required reporting frequency in the header and the instructions shown in the permit. The following should be completed by the permittee or authorized representative:

Resubmitted DMR: Check this box if this DMR is being re-submitted because there was information missing from or information that needed correction on a previously submitted DMR. The information that is being revised should be clearly noted on the re-submitted DMR (e.g. highlight, circle, etc.)

No Discharge From Site: Check this box if no discharge occurs and, as a result, there are no data or codes to be entered for all of the parameters on the DMR for the entire monitoring group number; however, if the monitoring group includes other monitoring locations (e.g., influent sampling), the "NOD" code should be used to individually denote those parameters for which there was no discharge.

Monitoring Period: Enter the month, day, and year for the first and last day of the monitoring period (i.e. the month, the quarter, the year, etc.) during which the data on this report were collected and analyzed.

Sample Measurement: Before filling in sample measurements in the table, check to see that the data collected correspond to the limit indicated on the DMR (i.e. interim or final) and that the data correspond to the monitoring group number in the header. Enter the data or calculated results for each parameter on this row in the non-shaded area above the limit. Be sure the result being entered corresponds to the appropriate statistical base code (e.g. annual average, monthly average, single sample maximum, etc.) and units.

No. Ex.: Enter the number of sample measurements during the monitoring period that exceeded the permit limit for each parameter in the non-shaded area. If none, enter zero.

Frequency of Analysis: The shaded areas in this column contain the minimum number of times the measurement is required to be made according to the permit. Enter the actual number of times the measurement was made in the space above the shaded area.

Sample Type: The shaded areas in this column contain the type of sample (e.g. grab, composite, continuous) required by the permit. Enter the actual sample type that was taken in the space above the shaded area.

Signature: This report must be signed in accordance with Rule 62-620.305, F.A.C. Type or print the name and title of the signing official. Include the telephone number where the official may be reached in the event there are questions concerning this report. Enter the date when the report is signed.

Comment and Explanation of Any Violations: Use this area to explain any exceedances, any upset or by-pass events, or other items which require explanation. If more space is needed, reference all attachments in this area.

PART B - DAILY SAMPLE RESULTS

Monitoring Period: Enter the month, day, and year for the first and last day of the monitoring period (i.e. the month, the quarter, the year, etc.) during which the data on this report were collected and analyzed.

Daily Monitoring Results: Transfer all analytical data from your facility's laboratory or a contract laboratory's data sheets for all day(s) that samples were collected. Record the data in the units indicated. Table 1 in Chapter 62-160, F.A.C., contains a complete list of all the data qualifier codes that your laboratory may use when reporting analytical results. However, when transferring numerical results onto Part B of the DMR, only the following data qualifier codes should be used and an explanation provided where appropriate.

CODE	DESCRIPTION/INSTRUCTIONS
<	The compound was analyzed for but not detected.
A	Value reported is the mean (average) of two or more determinations.
J	Estimated value, value not accurate.
Q	Sample held beyond the actual holding time.
Y	Laboratory analysis was from an unpreserved or improperly preserved sample.

To calculate the monthly average, add each reported value to get a total. For flow, divide this total by the number of days in the month. For all other parameters, divide the total by the number of observations.

Plant Staffing: List the name, certificate number, and class of all state certified operators operating the facility during the monitoring period. Use additional sheets as necessary.

PART D - GROUND WATER MONITORING REPORT

Monitoring Period: Enter the month, day, and year for the first and last day of the monitoring period (i.e. the month, the quarter, the year, etc.) during which the data on this report were collected and analyzed.

Date Sample Obtained: Enter the date the sample was taken. Also, check whether or not the well was purged before sampling.

Time Sample Obtained: Enter the time the sample was taken.

Sample Measurement: Record the results of the analysis. If the result was below the minimum detection limit, indicate that.

Detection Limits: Record the detection limits of the analytical methods used.

Analysis Method: Indicate the analytical method used. Record the method number from Chapter 62-160 or Chapter 62-601, F.A.C., or from other sources.

Sampling Equipment Used: Indicate the procedure used to collect the sample (e.g. airlift, bucket/bailer, centrifugal pump, etc.)

Samples Filtered: Indicate whether the sample obtained was filtered by laboratory (L), filtered in field (F), or unfiltered (N).

Signature: This report must be signed in accordance with Rule 62-620.305, F.A.C. Type or print the name and title of the signing official. Include the telephone number where the official may be reached in the event there are questions concerning this report. Enter the date when the report is signed.

Comments and Explanation: Use this space to make any comments on or explanations of results that are unexpected. If more space is needed, reference all attachments in this area.

SPECIAL INSTRUCTIONS FOR LIMITED WET WEATHER DISCHARGES

Flow (Limited Wet Weather Discharge): Enter the measured average flow rate during the period of discharge or divide gallons discharged by duration of discharge (converted into days). Record in million gallons per day (MGD).

Flow (Upstream): Enter the average flow rate in the receiving stream upstream from the point of discharge for the period of discharge. The average flow rate can be calculated based on two measurements; one made at the start and one made at the end of the discharge period. Measurements are to be made at the upstream gauging station described in the permit.

Actual Stream Dilution Ratio: To calculate the Actual Stream Dilution Ratio, divide the average upstream flow rate by the average discharge flow rate. Enter the Actual Stream Dilution Ratio accurate to the nearest 0.1.

No. of Days the SDF > Stream Dilution Ratio: For each day of discharge, compare the minimum Stream Dilution Factor (SDF) from the permit to the calculated Stream Dilution Ratio. On Part B of the DMR, enter an asterisk (*) if the SDF is greater than the Stream Dilution Ratio on any day of discharge. On Part A of the DMR, add up the days with an "*" and record the total number of days the Stream Dilution Factor was greater than the Stream Dilution Ratio.

CBOD₅: Enter the average CBOD₅ of the reclaimed water discharged during the period shown in duration of discharge.

TKN: Enter the average TKN of the reclaimed water discharged during the period shown in duration of discharge.

Actual Rainfall: Enter the actual rainfall for each day on Part B. Enter the actual cumulative rainfall to date for this calendar year and the actual total monthly rainfall on Part A. The cumulative rainfall to date for this calendar year is the total amount of rain, in inches, that has been recorded since January 1 of the current year through the month for which this DMR contains data.

Rainfall During Average Rainfall Year: On Part A, enter the total monthly rainfall during the average rainfall year and the cumulative rainfall for the average rainfall year. The cumulative rainfall for the average rainfall year is the amount of rain, in inches, which fell during the average rainfall year from January through the month for which this DMR contains data.

No. of Days LWWD Activated During Calendar Year: Enter the cumulative number of days that the limited wet weather discharge was activated since January 1 of the current year.

Reason for Discharge: Attach to the DMR a brief explanation of the factors contributing to the need to activate the limited wet weather discharge.