

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>			1. CONTRACT ID CODE	PAGE OF PAGES 1   2	
2. AMENDMENT/MODIFICATION NO. 0002		3. EFFECTIVE DATE 29-Oct-2015	4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO.(If applicable)
6. ISSUED BY NAVFAC SOUTHEAST SOUTH TEXAS AREA PWD CORPUS CHRISTI/PWD INGLESIDE 8851 OCEAN DRIVE, BLDG 19 CORPUS CHRISTI TX 78419-5525		CODE N69450	7. ADMINISTERED BY (If other than item 6) <b>See Item 6</b>		CODE
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)			X	9A. AMENDMENT OF SOLICITATION NO. N69450-16-Q-3208	
			X	9B. DATED (SEE ITEM 11) 21-Oct-2015	
				10A. MOD. OF CONTRACT/ORDER NO.	
				10B. DATED (SEE ITEM 13)	
CODE			FACILITY CODE		
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS					
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.					
12. ACCOUNTING AND APPROPRIATION DATA (If required)					
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.					
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.					
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).					
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:					
D. OTHER (Specify type of modification and authority)					
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.					
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)  REQUESTS FOR INFORMATION  THIS SOLICITATION IS AMENDED TO PROVIDE ANSWERS TO SUBMITTED PRE-PROPOSAL INQUIRIES					
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.					
15A. NAME AND TITLE OF SIGNER (Type or print)			16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print) JOEL OVERSON / CONTRACTING OFFICER TEL: 361-516-6107 EMAIL: joel.overson@navy.mil		
15B. CONTRACTOR/OFFEROR  _____ (Signature of person authorized to sign)		15C. DATE SIGNED	16B. UNITED STATES OF AMERICA  BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED  29-Oct-2015

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

**SUMMARY OF CHANGES**

SECTION SF 30 - BLOCK 14 CONTINUATION PAGE

The following have been added by full text:

PRE-PROPOSAL INQUIRIES

Q1. What is the thickness of the existing concrete that is to be drilled or saw cut?

A1. The thickness of concrete driveway aprons around the area varies. Typically it is approximately 6" (inches) to 8" (inches) thick around the area.

Q2. Are there any underground obstacles (piping, wiring, etc.)?

A2. Contractor will need to get excavation/dig permit prior to commencement of work. Line locator will mark all the existing underground utilities lines.

Q3. Will we be able to shut the fuel dispensing station down while we install the bollards or will it need to remain operational?

A3. During drilling process, the fuel dispenser may need to be shut down and it can be coordinated with the owner/user (Javier Portillo 361-961-3265 or John McNeil 361-961-2659).

Q4. Is there a MIL spec number for the paint or is it any TGIC polyester outdoor finish RAL 1028 yellow paint. We contacted Sherwin Williams and they asked us for the MIL spec number.

A4. Please find the attachment for TGIC polyester outdoor finish RAL 1028 yellow product information. Apply to a minimum dry film thickness of 2.0 mils.

(End of Summary of Changes)



# TECHNICAL INFORMATION

## POWDURA® RAL SERIES SUPER DURABLE POLYESTER TGIC-FREE POWDER COATING

### PRODUCT DESCRIPTION

**RYS8-00019  
RAL 1028 GL**

**POWDURA® RAL Series Super Durable Polyester TGIC-free Powder Coatings** are recommended for a broad range of interior/exterior decorative applications. They are designed for superior weatherability compared to standard polyester powder coatings.

#### **Advantages:**

- Excellent exterior color and gloss retention
- Excellent overbake resistance
- Good chemical resistance

Many applications, including:  
Windows  
Doors  
Frames  
Railings  
Fencing  
Heavy Equipment

**Storage: Powdura® Powder Coatings** should be kept in a dry and cool area at temperatures below 80°F (27°C). When not in use, store powder in sealed containers: fine powders are hygroscopic.

**Substrate Preparation:** Substrate should be free of grease, oil, dirt, fingerprints, drawing compounds, any contamination, and surface preparation treatments to ensure optimum adhesion and coating performance properties. The use of a chemical conversion coating prior to the application of a powder coating is strongly recommended.

**Testing:** Due to the wide variety of substrates, surface preparation methods, application methods, and environments, the customer should test the complete system for adhesion, compatibility and performance prior to full-scale application.

### CAUTIONS

Thoroughly review product MSDS prior to using this product. Please consult your local sales representative or your local Sherwin-Williams facility for additional information.

### APPLICATION

**Cure Schedule:** 10 MINS @ 400F  
10 MINS @ 205C

**Film Thickness Range (mils):** 3.0-4.0

### ATTRIBUTES

**Specific Gravity( g/ml ):** 1.47

**Coverage at 1.0 Mil( ft<sup>2</sup> /lb )** 131.2

**60° Gloss:** 85-100  
(ASTM D-523)

**Adhesion:** 5B  
(ASTM D-3359)

**Flexibility:** Pass 1/8"  
(ASTM D-522)

**Pencil Hardness:** H-2H  
(ASTM D-3363)

**Impact Resistance (in.lb):** Dir 80 in-lbs  
(ASTM D-2794) Rev 80 in-lbs

**Note:** Performance measured using 24-gauge Bonderite® 1000 test panels.

**Shelf Life:** 12 Months

#### **Note:**

Product Data Sheets are periodically updated to reflect new information relating to the product. It is important that the customer obtain the most recent Product Data Sheet for the product being used. The information, rating and opinions stated above pertain to the material currently offered and represent the results of tests believed to be reliable. However, due to variations in customer handling and methods of application, which are not known, or under our control, The Sherwin-Williams Company cannot make any warranties or guaranties as to the end results.

Grove City Product Mod  
18-Mar-2015