

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>			1. CONTRACT ID CODE	PAGE OF PAGES 1   3
2. AMENDMENT/MODIFICATION NO. 0001	3. EFFECTIVE DATE 26-Jan-2016	4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO.(If applicable)
6. ISSUED BY NAVFAC SOUTHEAST SOUTH TEXAS AREA PWD CORPUS CHRISTI/PWD INGLESIDE 8851 OCEAN DRIVE, BLDG 19 CORPUS CHRISTI TX 78419-5525	CODE N69450	7. ADMINISTERED BY (If other than item 6) <b>See Item 6</b>		
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)		X	9A. AMENDMENT OF SOLICITATION NO. N69450-16-Q-3217	
		X	9B. DATED (SEE ITEM 11) 07-Jan-2016	
			10A. MOD. OF CONTRACT/ORDER NO.	
			10B. DATED (SEE ITEM 13)	
CODE	FACILITY CODE			
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS				
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.				
12. ACCOUNTING AND APPROPRIATION DATA (If required)				
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.				
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.				
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).				
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:				
D. OTHER (Specify type of modification and authority)				
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.				
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)  PPIs				
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.				
15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print) JOEL OVERSON / CONTRACTING OFFICER TEL: 361-961-3397 EMAIL: joel.overson@navy.mil		
15B. CONTRACTOR/OFFEROR  _____ (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA  BY _____ (Signature of Contracting Officer)	16C. DATE SIGNED 26-Jan-2016	

## SECTION SF 30 BLOCK 14 CONTINUATION PAGE

**SUMMARY OF CHANGES**

## SECTION SF 30 - BLOCK 14 CONTINUATION PAGE

The following have been added by full text:

PRE-PROPOSAL INQUIRIES

Pre-Proposal Inquiries

Q1. Specification Paragraph 13.8.1 Site Work/Assessment describes the pump equipment as located fifteen feet below grade. During the site visit on January 19, 2016, the pump equipment appears to be much shallower than fifteen feet. Please verify the depth of the equipment.

A1. Please undertake demolition, removal, and replacement of equipment as specified at the existing depth for the given lift station.

Q2. Specification Paragraph 13.8.2 Demolition/Removal calls for the demolition of any and all piping, fittings, and valves. Specification 13.8.3 Installation addresses the installation of an isolation valve, but does not address any additional piping, fittings, or valves. Please describe the extent of the replacement of the piping, fittings, and valves.

A2. Please replace any and all piping, fittings, and valves.

Q3. Can the existing electrical conduits between the lift station and the control panel be reused? Further, can the conduits between the main breaker for the pump station and the existing control panel be reused. Specifications call for all conduits be Schedule 40 stainless steel. The existing conduits are not stainless steel.

A3. Please utilize austenitic stainless steel (316L or 316) explosion proof and water proof hardware consisting of ASTM A312 schedule 40 austenitic stainless steel (316L or 316) piping or austenitic stainless steel (316L or 316) heavy wall tubing as per the specification.

Q4. Paragraph 2; This spec calls for replacement pumps "to match two existing EBARA Vortex submersible pumps" yet, this spec goes on to call for "grinder pumps of approximately equivalent physical requirements". The existing pumps are solids handling sewage pumps, not grinder pumps. Clarification needs to be provided specifying with certainty if the customer is asking to replace the existing solids handling pumps with grinder pumps. We can provide pumps to match either requirement, yet we would not recommend grinder pumps for this application. Rather we would encourage the continued use of a Vortex non-clog sewage pump.

A4. Use a Vortex non-clog sewage pump.

Q5. Can you provide information on existing control panel systems?

A5. No information available.

Q6. Section 13.8.3; Again in this section the call for "grinder" pumps is made.

A6. Use a Vortex non-clog sewage pump.

(End of Summary of Changes)

N69450-16-Q-3217

0001

Page 3 of 3