

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE OF PAGES 1 3
2. AMENDMENT/MODIFICATION NO. 0001	3. EFFECTIVE DATE 21-Mar-2016	4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO.(If applicable)
6. ISSUED BY NAVFAC SOUTHEAST SOUTH TEXAS AREA PWD CORPUS CHRISTI/PWD INGLESIDE 8851 OCEAN DRIVE, BLDG 19 CORPUS CHRISTI TX 78419-5525	CODE N69450	7. ADMINISTERED BY (If other than item 6) See Item 6		
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)		X	9A. AMENDMENT OF SOLICITATION NO. N69450-16-Q-3221	
		X	9B. DATED (SEE ITEM 11) 17-Feb-2016	
			10A. MOD. OF CONTRACT/ORDER NO.	
			10B. DATED (SEE ITEM 13)	
CODE	FACILITY CODE			
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS				
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.				
12. ACCOUNTING AND APPROPRIATION DATA (If required)				
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.				
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.				
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).				
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:				
D. OTHER (Specify type of modification and authority)				
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.				
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)				
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.				
15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print) JOEL OVERSON / CONTRACTING OFFICER TEL: 361-961-3397 EMAIL: joel.overson@navy.mil		
15B. CONTRACTOR/OFFEROR _____ (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer)	16C. DATE SIGNED 21-Mar-2016	

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

SECTION SF 30 - BLOCK 14 CONTINUATION PAGE

The following have been added by full text:

PRE-PROPOSAL INQUIRIES

PRE-PROPOSAL INQUIRIES

1 – At the site visit we noticed that the Fresh Air Intake and the Exhaust Vent Pipe were rusted.

Question

Are these to be replaced on both Boilers per this SOW/Project?

2 – On page 6-7 of the SOW #6 it talks about the Boilers being tested under Direct Supervision of a NBBi Licensed Boiler and Pressure Vessel Inspector-

Question

Will this test be Done by Roger of NAS/NAVFAC or does NAS CC want the contractor to hire a third party inspection service?

Then have Roger from NAS/NAVFAC to confirm the third party test?

3 – On page 7 of the SOW Question #13.6

Question

It states that this work requires a Licensed NBBi Boiler and Pressure Inspector/

Will this still be required if NAS CC has Roger from NAS?NAVFAC doing the inspection?

4 – Once the old units are removed from their current placement what does NAS CC want the Contractor do with the Old Boilers?

5 - All three (3) of the Hamilton EVO Boilers are tied together Power and Controls, In other words they are Daisy Chained together.

Question:

Are we to take all three (3) boilers off line while we replace Boilers #2 and #3?

6 - Each Boiler should have their own Disconnect Box per the NEC and be within sight of the Boilers.

Question

Are we to bring Boilers #1, #2 and #3 up to Newest Mechanical and NEC Electrical Code?

7 - Will the Carrier A/C Temp trailer be removed as we will need to get a Forklift into that area to remove the Old boilers and place the new boilers.

1. Yes these can be replaced with the boilers

2. NAVFAC requirement is that work be completed with a NBBi licensed boiler and pressure vessel inspector present. Roger will provide final approval for all work completed.

3. Answered with number 2. NAVFAC will provide a final inspection and the NAVFAC boiler inspector will provide final acceptance, but Licensed NBBi boiler and pressure vessel inspector is required for installation and must be provided by the contractor.

4. After the boilers have been removed, NAS CC would like the removed boilers to be placed in building 1282.

5. The goal of this project was to replace the damage/non operational boilers without making further changes to the system. If all three boilers have to be off line to replace two, then all three boilers have to be off line to replace two.

6. Not at this time.

7. We will coordinate with the shops to move the temp chiller to allow clearance.

(End of Summary of Changes)