

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE OF PAGES 1 2	
2. AMENDMENT/MODIFICATION NO. 0001		3. EFFECTIVE DATE 22-Mar-2016	4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO.(If applicable)
6. ISSUED BY NAVFAC SOUTHEAST SOUTH TEXAS AREA PWD CORPUS CHRISTI/PWD INGLESIDE 8851 OCEAN DRIVE, BLDG 19 CORPUS CHRISTI TX 78419-5525		CODE N69450	7. ADMINISTERED BY (If other than item 6) See Item 6		CODE
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)			X	9A. AMENDMENT OF SOLICITATION NO. N69450-16-Q-3222	
			X	9B. DATED (SEE ITEM 11) 25-Feb-2016	
				10A. MOD. OF CONTRACT/ORDER NO.	
				10B. DATED (SEE ITEM 13)	
CODE			FACILITY CODE		
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS					
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.					
12. ACCOUNTING AND APPROPRIATION DATA (If required)					
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.					
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.					
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).					
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:					
D. OTHER (Specify type of modification and authority)					
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.					
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) PRE-PROPOSAL INQUIRIES					
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.					
15A. NAME AND TITLE OF SIGNER (Type or print)			16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print) JOEL OVERSON / CONTRACTING OFFICER TEL: 361-961-3397 EMAIL: joel.overson@navy.mil		
15B. CONTRACTOR/OFFEROR _____ (Signature of person authorized to sign)		15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED 22-Mar-2016

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

SECTION SF 30 - BLOCK 14 CONTINUATION PAGE

The following have been added by full text:

PRE-PROPOSAL INQUIRIES

1. Can the as-built drawings of the currently installed devices be provided?
2. Are the programming disks for these panels attainable?
3. Can the individual points lists for these panels be provided?
4. Are there any current inspection reports that can be provided to the contractor?
5. Is the contractor to assume all systems and panels are fully functioning?
6. Only one of the panels had power to it, why are the other ones down?
7. Specs state that the panel in building 1821 needs to be replaced with a refurbished panel. Specifications on this project also call for all materials to be new in order to achieve factory warranty, although the contractor would suggest using a current model panel with full backwards compatibility in order to be able to use existing field appliances. Please clarify.
8. Are we to assume responsibility for all of the field wiring?
9. Are we to assume responsibility for all of the field devices?
10. After installation of the new panels, sub-contractor will be required to perform 100% testing on the devices to verify proper operation. Will Prime and Sub- Contractors have access to all areas of the building to perform these tests? Will an escort be required?
11. What documentation will be required for acceptance testing?

1. We do not have configuration files for 1217 or 1281- we may have it for 1283 but will need time to locate
2. Programming disks are not available through the public works department.
3. The only printout available and possibly not complete or correct is for 1281 left in the panel by the original installer.
4. Inspections are done by personnel and stored in PDA's but wouldn't be a full inspection report.
5. The system components are fully functional, but the panels have a defect that can not be repaired and require replacement.
6. 1281 is tagged out because the system has been malfunctioning and can not be reset to operate properly. 1283 will not power on but power is present at the panel.
7. 1281 using a current model panel with full backwards compatibility is fine.
8. Yes
9. Yes
10. Yes, the prime and sub-contractor, as long as they have passed background, will have access to the building to test the system without escort. Unlocking of doors to panel locations will need to be coordinated through the associated building monitor.
11. Before requesting final approval of the installation and if required by the authority having jurisdiction, the installing contractor shall furnish a written statement stating that the system has been installed in accordance with approved plans and tested in accordance with the manufacturer's published instructions and the appropriate NFPA requirements. [NFPA 72-10:10.18.1.3]

(End of Summary of Changes)