

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE OF PAGES 1 4
2. AMENDMENT/MODIFICATION NO. 0001	3. EFFECTIVE DATE 15-Apr-2016	4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO.(If applicable)
6. ISSUED BY NAVFAC SOUTHEAST SOUTH TEXAS AREA PWD CORPUS CHRISTI/PWD INGLESIDE 8851 OCEAN DRIVE, BLDG 19 CORPUS CHRISTI TX 78419-5525	CODE N69450	7. ADMINISTERED BY (If other than item 6) See Item 6		
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)		X	9A. AMENDMENT OF SOLICITATION NO. N69450-16-Q-3226	
		X	9B. DATED (SEE ITEM 11) 23-Mar-2016	
			10A. MOD. OF CONTRACT/ORDER NO.	
			10B. DATED (SEE ITEM 13)	
CODE	FACILITY CODE			
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS				
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.				
12. ACCOUNTING AND APPROPRIATION DATA (If required)				
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.				
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.				
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).				
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:				
D. OTHER (Specify type of modification and authority)				
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.				
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) PRE-PROPOSAL INQUIRIES				
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.				
15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print) JOEL OVERSON / CONTRACTING OFFICER TEL: 361-961-3397 EMAIL: joel.overson@navy.mil		
15B. CONTRACTOR/OFFEROR _____ (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer)	16C. DATE SIGNED 15-Apr-2016	

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

SECTION SF 30 - BLOCK 14 CONTINUATION PAGE

The following have been added by full text:

PRE-PROPOSAL INQUIRIES

1 - During the Site Visit we noticed that the Ground for each area is very soft, a concrete truck would not be able to drive to these locations without getting stuck.

Question:

Can the contractor use Bagged Concrete with the minimum strength of 3500 psi?

Absolutely, the contractor can apply 3500 psi for field mix.

Is water available for the Contractor to fill the Water Tank?

Water is available any closest Hangars or Buildings.

Is there a charge for the Water?

There is no charge for water usage.

2 - On page 7 of 48 #5

It states that ALL debris shall be disposed of and hauled off daily from the Installation to prevent FOD at Airfield

Question:

Are we able to leave our equipment at work site?

The map for equipment laydown will be provided upon contractor's request. The equipment cannot be left abandoned at site since the area is in close proximity to airfield runways.

Will we be able to leave our Dumpster at site with the site debris?

Dumpster cannot be left abandoned at site since the area is in close proximity to airfield runways. The map for dumpster laydown area will be provided upon contractor's request.

3 - It was stated by the End User at the Site Visit that we have only 1 ½ weeks to do each site.

Question:

Is this the Time Frame in which we have to start and complete each site?

Refer Statement of Work paragraph 3. The period of performance is 60 days and preferred actual construction for each site not to exceed 1 ½ weeks and not interfere the airfield operations.

If yes will the contractor be able to work weekends?

The work shall be so scheduled as to cause a minimum of interference to the normal operations of the tenants. Work shall be accomplished between the hours of 7:30 A.M. and 4:30 P.M., Monday through Friday. If the Contractor desires to work on Saturday, Sunday, holidays, or outside of the Station's regular hours, an application may be submitted to the Contracting Officer for approval.

4 - On page 7 of 48 #10

It states that the Flanges shall be welded to the New Stand Pipes

Question:

It was stated on the Site Visit that the Flanges shall be Threaded Flanges.

Can this be Confirmed as to if they want them Welded or Flanged?

Threaded or Welded Flanges are acceptable.

5 - It was talked about at the Site Visit that the Contractor might be able to install the New Stand Pipe behind the Old Stand Pipe at the Site Visit.

Question:

Will this be acceptable or will this be part of the Amended SOW?

There will no amended SOW. we may need to use exact location for replacement.

6 - Will the Concrete need to have a Break Test done? (7 day, 14 day and 30 day break test)

No break test report is required for this project.

7 - What is the Time Line that the Government will be going by once the Concrete is placed?

High strength fast curing concrete usually achieves the required strength within 48 hours. Government will install the rest of flanges after 48 hours.

Concrete should sit for a minimum of 48 hours before any work is done to the top of the Flanges.

Asking this for a couple of reasons

1 - Scheduling of Project

2 - Warranty of Project (If End User Bolts Up to soon and concrete is not setup then we might have an issue)

Normally we would wait for the First Break Results to see where the concrete is.

The concentration load is minimum that 48 hours curing process shall suffice.

8 - Is any Grass Seeding going to be required at the Work Site once the Work Site is done?

Grass seeding is not included in part of statement of work. Granular base rock shall be placed around new concrete base area.

If so what type of Seeding will be required?

Not required.

(End of Summary of Changes)