

GOVERNMENT PRE AWARD INQUIRY FORM

Question No.	Date Received	REFERENCE			QUESTION	GOVERNMENT RESPONSE	Amend No.
		Page	Section	Para.			
1	8/29/2016	47	C - 1502000 - NAS Jax - Facility Investment	2.2.1	Personnel working on Fire Alarm Systems. Are all personnel to include junior technicians required to be NICET III? NICET III are personnel with a minimum of 5 years experience. This requirement would mean that no personnel who have less than 5 years experience would be able to work on or assist in the repairs or testing of Fire Alarm systems. The State of Florida only requires a FASA certification for working on Fire Alarm systems.	Yes. Personnel working on fire protection systems shall be National Institute for Certification in Engineering Technologies (NICET) Level III certified in Fire Alarm Systems or Level III certified in Inspection and Testing of Water-Based Systems, as required by Section C, Sub-annex 1502000 Facility Investment, Specification Item 2.2.1 Certification, Training, and Licensing.	0001
2	8/29/2016	47	C - 1502000 - NAS Jax - Facility Investment	2.2.1	Personnel working on Fire Protection Systems. Are all personnel to include junior technicians required to be NICET III? NICET III are personnel with a minimum of 5 years experience. This requirement would mean that no personnel who have less than 5 years experience would be able to work on or assist in the repairs or testing of Fire Protection systems. The State of Florida only requires a NICET II for working on Fire Protection systems.	See Government Response to Question #1	0001
3	8/29/2016	66	C - 1502000 - NAS Jax - Facility Investment	3.3.4	Provide a semi-annual Stand Alone Smoke Detector Report. Will there be a list that shows quantity and locations in order to estimate cost?	Requirement deleted via Amendment 0001.	0001
4	8/29/2016	90	C - 1502000 - NAS Jax - Facility Investment - Bumed	2.2.1	Personnel working on Fire Alarm Systems. Are all personnel to include junior technicians required to be NICET III? NICET III are personnel with a minimum of 5 years experience. This requirement would mean that no personnel who have less than 5 years experience would be able to work on or assist in the repairs or testing of Fire Alarm systems. The State of Florida only requires a FASA certification for working on Fire Alarm systems.	See Government Response to Question #1	0001
5	8/29/2016	90	C - 1502000 - NAS Jax - Facility Investment - Bumed	2.2.1	Personnel working on Fire Protection Systems. Are all personnel to include junior technicians required to be NICET III? NICET III are personnel with a minimum of 5 years experience. This requirement would mean that no personnel who have less than 5 years experience would be able to work on or assist in the repairs or testing of Fire Protection systems. The State of Florida only requires a NICET II for working on Fire Protection systems.	See Government Response to Question #1	0001
6	8/29/2016	119	C - 1502000 - NAS Jax - Facility Investment - Bumed	3.2.8	Are the Bumed facilities under the IMP?	No. The Contractor shall develop and implement a Preventive Maintenance (PM) program for facilities, systems, equipment and other assets identified in Section C - NAS Jacksonville, Sub-annex 1502000 Facility Investment - BUMED, Spec Item 3.2.	0001

GOVERNMENT PRE AWARD INQUIRY FORM

Question No.	Date Received	REFERENCE			QUESTION	GOVERNMENT RESPONSE	Amend No.
		Page	Section	Para.			
7	8/29/2016	58	C - 1502000 - NAS Jax - Facility Investment - NS Mayport	2.2.1	Personnel working on Fire Alarm Systems. Are all personnel to include junior technicians required to be NICET III? NICET III are personnel with a minimum of 5 years experience. This requirement would mean that no personnel who have less than 5 years experience would be able to work on or assist in the repairs or testing of Fire Alarm systems. The State of Florida only requires a FASA certification for working on Fire Alarm systems.	See Government Response to Question #1	0001
8	8/29/2016	58	C - 1502000 - NAS Jax - Facility Investment - NS Mayport	2.2.1	Personnel working on Fire Protection Systems. Are all personnel to include junior technicians required to be NICET III? NICET III are personnel with a minimum of 5 years experience. This requirement would mean that no personnel who have less than 5 years experience would be able to work on or assist in the repairs or testing of Fire Protection systems. The State of Florida only requires a NICET II for working on Fire Protection systems.	See Government Response to Question #1	0001
9	8/29/2016	98	C - 1502000 - NAS Jax - Facility Investment - MCSF-BI		Personnel working on Fire Alarm Systems. Are all personnel to include junior technicians required to be NICET III? NICET III are personnel with a minimum of 5 years experience. This requirement would mean that no personnel who have less than 5 years experience would be able to work on or assist in the repairs or testing of Fire Alarm systems. The State of Florida only requires a FASA certification for working on Fire Alarm systems.	See Government Response to Question #1	0001
10	8/29/2016	98	C - 1502000 - NAS Jax - Facility Investment - MCSF-BI		Personnel working on Fire Protection Systems. Are all personnel to include junior technicians required to be NICET III? NICET III are personnel with a minimum of 5 years experience. This requirement would mean that no personnel who have less than 5 years experience would be able to work on or assist in the repairs or testing of Fire Protection systems. The State of Florida only requires a NICET II for working on Fire Protection systems.	See Government Response to Question #1	0001
11	8/29/2016	181 & 182	J - 1502000 Facility Investment - Bumed		Will there be specific device counts such as smoke detectors and pull stations in order to create a PM plan? Without this information the incumbent has an unfair advantage.	No, information is not available	0001
12	8/29/2016	119 - 128	J - 1502000 Facility Investment - NS Mayport		Will there be specific device counts such as smoke detectors and pull stations in order to create a PM plan? Without this information the incumbent has an unfair advantage.	No, information is not available	0001
13	8/29/2016	203 - 204	J - 1502000 Facility Investment - MCSF-BI		Will there be specific device counts such as smoke detectors and pull stations in order to create a PM plan? Without this information the incumbent has an unfair advantage.	No, information is not available	0001
14	8/29/2016	104 - 123	J - 1502000 Facility Investment - NAS Jax		Will there be specific device counts such as smoke detectors and pull stations in order to create a PM plan? Without this information the incumbent has an unfair advantage.	No, information is not available	0001