

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>			1. CONTRACT ID CODE J	PAGE OF PAGES 1   2
2. AMENDMENT/MODIFICATION NO. 0002	3. EFFECTIVE DATE 15-Jan-2016	4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO.(If applicable)
6. ISSUED BY NAVFAC SOUTHEAST IPT GULFCOAST BLDG 903, PO BOX 30 NAS JACKSONVILLE JACKSONVILLE FL 32212-0030	CODE N69450	7. ADMINISTERED BY (If other than item 6) <b>See Item 6</b>		
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)		X	9A. AMENDMENT OF SOLICITATION NO. N69450-16-R-6217	
		X	9B. DATED (SEE ITEM 11) 21-Dec-2015	
			10A. MOD. OF CONTRACT/ORDER NO.	
			10B. DATED (SEE ITEM 13)	
CODE	FACILITY CODE			
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS				
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.				
12. ACCOUNTING AND APPROPRIATION DATA (If required)				
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.				
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.				
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).				
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:				
D. OTHER (Specify type of modification and authority)				
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.				
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)  The purpose of this amendment is to: 1. Provide revisions to the specifications. 2. An updated PPI Log (PPI Log as 1-15-16) has been posted to NECO/FBO.				
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.				
15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
		TEL:	EMAIL:	
15B. CONTRACTOR/OFFEROR  _____ (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA  BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED  15-Jan-2016

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

**SUMMARY OF CHANGES**

SECTION SF 30 - BLOCK 14 CONTINUATION PAGE

The following have been added by full text:

AMENDMENT 0002

1. The following specifications have been changed:

(a) Under Specification 01 11 00, Section 1.1.1, 1st Paragraph: Insert the following phrase after “removing EPDM roofing systems”:

"temporary catch basin 3rd story penthouse roof,"

(b) Under Specification Section 01 14 00, Paragraph 1.2 Add the following subparagraph:

"f.The Government will perform cooling tower shutdown and, if required, drain the holding tank. Contractor shall provide minimum of 15 day notice prior to scheduling work impacting cooling tower operations and work shall be phased as necessary to limit cooling tower shutdown to a maximum of 48 hours at a time. Work may be performed during normal work hours."

(c) Under Section 07 53 23, Paragraph 2.1 MATERIALS add the following sentence:

“EPDM roofing and flashing, and exposed adhesives and sealants are to be white.”

2. An updated PPI Log (PPI Log as of 1-15-16) has been posted to NECO under Additional Documents.

All other terms and conditions remain unchanged.

SECTION 00010 - SOLICITATION CONTRACT FORM

The Issued By organization has changed from  
NAVFAC SOUTHEAST  
ACQ SUPPORT  
BLDG 903, PO BOX 30  
NAS JACKSONVILLE  
JACKSONVILLE FL 32212-0030  
to  
NAVFAC SOUTHEAST  
ACQUISITION CORE  
BLDG 903, PO BOX 30  
NAS JACKSONVILLE  
JACKSONVILLE FL 32212-0030

(End of Summary of Changes)