

Salient Characteristics for Cord Room Right Wall Cabinets

1. There will be a total of 12 cabinets in the group. 6 upper cabinets and 6 lower cabinets. The lower cabinets will have a stackable feature in order to accommodate the upper cabinets. The overall length will be +/- 1 in of 16'3". The depth will be +/- 1 in of 2'4". The height will be +/- 1 in of 6'4".
2. On the lower cabinets there will be 1 cabinet that is +/- 1 in of 45"W X 27 3/4"D X 44"H; this cabinet will have 5 drawers of equal size. The other 5 lower cabinets will be +/- 1 in of 30"W X 27 3/4"D X 44"H; these cabinets will have 4 drawers of equal size.
3. On the upper stackable cabinets there will be 1 cabinet that is +/- 1 in of 45"W X 27 3/4"D X 31"H; this cabinet will have a bottom pan and a shelf. The other 5 upper stackable cabinets are +/- 1 in of 30"W X 27 3/4"D X 31"H; these cabinets will also have a bottom pan and a shelf.
4. The upper cabinets and lower cabinets will mirror each other in terms of width and depth so they will properly stack on top of each other.
5. User must be able to open more than one drawer at a time for most efficient usage.
6. 400-lb. capacity per drawer
7. Drawers to have a minimum of holes in the bottom to reduce contamination to lower drawers.
8. Drawer partitions must allow for fastening to drawer bottom L to R and Front to Back.
9. Dividers must be of steel ribbed construction for durability and reduced cost.

10. Drawer bodies shall not exceed 6 ½" on either the sides or backs of the drawers. This is so large items can be retrieved easily.
11. All cabinets are 27 3/4" deep
12. All partitions and dividers must be metal. No aluminum.
13. All units to be a single welded unit with no need to assemble any cabinets with drawers in them.
14. Drawer must be a minimum of 25"W X 25"D to most efficiently accommodate items of 6", 8" and 12".
15. Cabinet must be supplied with the capability to add a lock and key that cannot be duplicated on conventional equipment for maximum security.
16. Drawer end caps must be non snag design and attached to drawer pull mechanically (screwed into drawer front) and not via friction.

Salient Characteristics for Cord Room Left Wall Cabinets

1. There will be a total of 12 cabinets in the group. 6 upper cabinets and 6 lower cabinets. The lower cabinets will have a stackable feature in order to accommodate the upper cabinets. The overall length will be +/- 1 in of 20'. The depth will be +/- 1 in of 2'4". The height will be +/- 1 in of 6'4".
2. On the lower cabinets there will be 2 cabinets that are +/- 1 in of 60"W X 27 3/4"D X 44"H; this cabinet will have 5 drawers of equal size. The other 4 lower cabinets will be +/- 1 in of 30"W X 27 3/4"D X 44"H; these cabinets will have 4 drawers of equal size.
3. On the upper stackable cabinets there will be 2 cabinets that are +/- 1 in of 60"W X 27 3/4"D X 31"H; these cabinets will have a bottom pan and a shelf. The other 4 upper stackable cabinets are +/- 1 in of 30"W X 27 3/4"D X 31"H; these cabinets will also have a bottom pan and a shelf.
4. The upper cabinets and lower cabinets will mirror each other in terms of width and depth so they will properly stack on top of each other.
5. User must be able to open more than one drawer at a time for most efficient usage.
6. 400-lb. capacity per drawer
7. Drawers to have a minimum of holes in the bottom to reduce contamination to lower drawers.
8. Drawer partitions must allow for fastening to drawer bottom L to R and Front to Back.
9. Dividers must be of steel ribbed construction for durability and reduced cost.

10. Drawer bodies shall not exceed 6 ½" on either the sides or backs of the drawers. This is so large items can be retrieved easily.
11. All cabinets are 27 3/4" deep
12. All partitions and dividers must be metal. No aluminum.
13. All units to be a single welded unit with no need to assemble any cabinets with drawers in them.
14. Drawer must be a minimum of 25"W X 25"D to most efficiently accommodate items of 6", 8" and 12".
15. Cabinet must be supplied with the capability to add a lock and key that cannot be duplicated on conventional equipment for maximum security.
16. Drawer end caps must be non snag design and attached to drawer pull mechanically (screwed into drawer front) and not via friction.