

NSN: LL-S05-0901

SMIC: N/A

DOC:

**SPECIFICATIONS FOR: FILM PLASTIC, SHRINK, HIGH STRENGTH, WHITE**

- 1. 0.009" THICK (0.0085 MINIMUM)**
- 2. 25 TO 30 FEET WIDE**
- 3. 60 TO 80 FEET LONG**
- 4. EACH ANNUAL CONTRACT REQUIRES A SIGNED CERTIFICATION THAT MATERIAL MEETS ONE OR MORE OF THE FOLLOWING FIRE RETARDANT REQUIREMENTS OF PSNS FIRE DEPARTMENT (VERBATIUM WORDING ONLY):**
  - a. NFPA 701-89 LARGE SCALE TEST**
  - b. NFPA 701-96 TEST 1**
  - c. NFPA 701-96 TEST 2**
- 5. EACH ORDER MUST COME WITH A SIGNED CERTIFICATION THAT THE FORMULA AND PROCESS FOR MANUFACTURING HAS NOT CHANGED FROM THE APPROVED FORMULA AND PROCESS INCLUDED IN THE ANNUAL CONTRACT.**
- 6. TO BE INDELIBLY MARKED EVERY 4 FEET WITH "FR" OR "FIRE RETARDANT" IN AT LEAST 2 INCH HIGH LETTERS DOWN THE SIDE OF THE MATERIAL. MARKING TO BE MINIMUM 4" FROM EDGE OF MATERIAL.**
- 7. COLOR TO BE WHITE, NOT TRANSPARENT**
- 8. SAMPLE SPECIMENS SHALL BE SENT FOR TESTING, WHICH MAY INCLUDE TESTS FOR SELF-ADHERENCE AND EASE OF SHRINKING.**